

Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using  
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P1438993

Luminaire Tested: CB2-D-030U-085D-927-1D-UNV-STD-W-4

Issue Date: 3/31/2026

**Test Information**

Test Method: LM-79-2024  
Report Number: P1438993  
REPORT IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2312-242-13, G2-2312-242-18)  
Test Lab: INNOVATION CENTER  
Issue Date: 3/31/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: CORELITE  
Catalog Number: CB2-D-030U-085D-927-1D-UNV-STD-W-4  
Description: CORELITE BASIC SLOT LED LUMINAIRE, DIFFUSER DUST COVER UPLIGHT  
2-INCH APERTURE  
DOWNLIGHT 850 LUMENS PER FOOT  
UPLIGHT 300 LUMENS PER FOOT  
Light Source: 2700K CCT, 90 CRI LEDS  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 4369.8 lumens  
Efficiency: N/A  
Efficacy: 117.8 lumens/watt  
Spacing Criteria (0/90/45): 1.17 / 1.09 / 1.24  
Luminous Opening: Rectangular (W 0.15' x L: 4' x H: 0')  
CIE Type: Semi-Direct

Input Watts (W): 37.1  
Input Voltage (V): 120  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1438993

CATALOG NUMBER: CB2-D-030U-085D-927-1D-UNV-STD-W-4

### Luminous Intensity Polar Plot





TEST NUMBER: P1438993

CATALOG NUMBER: CB2-D-030U-085D-927-1D-UNV-STD-W-4

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	113	113	113	113	107	107	107	107	97	97	97	87	87	87	79	79	79	74				
1	104	99	95	92	98	94	91	88	86	83	80	77	75	73	70	68	67	63				
2	95	87	81	75	90	83	77	73	75	71	67	68	65	62	62	59	57	53				
3	86	77	69	63	82	73	66	61	67	61	57	61	56	53	55	52	49	46				
4	79	68	60	54	75	65	58	52	60	54	49	54	49	45	49	46	42	39				
5	73	61	53	47	69	58	51	45	54	47	42	49	44	40	45	40	37	34				
6	68	55	47	41	64	53	45	40	49	42	37	44	39	35	41	36	33	30				
7	63	50	42	36	59	48	40	35	44	38	33	41	35	31	37	33	29	27				
8	58	46	38	32	55	44	36	31	40	34	30	37	32	28	34	30	26	24				
9	54	42	34	29	52	40	33	28	37	31	27	34	29	25	32	27	24	22				
10	51	39	31	26	49	37	30	26	35	28	24	32	27	23	30	25	22	20				

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	24315	24315	24315
5°	24109	24147	24315
10°	23972	23915	23896
15°	23593	23438	23245
20°	23221	22706	22389
25°	22596	21960	21343
30°	21970	21003	20208
35°	21250	20023	19068
40°	20488	19103	17985
45°	19720	18141	16929
50°	19030	17204	15900
55°	18177	16231	14931
60°	17201	15303	13962
65°	16168	14272	12994
70°	15023	13118	11759
75°	13668	11871	10646
80°	12227	10401	9649
85°	9393	8553	7054

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 19720 cd/sqm



TEST NUMBER: P1438993

CATALOG NUMBER: CB2-D-030U-085D-927-1D-UNV-STD-W-4

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	131.3	3.0
10°-20°	365.9	8.4
20°-30°	526.2	12.0
30°-40°	591.4	13.5
40°-50°	571.3	13.1
50°-60°	482.7	11.0
60°-70°	346.7	7.9
70°-80°	189.5	4.3
80°-90°	50.4	1.2
90°-100°	16.9	0.4
100°-110°	69.6	1.6
110°-120°	126.4	2.9
120°-130°	172.0	3.9
130°-140°	198.5	4.5
140°-150°	200.1	4.6
150°-160°	172.6	4.0
160°-170°	117.0	2.7
170°-180°	41.3	0.9
0°-30°	1023.4	23.4
0°-40°	1614.8	37.0
0°-60°	2668.8	61.1
0°-90°	3255.4	74.5
90°-120°	212.9	4.9
90°-150°	783.4	17.9
90°-180°	1114.0	25.5
0°-180°	4369.8	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	1396	1396	1396	1396	1396	
5°	1379	1398	1381	1381	1391	131
15°	1308	1320	1300	1287	1289	369
25°	1176	1177	1143	1117	1111	541
35°	999	988	942	905	897	624
45°	801	784	736	698	687	619
55°	599	577	534	501	492	535
65°	392	378	346	322	315	389
75°	203	191	176	162	158	217
85°	47	44	43	37	35	56
90°	0	0	0	0	0	2
95°	16	14	14	11	11	19
105°	69	68	66	62	62	73
115°	131	130	128	124	124	129
125°	195	197	193	188	189	174
135°	259	262	258	253	255	200
145°	321	325	320	316	319	201
155°	376	380	374	372	375	173
165°	416	420	414	412	416	117
175°	435	440	434	432	432	41
180°	437	437	437	437	437	

TEST NUMBER: P1438993

CATALOG NUMBER: CB2-D-030U-085D-927-1D-UNV-STD-W-4

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	1396.0	1396.0	1396.0	1396.0	1396.0
2.5°	1386.6	1403.3	1390.9	1392.7	1395.2
5°	1378.9	1397.7	1381.1	1381.3	1390.7
7.5°	1369.1	1386.8	1365.9	1362.0	1370.8
10°	1355.4	1373.2	1352.2	1344.9	1351.1
12.5°	1337.4	1354.4	1334.2	1322.6	1328.0
15°	1308.4	1319.9	1299.8	1287.0	1289.1
17.5°	1276.7	1283.8	1254.9	1244.2	1242.1
20°	1252.8	1259.1	1225.0	1210.0	1207.9
22.5°	1222.0	1227.4	1191.6	1173.2	1170.3
25°	1175.8	1176.9	1142.7	1116.9	1110.6
27.5°	1127.5	1124.2	1086.2	1055.7	1047.5
30°	1092.4	1088.3	1044.3	1012.1	1004.8
32.5°	1054.8	1047.3	1003.3	968.5	961.2
35°	999.4	987.9	941.7	905.2	896.8
37.5°	940.4	927.5	882.1	842.3	832.9
40°	901.1	886.5	840.2	800.4	791.0
42.5°	861.8	845.5	798.3	758.5	748.2
45°	800.6	783.9	736.5	697.8	687.3
47.5°	742.5	721.2	675.1	636.6	626.2
50°	702.3	679.3	634.9	597.3	586.8
52.5°	661.2	637.4	594.8	558.8	548.4
55°	598.6	576.7	534.5	501.1	491.7
57.5°	536.6	515.5	477.0	445.1	435.9
60°	493.8	476.1	439.3	409.2	400.8
62.5°	452.8	436.7	401.7	374.1	365.8
65°	392.3	377.7	346.3	321.6	315.3
67.5°	333.5	318.9	293.5	271.3	264.2
70°	295.0	280.4	257.6	237.2	230.9
72.5°	258.3	242.8	224.3	205.6	201.0
75°	203.1	190.6	176.4	162.4	158.2
77.5°	154.4	142.2	131.9	122.0	121.0
80°	121.9	111.4	103.7	97.2	96.2
82.5°	91.1	83.1	78.0	73.3	73.1
85°	47.0	43.9	42.8	37.4	35.3
87.5°	13.7	13.7	12.0	10.3	10.3
90°	0.0	0.0	0.3	0.0	0.3
92.5°	4.1	3.6	3.3	2.2	2.5
95°	16.4	14.4	13.6	10.6	10.6
97.5°	30.9	28.9	27.8	24.7	24.0
100°	41.2	39.2	38.2	34.7	34.1
102.5°	51.9	50.9	49.1	45.4	44.7
105°	68.8	67.8	66.1	62.4	61.7
107.5°	86.3	86.5	83.9	80.8	79.9
110°	98.8	98.5	96.5	93.4	92.7



TEST NUMBER: P1438993

CATALOG NUMBER: CB2-D-030U-085D-927-1D-UNV-STD-W-4

**CANDELA DISTRIBUTION (continued):**

	0°	22.5°	45°	67.5°	90°
112.5°	111.7	<i>111.1</i>	109.0	105.9	105.2
115°	130.9	<i>130.5</i>	128.2	124.4	124.1
117.5°	149.1	<i>150.2</i>	147.4	143.4	143.3
120°	162.2	<i>163.6</i>	160.2	156.8	156.1
122.5°	175.1	<i>176.7</i>	173.3	169.3	169.5
125°	194.6	<i>196.6</i>	192.6	188.5	188.8
127.5°	213.5	<i>216.0</i>	212.2	208.1	208.5
130°	226.3	<i>229.3</i>	225.3	220.9	221.5
132.5°	239.4	<i>242.4</i>	238.4	233.7	234.9
135°	259.4	<i>262.4</i>	258.0	253.3	254.9
137.5°	278.2	<i>281.2</i>	276.4	272.4	274.4
140°	290.7	<i>293.7</i>	288.7	285.0	287.0
142.5°	303.0	<i>306.5</i>	301.2	297.3	299.8
145°	321.4	<i>325.1</i>	320.0	316.3	318.7
147.5°	338.9	<i>342.5</i>	337.4	333.9	336.3
150°	350.0	<i>353.7</i>	348.3	345.3	348.0
152.5°	360.4	<i>364.6</i>	359.0	356.0	359.4
155°	375.9	<i>379.6</i>	374.2	371.9	374.9
157.5°	389.4	<i>393.7</i>	388.3	386.4	388.8
160°	398.4	<i>402.4</i>	397.1	395.1	397.8
162.5°	405.3	<i>409.5</i>	404.4	402.2	405.4
165°	415.5	<i>419.8</i>	414.5	412.2	415.8
167.5°	423.5	<i>428.1</i>	422.7	420.3	424.1
170°	428.4	<i>432.8</i>	427.1	424.4	428.4
172.5°	431.7	<i>436.3</i>	430.3	427.7	430.3
175°	435.2	<i>439.9</i>	434.2	431.5	432.5
177.5°	436.9	<i>440.7</i>	436.1	433.7	436.9
180°	436.9	<i>436.9</i>	436.9	436.9	436.9



TEST NUMBER: P1438993

CATALOG NUMBER: CB2-D-030U-085D-927-1D-UNV-STD-W-4

**CIE UGR TABLE:**

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	20.11	21.22	20.82	21.96	22.83	19.01	20.12	19.72	20.86	21.73
	3H	21.77	22.77	22.50	23.52	24.42	20.55	21.55	21.28	22.30	23.20
	4H	22.41	23.35	23.16	24.11	25.03	21.14	22.08	21.89	22.84	23.75
	6H	22.82	23.70	23.59	24.46	25.39	21.52	22.39	22.28	23.16	24.09
	8H	22.98	23.81	23.75	24.59	25.53	21.67	22.50	22.44	23.28	24.21
	12H	23.06	23.85	23.84	24.63	25.59	21.74	22.53	22.52	23.31	24.27
4H	2H	20.54	21.49	21.30	22.24	23.16	19.67	20.61	20.42	21.37	22.29
	3H	22.44	23.22	23.20	24.01	24.95	21.43	22.21	22.19	23.01	23.94
	4H	23.19	23.91	23.97	24.70	25.66	22.11	22.83	22.89	23.62	24.58
	6H	23.73	24.35	24.52	25.16	26.13	22.60	23.22	23.40	24.03	25.01
	8H	23.94	24.52	24.74	25.33	26.31	22.80	23.37	23.60	24.19	25.17
	12H	24.06	24.58	24.88	25.41	26.40	22.90	23.42	23.72	24.25	25.24
8H	4H	23.37	23.95	24.17	24.76	25.74	22.40	22.98	23.21	23.79	24.78
	6H	24.02	24.50	24.85	25.35	26.34	23.02	23.50	23.85	24.35	25.33
	8H	24.31	24.74	25.15	25.59	26.59	23.30	23.72	24.14	24.57	25.57
	12H	24.50	24.87	25.34	25.72	26.77	23.46	23.83	24.30	24.67	25.73
12H	4H	23.36	23.88	24.18	24.71	25.70	22.42	22.94	23.24	23.77	24.76
	6H	24.05	24.48	24.89	25.33	26.33	23.08	23.51	23.92	24.36	25.36
	8H	24.38	24.76	25.22	25.60	26.65	23.40	23.78	24.24	24.62	25.67