

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P1438612

Luminaire Tested: CB2-030U-055D-940-1D-UNV-STD-W-8

Issue Date: 3/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1438612
REPORT IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2506-466-1, G2-2312-242-18)
Test Lab: INNOVATION CENTER
Issue Date: 3/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: CB2-030U-055D-940-1D-UNV-STD-W-8
Description: CORELITE BASIC SLOT LED LUMINAIRE, OPEN UPLIGHT
2-INCH APERTURE
DOWNLIGHT 550 LUMENS PER FOOT
UPLIGHT 300 LUMENS PER FOOT
Light Source: 4000K CCT, 90 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7802.1 lumens
Efficiency: N/A
Efficacy: 142.1 lumens/watt
Spacing Criteria (0/90/45): 1.17 / 1.09 / 1.24
Luminous Opening: Rectangular (W 0.15' x L: 8' x H: 0')
CIE Type: Semi-Direct

Input Watts (W): 54.9
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1438612

CATALOG NUMBER: CB2-030U-055D-940-1D-UNV-STD-W-8

Luminous Intensity Polar Plot





TEST NUMBER: P1438612

CATALOG NUMBER: CB2-030U-055D-940-1D-UNV-STD-W-8

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20										
RC	80									70									50									30									10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0														
RCR																																						
0	110	110	110	110	103	103	103	103	90	90	90	78	78	78	67	67	67	62																				
1	101	96	92	89	94	90	87	84	79	77	74	69	67	66	60	58	57	53																				
2	92	84	78	73	86	79	74	69	70	66	62	61	58	55	53	51	48	44																				
3	84	74	67	61	78	70	64	58	62	57	52	54	50	47	47	44	42	38																				
4	77	66	58	52	72	62	55	50	55	49	45	48	44	40	42	39	36	33																				
5	71	59	51	45	66	56	48	43	49	44	39	44	39	35	38	34	32	29																				
6	65	53	45	39	61	50	43	37	45	39	34	40	35	31	35	31	28	25																				
7	61	48	40	35	57	46	38	33	41	35	30	36	31	28	32	28	25	22																				
8	56	44	36	31	53	42	34	29	37	31	27	33	28	25	29	25	22	20																				
9	53	40	33	28	49	38	31	26	34	28	24	31	26	22	27	23	20	18																				
10	49	37	30	25	46	35	28	24	32	26	22	28	24	20	25	21	19	17																				

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	18064	18064	18064
5°	17911	17939	18064
10°	17810	17767	17753
15°	17528	17413	17270
20°	17252	16869	16633
25°	16789	16315	15858
30°	16324	15605	15013
35°	15789	14876	14167
40°	15222	14192	13362
45°	14652	13479	12578
50°	14138	12783	11814
55°	13505	12058	11093
60°	12781	11370	10374
65°	12012	10604	9656
70°	11163	9747	8736
75°	10155	8819	7911
80°	9082	7728	7167
85°	6984	6345	5236

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 14652 cd/sqm



TEST NUMBER: P1438612

CATALOG NUMBER: CB2-030U-055D-940-1D-UNV-STD-W-8

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	195.1	2.5
10°-20°	543.8	7.0
20°-30°	781.9	10.0
30°-40°	878.8	11.3
40°-50°	848.9	10.9
50°-60°	717.2	9.2
60°-70°	515.2	6.6
70°-80°	281.6	3.6
80°-90°	74.8	1.0
90°-100°	18.1	0.2
100°-110°	115.3	1.5
110°-120°	366.4	4.7
120°-130°	531.8	6.8
130°-140°	571.9	7.3
140°-150°	538.5	6.9
150°-160°	438.6	5.6
160°-170°	285.5	3.7
170°-180°	98.7	1.3
0°-30°	1520.7	19.5
0°-40°	2399.5	30.8
0°-60°	3965.6	50.8
0°-90°	4837.2	62.0
90°-120°	499.9	6.4
90°-150°	2142.0	27.5
90°-180°	2965.0	38.0
0°-180°	7802.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2074	2074	2074	2074	2074	
5°	2049	2077	2052	2052	2066	195
15°	1944	1961	1931	1912	1916	548
25°	1747	1749	1698	1660	1650	804
35°	1485	1468	1399	1345	1333	928
45°	1190	1165	1094	1037	1021	919
55°	890	857	794	745	731	795
65°	583	561	515	478	469	578
75°	302	283	262	241	235	323
85°	70	65	64	56	52	83
90°	0	0	0	1	1	4
95°	41	12	13	8	8	52
105°	216	225	23	26	28	228
115°	410	419	422	427	245	403
125°	582	592	592	602	610	520
135°	732	741	740	744	754	565
145°	857	864	858	859	870	536
155°	952	958	947	945	959	439
165°	1015	1018	1008	1003	1014	287
175°	1045	1047	1034	1027	1032	99
180°	1040	1040	1040	1040	1040	



TEST NUMBER: P1438612

CATALOG NUMBER: CB2-030U-055D-940-1D-UNV-STD-W-8

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2074.3	2074.3	2074.3	2074.3	2074.3
2.5°	2060.4	2085.2	2066.7	2069.4	2073.1
5°	2048.9	2076.9	2052.1	2052.4	2066.4
7.5°	2034.3	2060.7	2029.6	2023.8	2036.9
10°	2014.0	2040.4	2009.2	1998.3	2007.6
12.5°	1987.3	2012.5	1982.5	1965.3	1973.3
15°	1944.1	1961.2	1931.4	1912.4	1915.5
17.5°	1897.1	1907.7	1864.7	1848.7	1845.6
20°	1861.5	1870.8	1820.2	1797.9	1794.8
22.5°	1815.8	1823.8	1770.7	1743.2	1738.9
25°	1747.2	1748.7	1697.9	1659.6	1650.3
27.5°	1675.4	1670.4	1614.1	1568.7	1556.6
30°	1623.3	1617.1	1551.8	1503.9	1493.0
32.5°	1567.4	1556.2	1490.8	1439.1	1428.2
35°	1485.1	1468.0	1399.3	1345.0	1332.6
37.5°	1397.4	1378.1	1310.7	1251.6	1237.6
40°	1339.0	1317.2	1248.4	1189.3	1175.4
42.5°	1280.5	1256.3	1186.2	1127.0	1111.8
45°	1189.7	1164.8	1094.4	1036.8	1021.3
47.5°	1103.2	1071.6	1003.2	946.0	930.4
50°	1043.5	1009.4	943.5	887.5	872.0
52.5°	982.5	947.1	883.7	830.3	814.8
55°	889.5	856.8	794.2	744.6	730.6
57.5°	797.3	766.0	708.7	661.4	647.7
60°	733.8	707.4	652.8	608.0	595.6
62.5°	672.8	648.9	596.9	555.9	543.5
65°	582.9	561.2	514.6	477.9	468.6
67.5°	495.6	473.8	436.2	403.2	392.6
70°	438.4	416.6	382.8	352.4	343.1
72.5°	383.7	360.8	333.2	305.4	298.6
75°	301.8	283.1	262.1	241.3	235.1
77.5°	229.4	211.3	196.0	181.4	179.8
80°	181.1	165.5	154.1	144.5	142.9
82.5°	135.3	123.5	115.9	109.0	108.6
85°	69.9	65.2	63.5	55.5	52.4
87.5°	20.3	20.3	17.8	15.4	15.4
90°	0.0	0.0	0.0	0.8	0.8
92.5°	11.4	4.4	3.0	4.4	4.4
95°	41.4	11.9	12.8	8.3	7.5
97.5°	85.9	19.3	18.5	20.3	21.1
100°	119.5	39.4	20.3	23.3	24.1
102.5°	156.8	148.5	20.9	25.1	26.5
105°	216.5	224.6	22.6	26.3	27.8
107.5°	275.2	283.3	105.0	27.2	28.7
110°	314.3	322.4	332.3	27.9	29.3



TEST NUMBER: P1438612

CATALOG NUMBER: CB2-030U-055D-940-1D-UNV-STD-W-8

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	351.0	360.8	368.4	62.0	30.5
115°	409.8	418.6	422.5	427.4	245.1
117.5°	461.6	472.5	477.0	485.4	493.7
120°	497.7	508.0	511.3	519.7	528.5
122.5°	533.2	542.3	544.3	554.0	562.2
125°	581.9	592.2	592.4	602.4	610.5
127.5°	630.6	639.5	639.1	646.5	655.5
130°	663.1	669.0	669.1	675.4	684.9
132.5°	690.2	698.4	698.6	703.6	713.2
135°	732.3	741.1	739.8	744.5	754.1
137.5°	771.8	780.4	778.0	782.0	791.8
140°	797.7	805.1	801.5	805.5	816.5
142.5°	821.8	829.1	823.7	827.1	838.8
145°	857.1	863.7	857.8	858.9	869.9
147.5°	888.5	895.0	887.9	888.9	899.2
150°	909.0	914.9	906.0	907.0	917.2
152.5°	927.0	932.3	922.8	922.6	934.7
155°	951.8	957.7	947.3	945.4	958.6
157.5°	974.4	979.8	969.4	968.0	978.3
160°	989.4	993.1	982.7	980.6	990.9
162.5°	999.6	1003.9	993.5	990.3	1000.5
165°	1015.0	1017.9	1007.5	1003.2	1013.5
167.5°	1028.2	1031.6	1018.1	1014.3	1025.4
170°	1036.0	1038.2	1024.8	1019.7	1030.8
172.5°	1040.8	1042.5	1029.0	1023.3	1030.8
175°	1045.1	1047.3	1033.8	1027.1	1032.3
177.5°	1045.8	1047.0	1036.8	1031.0	1039.8
180°	1039.8	1039.8	1039.8	1039.8	1039.8



TEST NUMBER: P1438612

CATALOG NUMBER: CB2-030U-055D-940-1D-UNV-STD-W-8

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	18.10	19.06	18.95	19.93	21.02	17.00	17.96	17.85	18.83	19.92
	3H	19.75	20.62	20.61	21.50	22.61	18.53	19.40	19.40	20.28	21.40
	4H	20.38	21.20	21.26	22.09	23.21	19.11	19.93	19.99	20.81	21.94
	6H	20.79	21.55	21.68	22.44	23.58	19.49	20.24	20.38	21.13	22.28
	8H	20.94	21.66	21.84	22.57	23.71	19.63	20.35	20.53	21.26	22.40
	12H	21.02	21.70	21.92	22.61	23.77	19.70	20.38	20.60	21.29	22.45
4H	2H	18.52	19.34	19.40	20.22	21.35	17.65	18.46	18.53	19.35	20.48
	3H	20.40	21.08	21.29	22.00	23.14	19.39	20.07	20.28	20.99	22.13
	4H	21.15	21.77	22.05	22.68	23.85	20.07	20.69	20.97	21.60	22.77
	6H	21.67	22.21	22.59	23.15	24.32	20.55	21.08	21.47	22.02	23.19
	8H	21.88	22.38	22.80	23.31	24.50	20.74	21.24	21.66	22.17	23.36
	12H	21.99	22.44	22.93	23.39	24.58	20.83	21.28	21.78	22.23	23.42
8H	4H	21.31	21.81	22.24	22.75	23.93	20.35	20.85	21.27	21.78	22.96
	6H	21.96	22.37	22.91	23.35	24.53	20.96	21.37	21.91	22.35	23.53
	8H	22.25	22.62	23.21	23.58	24.78	21.23	21.60	22.19	22.56	23.76
	12H	22.43	22.75	23.39	23.71	24.96	21.39	21.71	22.35	22.67	23.92
12H	4H	21.30	21.75	22.24	22.70	23.89	20.36	20.81	21.30	21.76	22.95
	6H	21.99	22.36	22.95	23.32	24.52	21.02	21.39	21.98	22.35	23.55
	8H	22.31	22.63	23.27	23.59	24.84	21.33	21.66	22.29	22.61	23.86