

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2024 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P1439183

Luminaire Tested: CB3-055U-055D-930-1D-UNV-STD-W-4

Issue Date: 3/31/2026

Test Information

Test Method: LM-79-2024
Report Number: P1439183
REPORT IS SCALED FROM IESNA LM-79-24 TEST DATA (G2-2506-466-2, G2-2312-242-8)
Test Lab: INNOVATION CENTER
Issue Date: 3/31/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: CB3-055U-055D-930-1D-UNV-STD-W-4
Description: CORELITE BASIC SLOT LED LUMINAIRE, OPEN UPLIGHT
3-INCH APERTURE
DOWNLIGHT 550 LUMENS PER FOOT
UPLIGHT 550 LUMENS PER FOOT
Light Source: 3000K CCT, 90 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 4930.0 lumens
Efficiency: N/A
Efficacy: 151.7 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.13 / 1.26
Luminous Opening: Rectangular (W 0.24' x L: 4' x H: 0')
CIE Type: General Diffuse

Input Watts (W): 32.5
Input Voltage (V): 120
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1439183

CATALOG NUMBER: CB3-055U-055D-930-1D-UNV-STD-W-4

Luminous Intensity Polar Plot





TEST NUMBER: P1439183

CATALOG NUMBER: CB3-055U-055D-930-1D-UNV-STD-W-4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20	
RC	80					70					50					30					10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	106	106	106	106	97	97	97	97	81	81	81	66	66	66	52	52	52	46				
1	97	93	89	86	89	85	82	79	71	69	67	58	57	55	47	46	45	39				
2	88	81	75	70	81	75	70	65	63	59	56	52	49	47	41	39	38	33				
3	81	72	64	59	74	66	60	55	55	51	47	46	42	40	37	34	32	28				
4	74	63	56	50	68	59	52	46	49	44	40	41	37	34	33	30	28	24				
5	68	57	49	43	62	52	45	40	44	39	35	37	33	30	30	27	24	21				
6	63	51	43	37	57	47	40	35	40	34	30	33	29	26	27	24	22	19				
7	58	46	38	32	53	42	35	31	36	31	27	30	26	23	25	22	19	17				
8	54	42	34	29	49	39	32	27	33	28	24	28	24	21	23	20	17	15				
9	50	38	31	26	46	35	29	24	30	25	21	25	21	18	21	18	16	13				
10	47	35	28	23	43	32	26	22	28	23	19	24	20	17	19	16	14	12				

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	10712	10712	10712
5°	10660	10668	10730
10°	10614	10599	10599
15°	10451	10451	10388
20°	10282	10176	10088
25°	10022	9896	9720
30°	9776	9522	9293
35°	9520	9166	8841
40°	9177	8739	8361
45°	8865	8359	7842
50°	8544	7905	7338
55°	8196	7466	6857
60°	7821	7015	6314
65°	7381	6498	5743
70°	6874	5895	5114
75°	6230	5172	4555
80°	5434	4340	4033
85°	4193	3661	3661

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 8865 cd/sqm



TEST NUMBER: P1439183

CATALOG NUMBER: CB3-055U-055D-930-1D-UNV-STD-W-4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	89.3	1.8
10°-20°	250.9	5.1
20°-30°	364.6	7.4
30°-40°	414.5	8.4
40°-50°	402.4	8.2
50°-60°	339.7	6.9
60°-70°	241.7	4.9
70°-80°	129.1	2.6
80°-90°	34.1	0.7
90°-100°	20.8	0.4
100°-110°	150.9	3.1
110°-120°	358.9	7.3
120°-130°	458.5	9.3
130°-140°	494.5	10.0
140°-150°	466.2	9.5
150°-160°	380.3	7.7
160°-170°	247.8	5.0
170°-180°	85.7	1.7
0°-30°	704.8	14.3
0°-40°	1119.3	22.7
0°-60°	1861.5	37.8
0°-90°	2266.5	46.0
90°-120°	530.6	10.8
90°-150°	1949.8	39.5
90°-180°	2664.0	54.0
0°-180°	4930.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	947	947	947	947	947	
5°	939	950	939	938	945	89
15°	892	900	892	887	887	251
25°	803	805	793	782	779	370
35°	689	683	664	644	640	429
45°	554	546	522	497	490	427
55°	416	404	378	354	348	371
65°	276	266	243	221	214	273
75°	142	135	118	106	104	152
85°	32	30	28	28	28	38
90°	0	0	0	1	0	3
95°	38	7	9	10	10	47
105°	191	194	197	14	15	202
115°	358	361	362	367	369	354
125°	509	513	512	517	520	455
135°	640	643	638	643	647	493
145°	745	749	740	745	749	466
155°	825	832	820	822	828	380
165°	879	884	875	872	878	248
175°	905	909	897	892	895	86
180°	902	902	902	902	902	

TEST NUMBER: P1439183

CATALOG NUMBER: CB3-055U-055D-930-1D-UNV-STD-W-4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	946.7	946.7	946.7	946.7	946.7
2.5°	941.8	951.3	942.9	944.0	946.1
5°	938.6	950.4	939.3	938.1	944.7
7.5°	931.3	942.1	930.5	927.8	933.8
10°	923.8	935.6	922.5	919.2	922.5
12.5°	910.4	922.7	912.2	906.8	909.6
15°	892.2	900.1	892.2	886.8	886.8
17.5°	870.0	878.3	863.4	859.6	858.2
20°	853.9	861.1	845.1	839.7	837.8
22.5°	832.4	839.1	825.8	816.6	814.1
25°	802.8	805.4	792.7	781.9	778.6
27.5°	773.1	773.7	756.3	743.1	738.8
30°	748.3	749.0	728.8	714.6	711.3
32.5°	723.6	721.6	702.5	685.6	683.4
35°	689.2	682.6	663.6	644.0	640.1
37.5°	647.6	643.7	621.3	601.6	595.7
40°	621.3	614.7	591.7	572.0	566.1
42.5°	594.9	587.3	563.7	541.9	535.5
45°	554.0	545.5	522.4	497.4	490.1
47.5°	512.9	503.5	478.2	453.9	445.9
50°	485.4	475.6	449.1	425.4	416.9
52.5°	457.5	447.1	420.6	396.4	389.4
55°	415.5	404.3	378.5	354.2	347.6
57.5°	373.6	362.5	336.8	313.8	305.9
60°	345.6	335.1	310.0	286.9	279.0
62.5°	317.1	307.1	282.5	260.0	252.7
65°	275.7	265.8	242.7	221.1	214.5
67.5°	234.7	226.2	203.5	183.6	178.3
70°	207.8	199.9	178.2	159.9	154.6
72.5°	181.9	173.5	152.9	137.3	133.7
75°	142.5	134.6	118.3	106.2	104.2
77.5°	106.5	100.1	85.9	79.0	78.0
80°	83.4	77.5	66.6	61.9	61.9
82.5°	61.9	57.0	49.9	47.9	47.9
85°	32.3	29.6	28.2	28.2	28.2
87.5°	9.7	9.7	9.1	8.7	8.6
90°	0.0	0.0	0.0	0.7	0.0
92.5°	10.3	4.0	3.3	3.9	3.8
95°	38.1	6.8	8.8	9.5	9.5
97.5°	76.7	75.3	10.3	12.4	12.5
100°	106.1	109.4	10.9	12.9	13.6
102.5°	138.7	141.5	20.1	13.5	14.1
105°	191.1	193.8	196.6	14.3	15.0
107.5°	243.2	245.2	247.0	222.4	83.2
110°	277.5	279.5	280.2	287.0	288.4



TEST NUMBER: P1439183

CATALOG NUMBER: CB3-055U-055D-930-1D-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	309.6	312.1	313.4	319.2	321.6
115°	358.4	361.1	361.8	367.3	369.3
117.5°	404.8	407.6	408.9	413.3	416.5
120°	435.3	438.6	439.4	444.9	447.5
122.5°	465.2	469.1	468.7	473.7	477.4
125°	509.4	512.7	511.5	517.0	520.3
127.5°	551.4	553.4	550.6	557.4	560.2
130°	578.1	580.1	576.7	582.9	586.3
132.5°	602.6	605.6	601.8	607.4	610.8
135°	640.0	643.3	638.0	642.8	646.8
137.5°	673.3	677.3	670.9	676.5	680.0
140°	695.1	699.1	691.0	697.2	701.2
142.5°	715.2	720.3	710.6	716.3	720.8
145°	744.7	749.4	740.0	744.8	748.8
147.5°	772.8	776.7	767.7	771.2	774.0
150°	789.6	793.6	783.5	787.0	790.3
152.5°	803.2	808.8	798.7	801.2	806.1
155°	825.0	831.6	820.2	822.4	827.7
157.5°	845.0	851.0	839.5	841.4	846.1
160°	857.0	862.9	851.5	852.3	857.0
162.5°	866.2	871.7	861.9	860.5	866.2
165°	879.4	884.1	874.6	872.1	878.0
167.5°	890.4	895.7	884.2	882.0	888.8
170°	896.4	901.7	889.6	886.4	893.7
172.5°	900.2	905.0	893.4	889.1	894.8
175°	904.6	909.2	897.1	892.4	895.0
177.5°	905.8	909.5	899.8	895.6	902.0
180°	902.5	902.5	902.5	902.5	902.5



TEST NUMBER: P1439183

CATALOG NUMBER: CB3-055U-055D-930-1D-UNV-STD-W-4

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	15.00	15.82	16.00	16.82	18.15	13.92	14.74	14.92	15.74	17.07
	3H	16.67	17.40	17.67	18.41	19.76	15.33	16.07	16.34	17.08	18.43
	4H	17.29	17.99	18.31	19.00	20.36	15.85	16.54	16.87	17.56	18.91
	6H	17.68	18.31	18.70	19.33	20.70	16.17	16.80	17.19	17.82	19.19
	8H	17.81	18.42	18.85	19.46	20.82	16.29	16.89	17.32	17.93	19.30
	12H	17.88	18.46	18.92	19.49	20.88	16.36	16.94	17.40	17.97	19.36
4H	2H	15.40	16.10	16.43	17.11	18.47	14.55	15.24	15.57	16.25	17.61
	3H	17.29	17.87	18.32	18.91	20.28	16.16	16.74	17.19	17.78	19.15
	4H	18.04	18.57	19.08	19.60	20.99	16.77	17.29	17.80	18.33	19.72
	6H	18.54	18.99	19.59	20.05	21.44	17.18	17.63	18.22	18.69	20.08
	8H	18.73	19.15	19.78	20.20	21.61	17.35	17.77	18.39	18.82	20.22
	12H	18.82	19.21	19.89	20.27	21.68	17.45	17.83	18.52	18.90	20.31
8H	4H	18.16	18.59	19.21	19.64	21.04	17.02	17.45	18.07	18.50	19.90
	6H	18.78	19.13	19.85	20.22	21.63	17.55	17.90	18.62	18.99	20.40
	8H	19.06	19.36	20.14	20.44	21.86	17.80	18.11	18.88	19.19	20.61
	12H	19.22	19.49	20.30	20.56	22.02	17.98	18.25	19.06	19.32	20.78
12H	4H	18.13	18.52	19.20	19.58	20.99	17.02	17.41	18.09	18.47	19.88
	6H	18.80	19.10	19.88	20.18	21.60	17.61	17.92	18.69	18.99	20.41
	8H	19.09	19.37	20.18	20.44	21.90	17.89	18.16	18.97	19.23	20.69