

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: CORELITE

Report Number: P1191292

Luminaire Tested: SQ2-FA-075U-100D-L940-UNV-STD-W-4

Issue Date: 9/23/2025

Test Information

Test Method: LM-79-2019
Report Number: P1191292
REPORT IS SCALED FROM IESNA LM-79-08 TEST DATA (G3-2104-222-9, G2-2502-345-2)
Test Lab: INNOVATION CENTER
Issue Date: 9/23/2025
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: CORELITE
Catalog Number: SQ2-FA-075U-100D-L940-UNV-STD-W-4
Description: CORELITE SQ2 LED LUMINAIRE
FROSTED CONTINUOUS ASYMMETRIC ROLL LENS
DOWNLIGHT 1000 LUMENS PER FOOT
UPLIGHT 750 LUMENS PER FOOT
Light Source: 4000K CCT, 90 CRI LEDS
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 7129.5 lumens
Efficiency: N/A
Efficacy: 117.1 lumens/watt
Spacing Criteria (0/90/45): 1.08 / 1.23 / 1.34
Luminous Opening: Rectangular (W 0.17' x L: 4' x H: 0')
CIE Type: General Diffuse

Input Watts (W): 60.9
Input Voltage (V): 120
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

Luminous Intensity Polar Plot



TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	108	108	108	108	101	101	101	101	86	86	86	73	73	73	61	61	61
1	99	95	91	88	92	88	85	82	76	74	71	65	63	61	54	53	52
2	90	83	77	72	84	77	72	67	67	63	59	57	54	51	48	46	44
3	82	73	66	60	76	68	62	56	59	54	50	50	47	44	43	40	37
4	75	65	57	51	70	60	53	48	52	47	42	45	41	37	38	35	32
5	69	58	49	43	64	54	47	41	47	41	37	40	36	32	34	31	28
6	64	52	43	38	59	48	41	36	42	36	32	36	32	28	31	27	25
7	59	47	39	33	55	44	36	31	38	32	28	33	28	25	28	25	22
8	55	42	35	29	51	40	33	28	35	29	25	30	26	22	26	22	20
9	51	39	31	26	47	36	29	25	32	26	22	28	23	20	24	20	18
10	48	35	28	23	44	33	27	22	29	24	20	26	21	18	22	19	16

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	25785	25785	25785	25785
5°	25481	26686	25481	21269
10°	25371	26994	25371	19282
15°	24936	27211	24936	21314
20°	24249	27014	24249	22228
25°	23047	26795	23047	22495
30°	21233	26196	21233	22734
35°	18788	25622	18788	22328
40°	16177	24919	16177	22571
45°	15972	24028	15972	22614
50°	15237	22855	15237	22700
55°	15158	21084	15158	22477
60°	13592	18791	13592	22388
65°	11587	16554	11587	21757
70°	9352	14025	9352	20162
75°	8110	11584	8110	18534
80°	6908	8629	6908	14961
85°	4594	4594	4594	9170

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 45°

Vertical Angle: 45°

Luminance: 24875 cd/sqm

TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	143.7	2.0
10°-20°	401.5	5.6
20°-30°	609.8	8.6
30°-40°	715.8	10.0
40°-50°	726.4	10.2
50°-60°	636.3	8.9
60°-70°	451.4	6.3
70°-80°	232.5	3.3
80°-90°	49.3	0.7
90°-100°	193.2	2.7
100°-110°	640.4	9.0
110°-120°	635.6	8.9
120°-130°	517.7	7.3
130°-140°	420.8	5.9
140°-150°	326.8	4.6
150°-160°	235.4	3.3
160°-170°	144.2	2.0
170°-180°	48.7	0.7
0°-30°	1155.0	16.2
0°-40°	1870.8	26.2
0°-60°	3233.5	45.4
0°-90°	3966.7	55.6
90°-120°	1469.2	20.6
90°-150°	2734.5	38.4
90°-180°	3163.0	44.4
0°-180°	7129.5	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	1597	1597	1597	1597	1597	
5°	1572	1646	1572	1312	1572	149
15°	1492	1628	1492	1275	1492	419
25°	1294	1504	1294	1263	1294	591
35°	953	1300	953	1133	953	594
45°	700	1052	700	990	700	535
55°	538	749	538	798	538	466
65°	303	433	303	570	303	303
75°	130	186	130	297	130	141
85°	25	25	25	50	25	31
90°	0	4	0	4	0	2
95°	28	84	28	84	28	31
105°	112	1131	112	1131	112	118
115°	200	1256	200	1256	200	198
125°	279	995	279	995	279	248
135°	334	818	334	818	334	259
145°	388	682	388	682	388	243
155°	443	578	443	578	443	204
165°	486	532	486	532	486	137
175°	509	512	509	512	509	48
180°	511	511	511	511	511	

TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
0°	1597.0	1597.0	1597.0	1597.0	1597.0	1597.0	1597.0	1597.0	1597.0	1597.0	1597.0
2.5°	1587.1	1611.3	1611.9	1611.9	1611.9	1611.9	1611.9	1611.3	1587.1	1587.1	1562.3
5°	1572.2	1614.6	1627.9	1634.4	1646.5	1634.4	1627.9	1614.6	1572.2	1554.1	1454.6
7.5°	1557.4	1614.3	1634.1	1645.4	1651.5	1645.4	1634.1	1614.3	1557.4	1476.3	1267.7
10°	1547.5	1614.1	1634.1	1640.5	1646.5	1640.5	1634.1	1614.1	1547.5	1384.1	1213.2
12.5°	1532.6	1604.0	1629.2	1635.5	1641.6	1635.5	1629.2	1604.0	1532.6	1301.4	1173.6
15°	1491.8	1588.6	1609.4	1621.9	1627.9	1621.9	1609.4	1588.6	1491.8	1231.5	1145.1
17.5°	1441.0	1558.4	1585.9	1597.1	1601.9	1597.1	1585.9	1558.4	1441.0	1168.7	1146.4
20°	1411.3	1538.4	1566.0	1572.2	1572.2	1572.2	1566.0	1538.4	1411.3	1138.9	1176.1
22.5°	1371.7	1513.3	1541.3	1542.6	1547.5	1542.6	1541.3	1513.3	1371.7	1104.2	1190.9
25°	1293.7	1457.1	1498.0	1492.0	1504.1	1492.0	1498.0	1457.1	1293.7	1057.6	1188.5
27.5°	1198.4	1404.1	1433.6	1439.8	1439.8	1439.8	1433.6	1404.1	1198.4	1012.0	1163.7
30°	1138.9	1368.9	1398.9	1405.1	1405.1	1405.1	1398.9	1368.9	1138.9	981.6	1138.9
32.5°	1064.7	1338.2	1364.3	1365.5	1365.5	1365.5	1364.3	1338.2	1064.7	950.9	1099.3
35°	953.2	1286.1	1306.1	1305.9	1299.9	1305.9	1306.1	1286.1	953.2	904.8	1052.3
37.5°	841.8	1219.5	1246.6	1237.8	1231.8	1237.8	1246.6	1219.5	841.8	857.6	1012.7
40°	767.5	1179.1	1207.0	1188.3	1182.3	1188.3	1207.0	1179.1	767.5	822.0	978.0
42.5°	727.9	1134.6	1162.5	1138.8	1132.8	1138.8	1162.5	1134.6	727.9	787.2	948.3
45°	699.5	1062.6	1089.4	1064.4	1052.3	1064.4	1089.4	1062.6	699.5	735.8	897.5
47.5°	656.1	975.7	1013.9	976.5	964.4	976.5	1013.9	975.7	656.1	682.8	851.7
50°	606.6	921.3	959.4	922.0	909.9	922.0	959.4	921.3	606.6	642.9	817.1
52.5°	571.9	867.3	900.0	857.6	845.5	857.6	900.0	867.3	571.9	593.7	787.4
55°	538.5	786.7	810.9	767.1	749.0	767.1	810.9	786.7	538.5	520.4	730.4
57.5°	460.5	696.6	721.7	671.8	651.2	671.8	721.7	696.6	460.5	444.8	671.0
60°	420.9	632.7	662.3	612.1	581.9	612.1	662.3	632.7	420.9	390.7	631.4
62.5°	376.3	564.0	602.9	552.7	522.4	552.7	602.9	564.0	376.3	355.8	586.8
65°	303.3	466.7	513.8	463.6	433.3	463.6	513.8	466.7	303.3	315.4	513.8
67.5°	237.7	378.1	430.8	375.8	351.6	375.8	430.8	378.1	237.7	277.6	446.9
70°	198.1	319.1	371.4	321.3	297.1	321.3	371.4	319.1	198.1	252.5	402.3
72.5°	173.3	265.3	321.9	267.0	247.6	267.0	321.9	265.3	173.3	227.8	347.9
75°	130.0	184.5	247.6	197.8	185.7	197.8	247.6	184.5	130.0	184.5	272.4
77.5°	94.1	119.5	174.6	132.4	127.5	132.4	174.6	119.5	94.1	138.9	198.1
80°	74.3	80.3	130.0	92.8	92.8	92.8	130.0	80.3	74.3	104.5	148.6
82.5°	49.5	55.6	90.4	63.0	58.2	63.0	90.4	55.6	49.5	74.9	104.0
85°	24.8	24.8	37.1	24.8	24.8	24.8	37.1	24.8	24.8	36.9	49.5
87.5°	5.0	5.2	10.5	5.8	5.8	5.8	10.5	5.2	5.0	10.0	10.5
90°	0.0	1.0	3.2	4.2	4.2	4.2	3.2	1.0	0.0	1.0	3.2
92.5°	8.5	32.7	96.2	31.2	26.2	31.2	96.2	32.7	8.5	32.7	96.2
95°	27.5	81.3	350.1	124.9	83.6	124.9	350.1	81.3	27.5	81.3	350.1
97.5°	50.6	106.8	611.1	356.4	225.3	356.4	611.1	106.8	50.6	106.8	611.1
100°	66.6	120.4	707.6	607.7	403.0	607.7	707.6	120.4	66.6	120.4	707.6
102.5°	84.4	136.5	701.6	928.7	701.6	928.7	701.6	136.5	84.4	136.5	701.6
105°	112.1	159.7	640.9	1209.2	1130.6	1209.2	640.9	159.7	112.1	159.7	640.9
107.5°	140.5	182.9	582.8	1237.7	1297.5	1237.7	582.8	182.9	140.5	182.9	582.8
110°	156.5	198.9	553.1	1209.5	1330.5	1209.5	553.1	198.9	156.5	198.9	553.1

TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
112.5°	173.5	215.0	535.4	1159.5	1313.6	1159.5	535.4	215.0	173.5	215.0	535.4
115°	199.9	239.2	516.1	1074.5	1256.5	1074.5	516.1	239.2	199.9	239.2	516.1
117.5°	226.1	261.1	509.1	993.2	1184.1	993.2	509.1	261.1	226.1	261.1	509.1
120°	242.2	276.3	506.6	942.3	1127.4	942.3	506.6	276.3	242.2	276.3	506.6
122.5°	256.6	289.9	506.6	900.6	1071.6	900.6	506.6	289.9	256.6	289.9	506.6
125°	279.2	310.2	506.6	844.3	995.2	844.3	506.6	310.2	279.2	310.2	506.6
127.5°	297.8	328.2	505.3	801.7	930.7	801.7	505.3	328.2	297.8	328.2	505.3
130°	308.8	340.9	504.5	776.8	892.6	776.8	504.5	340.9	308.8	340.9	504.5
132.5°	319.0	351.9	503.6	756.3	860.5	756.3	503.6	351.9	319.0	351.9	503.6
135°	334.2	368.3	502.4	724.5	817.6	724.5	502.4	368.3	334.2	368.3	502.4
137.5°	350.7	383.6	501.1	693.8	775.9	693.8	501.1	383.6	350.7	383.6	501.1
140°	361.7	393.8	500.3	673.3	748.8	673.3	500.3	393.8	361.7	393.8	500.3
142.5°	371.9	403.1	501.1	652.8	720.0	652.8	501.1	403.1	371.9	403.1	501.1
145°	388.2	417.1	501.3	623.2	682.2	623.2	501.3	417.1	388.2	417.1	501.3
147.5°	405.7	429.9	501.5	598.1	642.0	598.1	501.5	429.9	405.7	429.9	501.5
150°	416.7	438.4	502.4	583.6	620.8	583.6	502.4	438.4	416.7	438.4	502.4
152.5°	426.9	447.8	503.2	571.6	601.4	571.6	503.2	447.8	426.9	447.8	503.2
155°	443.1	458.7	504.5	556.8	577.5	556.8	504.5	458.7	443.1	458.7	504.5
157.5°	459.0	471.0	505.8	546.3	561.0	546.3	505.8	471.0	459.0	471.0	505.8
160°	467.5	477.8	506.6	538.6	550.0	538.6	506.6	477.8	467.5	477.8	506.6
162.5°	475.9	483.8	506.6	533.5	542.4	533.5	506.6	483.8	475.9	483.8	506.6
165°	486.5	491.7	506.6	526.8	532.0	526.8	506.6	491.7	486.5	491.7	506.6
167.5°	496.2	498.9	507.7	520.8	523.5	520.8	507.7	498.9	496.2	498.9	507.7
170°	501.3	502.4	507.7	518.3	519.3	518.3	507.7	502.4	501.3	502.4	507.7
172.5°	504.7	505.7	508.5	515.7	515.9	515.7	508.5	505.7	504.7	505.7	508.5
175°	508.7	508.7	509.8	512.9	511.9	512.9	509.8	508.7	508.7	508.7	509.8
177.5°	510.8	510.8	510.0	511.6	510.0	511.6	510.0	510.8	510.8	510.8	510.0
180°	510.8	510.8	510.8	510.8	510.8	510.8	510.8	510.8	510.8	510.8	510.8

TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
0°	1597.0	1597.0	1597.0	1597.0	1597.0	1597.0
2.5°	1547.4	1542.5	1547.4	1562.3	1587.1	1587.1
5°	1342.5	1312.3	1342.5	1454.6	1554.1	1572.2
7.5°	1220.4	1210.7	1220.4	1267.7	1476.3	1557.4
10°	1176.1	1176.1	1176.1	1213.2	1384.1	1547.5
12.5°	1171.7	1195.9	1171.7	1173.6	1301.4	1532.6
15°	1244.9	1275.1	1244.9	1145.1	1231.5	1491.8
17.5°	1269.5	1293.7	1269.5	1146.4	1168.7	1441.0
20°	1269.5	1293.7	1269.5	1176.1	1138.9	1411.3
22.5°	1264.5	1288.7	1264.5	1190.9	1104.2	1371.7
25°	1250.6	1262.7	1250.6	1188.5	1057.6	1293.7
27.5°	1225.8	1234.3	1225.8	1163.7	1012.0	1198.4
30°	1201.3	1219.4	1201.3	1138.9	981.6	1138.9
32.5°	1176.2	1179.8	1176.2	1099.3	950.9	1064.7
35°	1138.8	1132.8	1138.8	1052.3	904.8	953.2
37.5°	1088.3	1095.6	1088.3	1012.7	857.6	841.8
40°	1058.7	1070.9	1058.7	978.0	822.0	767.5
42.5°	1029.0	1041.1	1029.0	948.3	787.2	727.9
45°	984.3	990.4	984.3	897.5	735.8	699.5
47.5°	932.3	938.4	932.3	851.7	682.8	656.1
50°	897.7	903.7	897.7	817.1	642.9	606.6
52.5°	858.1	864.1	858.1	787.4	593.7	571.9
55°	798.5	798.5	798.5	730.4	520.4	538.5
57.5°	730.6	737.8	730.6	671.0	444.8	460.5
60°	681.2	693.3	681.2	631.4	390.7	420.9
62.5°	636.5	643.7	636.5	586.8	355.8	376.3
65°	563.4	569.5	563.4	513.8	315.4	303.3
67.5°	481.7	486.5	481.7	446.9	277.6	237.7
70°	427.1	427.1	427.1	402.3	252.5	198.1
72.5°	372.7	377.6	372.7	347.9	227.8	173.3
75°	291.1	297.1	291.1	272.4	184.5	130.0
77.5°	209.4	215.4	209.4	198.1	138.9	94.1
80°	154.9	160.9	154.9	148.6	104.5	74.3
82.5°	110.2	111.4	110.2	104.0	74.9	49.5
85°	49.5	49.5	49.5	49.5	36.9	24.8
87.5°	10.7	10.7	10.7	10.5	10.0	5.0
90°	4.2	4.2	4.2	3.2	1.0	0.0
92.5°	31.2	26.2	31.2	96.2	32.7	8.5
95°	124.9	83.6	124.9	350.1	81.3	27.5
97.5°	356.4	225.3	356.4	611.1	106.8	50.6
100°	607.7	403.0	607.7	707.6	120.4	66.6
102.5°	928.7	701.6	928.7	701.6	136.5	84.4
105°	1209.2	1130.6	1209.2	640.9	159.7	112.1
107.5°	1237.7	1297.5	1237.7	582.8	182.9	140.5
110°	1209.5	1330.5	1209.5	553.1	198.9	156.5

TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
112.5°	1159.5	1313.6	1159.5	535.4	215.0	173.5
115°	1074.5	1256.5	1074.5	516.1	239.2	199.9
117.5°	993.2	1184.1	993.2	509.1	261.1	226.1
120°	942.3	1127.4	942.3	506.6	276.3	242.2
122.5°	900.6	1071.6	900.6	506.6	289.9	256.6
125°	844.3	995.2	844.3	506.6	310.2	279.2
127.5°	801.7	930.7	801.7	505.3	328.2	297.8
130°	776.8	892.6	776.8	504.5	340.9	308.8
132.5°	756.3	860.5	756.3	503.6	351.9	319.0
135°	724.5	817.6	724.5	502.4	368.3	334.2
137.5°	693.8	775.9	693.8	501.1	383.6	350.7
140°	673.3	748.8	673.3	500.3	393.8	361.7
142.5°	652.8	720.0	652.8	501.1	403.1	371.9
145°	623.2	682.2	623.2	501.3	417.1	388.2
147.5°	598.1	642.0	598.1	501.5	429.9	405.7
150°	583.6	620.8	583.6	502.4	438.4	416.7
152.5°	571.6	601.4	571.6	503.2	447.8	426.9
155°	556.8	577.5	556.8	504.5	458.7	443.1
157.5°	546.3	561.0	546.3	505.8	471.0	459.0
160°	538.6	550.0	538.6	506.6	477.8	467.5
162.5°	533.5	542.4	533.5	506.6	483.8	475.9
165°	526.8	532.0	526.8	506.6	491.7	486.5
167.5°	520.8	523.5	520.8	507.7	498.9	496.2
170°	518.3	519.3	518.3	507.7	502.4	501.3
172.5°	515.7	515.9	515.7	508.5	505.7	504.7
175°	512.9	511.9	512.9	509.8	508.7	508.7
177.5°	511.6	510.0	511.6	510.0	510.8	510.8
180°	510.8	510.8	510.8	510.8	510.8	510.8

TEST NUMBER: P1191292

CATALOG NUMBER: SQ2-FA-075U-100D-L940-UNV-STD-W-4

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	18.15	19.06	19.05	19.99	21.18	19.37	20.29	20.28	21.21	22.40
	3H	19.24	20.06	20.16	20.99	22.21	20.62	21.44	21.54	22.37	23.59
	4H	19.60	20.37	20.53	21.31	22.53	21.01	21.79	21.95	22.73	23.95
	6H	19.76	20.47	20.71	21.42	22.66	21.18	21.89	22.12	22.83	24.07
	8H	19.80	20.48	20.75	21.44	22.67	21.20	21.88	22.16	22.84	24.08
	12H	19.80	20.44	20.76	21.40	22.66	21.19	21.83	22.15	22.79	24.05
4H	2H	19.08	19.86	20.02	20.80	22.02	19.99	20.77	20.93	21.71	22.93
	3H	20.46	21.10	21.41	22.07	23.31	21.45	22.09	22.40	23.07	24.30
	4H	20.90	21.49	21.86	22.46	23.72	21.92	22.51	22.88	23.47	24.73
	6H	21.13	21.64	22.11	22.63	23.89	22.14	22.65	23.12	23.64	24.90
	8H	21.19	21.66	22.17	22.65	23.92	22.19	22.66	23.17	23.65	24.92
	12H	21.20	21.62	22.19	22.62	23.90	22.18	22.61	23.18	23.61	24.89
8H	4H	21.31	21.78	22.28	22.76	24.04	22.13	22.61	23.11	23.59	24.86
	6H	21.65	22.04	22.65	23.07	24.34	22.45	22.84	23.45	23.86	25.13
	8H	21.77	22.11	22.78	23.13	24.42	22.54	22.88	23.55	23.90	25.19
	12H	21.81	22.11	22.82	23.12	24.45	22.56	22.86	23.57	23.86	25.20
12H	4H	21.31	21.74	22.31	22.74	24.02	22.10	22.53	23.10	23.53	24.81
	6H	21.73	22.07	22.74	23.08	24.38	22.47	22.81	23.48	23.82	25.12
	8H	21.87	22.18	22.89	23.18	24.52	22.58	22.88	23.59	23.89	25.23