

Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P1357507

Luminaire Tested: 8ASL4-25VHE-3-27-UNV

Issue Date: 2/17/2026

Test Information

Test Method: LM-79-2019
Report Number: P1357507
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2511-597-12)
Test Lab: INNOVATION CENTER
Issue Date: 2/17/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: 8ASL4-25VHE-3-27-UNV
Description: 8FT 2500 LUMEN PER FOOT 4ASL LED LUMINAIRE WITH OPL LENS AND 2700K LEDS 3 ROW
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 18464.0 lumens
Efficiency: N/A
Efficacy: 107.9 lumens/watt
Spacing Criteria (0/90/45): 1.21 / 1.3 / 1.39
Luminous Opening: Rectangular w/ Sides (W: 0.33' x L: 7.98' x H: 0.1')
CIE Type: Direct

Input Watts (W): 171.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1357507

CATALOG NUMBER: 8ASL4-25VHE-3-27-UNV

Luminous Intensity Polar Plot



TEST NUMBER: P1357507

CATALOG NUMBER: 8ASL4-25VHE-3-27-UNV

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	117	117	117	117	114	114	114	114	107	107	107		101	101	101		96
1	105	100	95	91	102	97	92	88	91	88	84		86	83	80		81
2	95	86	79	72	92	84	77	71	79	73	68		75	70	66		71
3	86	75	67	60	83	73	65	59	69	62	57		65	60	55		62
4	79	66	57	50	76	65	56	49	61	54	48		58	52	47		55
5	73	59	50	43	70	58	49	42	55	47	41		52	45	40		49
6	67	53	44	37	64	52	43	37	49	42	36		47	40	35		45
7	62	48	39	33	60	47	38	32	45	37	32		43	36	31		41
8	58	44	35	29	56	43	35	29	41	34	28		39	32	28		37
9	54	40	32	26	52	39	31	26	38	30	25		36	30	25		35
10	50	37	29	24	49	36	29	23	35	28	23		33	27	23		32

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	21977	21977	21977
5°	21807	21581	21474
10°	21710	21179	20931
15°	21495	20674	20471
20°	21196	20189	19951
25°	20846	19577	19361
30°	20475	19047	18862
35°	20009	18446	18306
40°	19588	17896	17721
45°	19135	17228	17133
50°	18619	16511	16522
55°	18065	15827	15973
60°	17336	15026	15415
65°	16406	14259	14953
70°	15218	13503	14591
75°	13467	12820	14343
80°	10780	12325	14237
85°	6845	12272	14448

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 19135 cd/sqm

TEST NUMBER: P1357507

CATALOG NUMBER: 8ASL4-25VHE-3-27-UNV

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	515.0	2.8
10°-20°	1478.5	8.0
20°-30°	2235.4	12.1
30°-40°	2706.8	14.7
40°-50°	2842.9	15.4
50°-60°	2652.3	14.4
60°-70°	2192.0	11.9
70°-80°	1578.3	8.5
80°-90°	980.8	5.3
90°-100°	574.7	3.1
100°-110°	328.7	1.8
110°-120°	185.6	1.0
120°-130°	106.8	0.6
130°-140°	57.6	0.3
140°-150°	24.2	0.1
150°-160°	4.5	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4228.9	22.9
0°-40°	6935.7	37.6
0°-60°	12430.9	67.3
0°-90°	17181.9	93.1
90°-120°	1089.1	5.9
90°-150°	1277.6	6.9
90°-180°	1282.0	6.9
0°-180°	18464.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	5430	5430	5430	5430	5430	
5°	5374	5419	5419	5419	5430	511
15°	5148	5216	5239	5272	5295	1452
25°	4697	4776	4855	4922	4968	2163
35°	4087	4200	4335	4460	4516	2558
45°	3387	3511	3703	3861	3929	2613
55°	2608	2755	2981	3195	3274	2330
65°	1761	1931	2224	2506	2608	1743
75°	903	1129	1524	1852	1987	955
85°	169	508	960	1298	1422	207
90°	0	305	734	1050	1186	8
95°	0	192	553	847	971	0
105°	0	68	305	531	621	0
115°	0	34	181	327	384	0
125°	0	23	113	214	248	0
135°	0	0	68	136	169	0
145°	0	0	34	79	90	0
155°	0	0	0	23	34	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0



TEST NUMBER: P1357507

CATALOG NUMBER: 8ASL4-25VHE-3-27-UNV

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	5430.5	5430.5	5430.5	5430.5	5430.5
2.5°	5407.9	5441.8	5441.8	5407.9	5407.9
5°	5374.1	5419.2	5419.2	5419.2	5430.5
7.5°	5340.2	5396.6	5396.6	5396.6	5419.2
10°	5295.0	5351.5	5362.8	5362.8	5374.1
12.5°	5227.3	5295.0	5306.3	5317.6	5328.9
15°	5148.3	5216.0	5238.6	5272.4	5295.0
17.5°	5057.9	5137.0	5182.1	5216.0	5238.6
20°	4945.0	5024.1	5080.5	5125.7	5159.5
22.5°	4832.1	4899.9	4967.6	5024.1	5057.9
25°	4696.7	4775.7	4854.7	4922.5	4967.6
27.5°	4549.9	4640.2	4741.8	4820.8	4866.0
30°	4414.4	4504.7	4617.6	4719.2	4764.4
32.5°	4256.3	4358.0	4482.1	4583.8	4640.2
35°	4087.0	4199.9	4335.4	4459.6	4516.0
37.5°	3917.6	4030.5	4199.9	4324.1	4380.5
40°	3748.3	3861.2	4041.8	4177.3	4233.8
42.5°	3567.7	3680.6	3872.5	4019.3	4087.0
45°	3387.0	3511.2	3703.1	3861.2	3928.9
47.5°	3206.4	3330.6	3533.8	3703.1	3770.9
50°	3003.2	3138.6	3341.9	3533.8	3601.5
52.5°	2811.2	2946.7	3172.5	3364.4	3432.2
55°	2608.0	2754.8	2980.6	3195.1	3274.1
57.5°	2404.8	2551.5	2788.6	3014.4	3104.8
60°	2190.3	2348.3	2596.7	2833.8	2935.4
62.5°	1975.8	2145.1	2416.1	2664.4	2766.1
65°	1761.2	1930.6	2224.1	2506.4	2608.0
67.5°	1546.7	1727.4	2043.5	2337.0	2461.2
70°	1332.2	1524.2	1862.9	2167.7	2291.9
72.5°	1117.7	1320.9	1693.5	2009.6	2133.8
75°	903.2	1129.0	1524.2	1851.6	1987.0
77.5°	688.7	948.4	1377.4	1704.8	1840.3
80°	496.8	790.3	1219.3	1558.0	1693.5
82.5°	316.1	632.2	1083.8	1422.5	1558.0
85°	169.4	508.1	959.7	1298.4	1422.5
87.5°	56.5	395.2	835.5	1174.2	1298.4
90°	0.0	304.8	733.9	1050.0	1185.5
92.5°	0.0	237.1	643.5	948.4	1072.6
95°	0.0	191.9	553.2	846.8	970.9
97.5°	0.0	158.1	485.5	756.4	869.3
100°	0.0	124.2	417.7	677.4	779.0
102.5°	0.0	101.6	361.3	598.4	700.0
105°	0.0	67.7	304.8	530.6	621.0
107.5°	0.0	56.5	259.7	474.2	553.2
110°	0.0	45.2	237.1	406.4	485.5

TEST NUMBER: P1357507

CATALOG NUMBER: 8ASL4-25VHE-3-27-UNV

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.0	33.9	214.5	361.3	440.3
115°	0.0	33.9	180.6	327.4	383.9
117.5°	0.0	33.9	158.1	293.5	350.0
120°	0.0	22.6	146.8	259.7	316.1
122.5°	0.0	22.6	124.2	237.1	282.3
125°	0.0	22.6	112.9	214.5	248.4
127.5°	0.0	11.3	101.6	191.9	225.8
130°	0.0	11.3	90.3	169.4	203.2
132.5°	0.0	11.3	79.0	158.1	191.9
135°	0.0	0.0	67.7	135.5	169.4
137.5°	0.0	0.0	56.5	124.2	146.8
140°	0.0	0.0	45.2	101.6	135.5
142.5°	0.0	0.0	33.9	90.3	112.9
145°	0.0	0.0	33.9	79.0	90.3
147.5°	0.0	0.0	22.6	56.5	79.0
150°	0.0	0.0	11.3	45.2	56.5
152.5°	0.0	0.0	0.0	33.9	45.2
155°	0.0	0.0	0.0	22.6	33.9
157.5°	0.0	0.0	0.0	0.0	11.3
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

TEST NUMBER: P1357507

CATALOG NUMBER: 8ASL4-25VHE-3-27-UNV

CIE UGR TABLE:

Reflectances:											
Ceiling		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
X=2H	Y=2H	20.08	21.62	20.55	22.08	22.56	22.15	23.69	22.62	24.15	24.63
	3H	21.58	22.98	22.06	23.45	23.97	24.64	26.04	25.12	26.50	27.03
	4H	22.06	23.39	22.56	23.87	24.41	25.85	27.18	26.35	27.66	28.20
	6H	22.34	23.58	22.85	24.07	24.62	27.13	28.37	27.64	28.86	29.42
	8H	22.39	23.58	22.91	24.09	24.65	27.80	28.99	28.33	29.51	30.07
	12H	22.40	23.54	22.93	24.05	24.64	28.55	29.68	29.08	30.20	30.79
4H	2H	20.97	22.30	21.47	22.78	23.32	22.59	23.92	23.09	24.40	24.94
	3H	22.70	23.84	23.22	24.36	24.92	25.29	26.43	25.81	26.95	27.51
	4H	23.31	24.35	23.84	24.88	25.47	26.68	27.72	27.21	28.25	28.84
	6H	23.70	24.62	24.26	25.18	25.79	28.15	29.07	28.70	29.63	30.23
	8H	23.80	24.66	24.36	25.22	25.84	28.92	29.79	29.48	30.35	30.97
	12H	23.84	24.63	24.43	25.22	25.84	29.80	30.58	30.38	31.17	31.79
8H	4H	24.00	24.86	24.56	25.42	26.04	26.89	27.75	27.45	28.32	28.94
	6H	24.58	25.31	25.17	25.91	26.54	28.53	29.26	29.12	29.87	30.49
	8H	24.76	25.42	25.36	26.03	26.67	29.45	30.11	30.05	30.72	31.36
	12H	24.87	25.46	25.48	26.07	26.77	30.51	31.09	31.11	31.70	32.40
12H	4H	24.20	24.98	24.78	25.57	26.20	26.90	27.68	27.48	28.27	28.90
	6H	24.88	25.54	25.48	26.15	26.79	28.57	29.23	29.17	29.84	30.48
	8H	25.16	25.75	25.76	26.35	27.05	29.55	30.14	30.16	30.75	31.45

LM-79-2019: Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Report Prepared for

Cooper Lighting Solutions

Fail-Safe

Report Number: SP1-2511-597-2

Test Date: 11/17/2025

Luminaire Tested: 4ASL-2-27-UNV-OPL-1_600mA

Data in this report applies to families of products including 4ASL


Test Information

Test Method: LM-79-2019
 Report Number: SP1-2511-597-2
 Test Lab: COOPER LIGHTING SOLUTIONS
 Photometer: SP1 - 76IN SPHERE
 Measurement Geometry: 4π
 Issue Date: 11/18/2025
 Manufacturer: COOPER LIGHTING SOLUTIONS
 Product Line: Fail-Safe
 Catalog Number: **4ASL-2-27-UNV-OPL-1_600mA**
 Description: 2foot 4ASL LED LUMINAIRE WITH OPL LENS AND 2700K LEDS with 1 rows at 600mA

Spectral Parameters

CCT (K): 2696
 CIE u' : 0.2632
 CIE v' : 0.5245
 Duv: -0.0020
 CIE x: 0.4568
 CIE y: 0.4045
 CIE z: 0.1387
 Peak Wavelength (nm): 630
 Dominant Wavelength (nm): 584
 Purity: 58.52757
 R_f: 90.1
 R_g: 103.5

CRI (Ra): 94.4
 R1: 97.5
 R2: 97.8
 R3: 96.9
 R4: 95.3
 R5: 97.2
 R6: 96.5
 R7: 91.2
 R8: 83.2
 R9: 61.8
 R10: 93.6
 R11: 93.7
 R12: 94.1
 R13: 97.6
 R14: 96.8
 R15: 91.9



Test Conditions


Stabilization Time: 32M
 Operation Time: 1H 32M
 Sphere Temperature (°C): 24.1

REPORT NUMBER: SP1-2511-597-2

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	76INCH SPHERE IN0058	6/16/2025	12/16/2025
Power Meter	XITRON INXT2011004	10/21/2025	10/21/2026
AC Power Source	CHROMA 61603 IN0063	10/21/2025	10/21/2026
DC Power Source	AGILENT E3634A IN0208	10/21/2025	10/21/2026
Sphere Thermometer	ONSET IN0085	10/21/2025	10/21/2026
Room Thermometer	ONSET IN0046	10/21/2025	10/21/2026

REPORT NUMBER: SP1-2511-597-2

Photopic Flux vs. Wavelength




Photopic Lumens: NR

λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	70	NR	620	281	NR	750	7	NR	880	0	NR
365	0	NR	495	88	NR	625	288	NR	755	6	NR	885	0	NR
370	0	NR	500	106	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	121	NR	635	581	NR	765	5	NR	895	0	NR
380	0	NR	510	133	NR	640	184	NR	770	4	NR	900	0	NR
385	0	NR	515	143	NR	645	191	NR	775	3	NR	905	0	NR
390	0	NR	520	149	NR	650	161	NR	780	3	NR	910	0	NR
395	1	NR	525	155	NR	655	136	NR	785	2	NR	915	0	NR
400	1	NR	530	158	NR	660	116	NR	790	2	NR	920	0	NR
405	2	NR	535	163	NR	665	99	NR	795	2	NR	925	0	NR
410	3	NR	540	168	NR	670	92	NR	800	2	NR	930	0	NR
415	6	NR	545	173	NR	675	75	NR	805	1	NR	935	0	NR
420	11	NR	550	179	NR	680	65	NR	810	1	NR	940	0	NR
425	19	NR	555	187	NR	685	56	NR	815	1	NR	945	0	NR
430	32	NR	560	195	NR	690	48	NR	820	1	NR	950	0	NR
435	54	NR	565	203	NR	695	41	NR	825	1	NR	955	0	NR
440	90	NR	570	211	NR	700	35	NR	830	1	NR	960	0	NR
445	134	NR	575	219	NR	705	30	NR	835	1	NR	965	0	NR
450	128	NR	580	228	NR	710	26	NR	840	1	NR	970	0	NR
455	83	NR	585	237	NR	715	22	NR	845	0	NR	975	0	NR
460	67	NR	590	246	NR	720	19	NR	850	0	NR	980	0	NR
465	55	NR	595	251	NR	725	16	NR	855	0	NR	985	0	NR
470	42	NR	600	259	NR	730	13	NR	860	0	NR	990	0	NR
475	41	NR	605	266	NR	735	11	NR	865	0	NR	995	0	NR
480	46	NR	610	299	NR	740	10	NR	870	0	NR	1000	0	NR
485	55	NR	615	317	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2511-597-2

Scotopic Flux vs. Wavelength




Scotopic Lumens: NR

S/P: 1.29

λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)	λ (nm)	Power W [^] /nm	Lumens (Φ/nm)
360	0	NR	490	70	NR	620	281	NR	750	7	NR	880	0	NR
365	0	NR	495	88	NR	625	288	NR	755	6	NR	885	0	NR
370	0	NR	500	106	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	121	NR	635	581	NR	765	5	NR	895	0	NR
380	0	NR	510	133	NR	640	184	NR	770	4	NR	900	0	NR
385	0	NR	515	143	NR	645	191	NR	775	3	NR	905	0	NR
390	0	NR	520	149	NR	650	161	NR	780	3	NR	910	0	NR
395	1	NR	525	155	NR	655	136	NR	785	2	NR	915	0	NR
400	1	NR	530	158	NR	660	116	NR	790	2	NR	920	0	NR
405	2	NR	535	163	NR	665	99	NR	795	2	NR	925	0	NR
410	3	NR	540	168	NR	670	92	NR	800	2	NR	930	0	NR
415	6	NR	545	173	NR	675	75	NR	805	1	NR	935	0	NR
420	11	NR	550	179	NR	680	65	NR	810	1	NR	940	0	NR
425	19	NR	555	187	NR	685	56	NR	815	1	NR	945	0	NR
430	32	NR	560	195	NR	690	48	NR	820	1	NR	950	0	NR
435	54	NR	565	203	NR	695	41	NR	825	1	NR	955	0	NR
440	90	NR	570	211	NR	700	35	NR	830	1	NR	960	0	NR
445	134	NR	575	219	NR	705	30	NR	835	1	NR	965	0	NR
450	128	NR	580	228	NR	710	26	NR	840	1	NR	970	0	NR
455	83	NR	585	237	NR	715	22	NR	845	0	NR	975	0	NR
460	67	NR	590	246	NR	720	19	NR	850	0	NR	980	0	NR
465	55	NR	595	251	NR	725	16	NR	855	0	NR	985	0	NR
470	42	NR	600	259	NR	730	13	NR	860	0	NR	990	0	NR
475	41	NR	605	266	NR	735	11	NR	865	0	NR	995	0	NR
480	46	NR	610	299	NR	740	10	NR	870	0	NR	1000	0	NR
485	55	NR	615	317	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2511-597-2

Melanopic Flux vs. Wavelength



Melanopic Lumens: NR

M/P: 2.45


λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)	λ (nm)	Power W [^] /nm	Lumens (φ/nm)
360	0	NR	490	70	NR	620	281	NR	750	7	NR	880	0	NR
365	0	NR	495	88	NR	625	288	NR	755	6	NR	885	0	NR
370	0	NR	500	106	NR	630	1000	NR	760	5	NR	890	0	NR
375	0	NR	505	121	NR	635	581	NR	765	5	NR	895	0	NR
380	0	NR	510	133	NR	640	184	NR	770	4	NR	900	0	NR
385	0	NR	515	143	NR	645	191	NR	775	3	NR	905	0	NR
390	0	NR	520	149	NR	650	161	NR	780	3	NR	910	0	NR
395	1	NR	525	155	NR	655	136	NR	785	2	NR	915	0	NR
400	1	NR	530	158	NR	660	116	NR	790	2	NR	920	0	NR
405	2	NR	535	163	NR	665	99	NR	795	2	NR	925	0	NR
410	3	NR	540	168	NR	670	92	NR	800	2	NR	930	0	NR
415	6	NR	545	173	NR	675	75	NR	805	1	NR	935	0	NR
420	11	NR	550	179	NR	680	65	NR	810	1	NR	940	0	NR
425	19	NR	555	187	NR	685	56	NR	815	1	NR	945	0	NR
430	32	NR	560	195	NR	690	48	NR	820	1	NR	950	0	NR
435	54	NR	565	203	NR	695	41	NR	825	1	NR	955	0	NR
440	90	NR	570	211	NR	700	35	NR	830	1	NR	960	0	NR
445	134	NR	575	219	NR	705	30	NR	835	1	NR	965	0	NR
450	128	NR	580	228	NR	710	26	NR	840	1	NR	970	0	NR
455	83	NR	585	237	NR	715	22	NR	845	0	NR	975	0	NR
460	67	NR	590	246	NR	720	19	NR	850	0	NR	980	0	NR
465	55	NR	595	251	NR	725	16	NR	855	0	NR	985	0	NR
470	42	NR	600	259	NR	730	13	NR	860	0	NR	990	0	NR
475	41	NR	605	266	NR	735	11	NR	865	0	NR	995	0	NR
480	46	NR	610	299	NR	740	10	NR	870	0	NR	1000	0	NR
485	55	NR	615	317	NR	745	8	NR	875	0	NR			

REPORT NUMBER: SP1-2511-597-2





TM-30-18

Summary

$R_f = 90.1$
 $R_g = 103.5$
 $CIE R_a = 94.4$
 $R_9 = 61.8$




Color Vector Graphics






Individual Sample Fidelity Index ($R_{f,i}$)



CES01 = 86	CES26 = 89	CES51 = 92	CES76 = 90
CES02 = 64	CES27 = 97	CES52 = 92	CES77 = 84
CES03 = 32	CES28 = 96	CES53 = 88	CES78 = 87
CES04 = 71	CES29 = 83	CES54 = 97	CES79 = 88
CES05 = 51	CES30 = 85	CES55 = 95	CES80 = 91
CES06 = 51	CES31 = 85	CES56 = 89	CES81 = 69
CES07 = 44	CES32 = 80	CES57 = 87	CES82 = 95
CES08 = 43	CES33 = 84	CES58 = 88	CES83 = 91
CES09 = 29	CES34 = 91	CES59 = 98	CES84 = 97
CES10 = 77	CES35 = 96	CES60 = 99	CES85 = 81
CES11 = 59	CES36 = 98	CES61 = 99	CES86 = 75
CES12 = 66	CES37 = 93	CES62 = 91	CES87 = 91
CES13 = 45	CES38 = 89	CES63 = 90	CES88 = 94
CES14 = 74	CES39 = 95	CES64 = 93	CES89 = 80
CES15 = 72	CES40 = 91	CES65 = 92	CES90 = 93
CES16 = 48	CES41 = 89	CES66 = 92	CES91 = 91
CES17 = 50	CES42 = 89	CES67 = 93	CES92 = 80
CES18 = 57	CES43 = 85	CES68 = 97	CES93 = 88
CES19 = 72	CES44 = 98	CES69 = 98	CES94 = 72
CES20 = 68	CES45 = 90	CES70 = 93	CES95 = 88
CES21 = 87	CES46 = 89	CES71 = 95	CES96 = 92
CES22 = 79	CES47 = 79	CES72 = 98	CES97 = 90
CES23 = 92	CES48 = 87	CES73 = 89	CES98 = 91
CES24 = 91	CES49 = 87	CES74 = 88	CES99 = 92
CES25 = 72	CES50 = 92	CES75 = 94	



Color Rendition by Hue-Angle Bin



Measure Comparisons



(END OF REPORT)