

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517476

Luminaire Tested: HVL12-4-LD4-1STD-40-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517476
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-1STD-40-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3876.0 lumens
Efficiency: N/A
Efficacy: 115.7 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 33.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517476

CATALOG NUMBER: HVL12-4-LD4-1STD-40-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517476

CATALOG NUMBER: HVL12-4-LD4-1STD-40-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3462	3462	3462
5°	3454	3428	3470
10°	3409	3492	3516
15°	3347	3414	3287
20°	3272	3214	3165
25°	3192	3091	3208
30°	3070	2995	3268
35°	2984	2904	3236
40°	2891	2841	3284
45°	2791	2755	3256
50°	2670	2665	3265
55°	2492	2568	3303
60°	2355	2429	3208
65°	2082	2259	3161
70°	1699	2030	2898
75°	1212	1746	2725
80°	681	1461	2551
85°	253	1166	2401

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 3303 cd/sqm

TEST NUMBER: P517476

CATALOG NUMBER: HVL12-4-LD4-1STD-40-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	123.7	3.2
10°-20°	352.2	9.1
20°-30°	524.0	13.5
30°-40°	629.8	16.2
40°-50°	662.9	17.1
50°-60°	615.1	15.9
60°-70°	486.3	12.5
70°-80°	297.1	7.7
80°-90°	129.4	3.3
90°-100°	40.3	1.0
100°-110°	9.1	0.2
110°-120°	3.6	0.1
120°-130°	2.0	0.1
130°-140°	0.5	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	999.8	25.8
0°-40°	1629.6	42.0
0°-60°	2907.6	75.0
0°-90°	3820.4	98.6
90°-120°	53.0	1.4
90°-150°	55.6	1.4
90°-180°	56.0	1.4
0°-180°	3876.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1287	1287	1287	1287	1287	
5°	1284	1281	1285	1300	1303	122
15°	1215	1262	1274	1232	1232	342
25°	1096	1166	1113	1146	1164	503
35°	935	961	975	1064	1100	584
45°	764	767	831	962	998	589
55°	563	572	663	808	872	506
65°	356	368	467	618	674	353
75°	135	178	260	400	425	147
85°	12	42	101	197	226	19
90°	0	13	53	125	147	1
95°	0	3	23	68	84	0
105°	0	2	5	13	19	0
115°	0	1	4	6	6	0
125°	0	0	2	4	6	0
135°	0	0	0	1	2	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517476

CATALOG NUMBER: HVL12-4-LD4-1STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1286.6	1286.6	1286.6	1286.6	1286.6
2.5°	1288.2	1284.8	1277.7	1284.5	1286.4
5°	1283.5	1280.9	1285.3	1299.7	1303.4
7.5°	1272.7	1282.7	1294.5	1320.7	1329.1
10°	1256.7	1275.6	1311.0	1333.3	1324.6
12.5°	1237.3	1269.3	1316.8	1273.3	1253.1
15°	1214.8	1261.5	1273.8	1231.6	1232.4
17.5°	1188.3	1254.9	1216.9	1215.9	1208.3
20°	1159.8	1232.9	1182.6	1180.5	1172.3
22.5°	1129.1	1203.8	1152.2	1148.0	1170.0
25°	1095.8	1165.8	1112.6	1145.9	1164.5
27.5°	1054.1	1116.0	1079.6	1126.7	1150.1
30°	1011.9	1064.6	1045.8	1111.5	1153.0
32.5°	972.4	1010.9	1018.0	1105.8	1112.6
35°	934.9	960.8	975.3	1063.8	1100.0
37.5°	893.7	900.8	939.1	1046.3	1081.1
40°	851.8	847.4	908.7	1017.5	1065.7
42.5°	806.7	805.2	876.4	1003.0	1027.1
45°	764.0	767.4	830.6	962.1	998.1
47.5°	720.2	724.7	787.1	917.3	961.9
50°	669.4	675.2	748.3	877.5	934.9
52.5°	614.3	625.4	710.5	839.8	897.7
55°	562.7	571.9	662.6	807.5	871.7
57.5°	515.5	521.0	613.0	766.9	815.4
60°	469.1	470.5	566.4	721.8	768.2
62.5°	415.9	418.3	518.4	668.6	730.7
65°	356.2	367.5	466.8	617.8	673.8
67.5°	300.4	320.0	414.1	571.1	600.5
70°	240.6	273.9	362.5	516.3	537.0
72.5°	185.8	224.9	309.5	455.0	484.1
75°	134.7	178.5	260.3	400.0	425.1
77.5°	90.7	135.2	214.1	339.2	372.4
80°	54.3	98.8	173.0	282.8	320.3
82.5°	27.8	66.3	134.2	237.2	270.7
85°	12.1	41.9	101.4	196.8	225.9
87.5°	3.4	23.9	74.7	159.1	183.7
90°	0.3	12.6	53.2	124.8	147.0
92.5°	0.3	6.0	37.5	94.4	111.4
95°	0.3	3.1	23.3	68.4	83.6
97.5°	0.3	1.8	14.2	48.5	61.3
100°	0.3	1.6	8.4	32.2	43.8
102.5°	0.3	1.8	5.8	20.4	28.6
105°	0.3	1.8	4.7	13.4	18.9
107.5°	0.5	1.8	4.2	10.0	13.1
110°	0.3	1.6	4.5	7.6	10.2

TEST NUMBER: P517476

CATALOG NUMBER: HVL12-4-LD4-1STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	1.3	4.2	6.3	7.6
115°	0.3	1.0	3.7	6.0	6.3
117.5°	0.5	0.8	2.9	6.0	6.3
120°	0.5	0.5	2.4	5.8	6.6
122.5°	0.5	0.5	1.8	5.2	6.3
125°	0.3	0.5	1.6	3.9	5.5
127.5°	0.5	0.5	1.3	3.1	4.2
130°	0.5	0.5	1.0	2.4	3.1
132.5°	0.5	0.5	0.8	1.8	2.4
135°	0.5	0.5	0.5	1.3	1.8
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)