

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517480

Luminaire Tested: HVL12-4-LD4-1STD-50-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517480
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-1STD-50-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3941.0 lumens
Efficiency: N/A
Efficacy: 117.6 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct

Input Watts (W): 33.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517480
CATALOG NUMBER: HVL12-4-LD4-1STD-50-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517480

CATALOG NUMBER: HVL12-4-LD4-1STD-50-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3520	3520	3520
5°	3512	3485	3529
10°	3466	3550	3575
15°	3403	3471	3341
20°	3326	3268	3218
25°	3245	3143	3262
30°	3122	3045	3323
35°	3034	2953	3290
40°	2940	2888	3339
45°	2838	2801	3310
50°	2714	2709	3320
55°	2534	2611	3359
60°	2394	2469	3262
65°	2117	2296	3214
70°	1727	2064	2946
75°	1233	1775	2770
80°	692	1485	2594
85°	257	1186	2441

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 3359 cd/sqm

TEST NUMBER: P517480

CATALOG NUMBER: HVL12-4-LD4-1STD-50-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	125.7	3.2
10°-20°	358.1	9.1
20°-30°	532.7	13.5
30°-40°	640.4	16.2
40°-50°	674.0	17.1
50°-60°	625.4	15.9
60°-70°	494.5	12.5
70°-80°	302.0	7.7
80°-90°	131.6	3.3
90°-100°	41.0	1.0
100°-110°	9.2	0.2
110°-120°	3.7	0.1
120°-130°	2.1	0.1
130°-140°	0.6	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1016.5	25.8
0°-40°	1656.9	42.0
0°-60°	2956.3	75.0
0°-90°	3884.5	98.6
90°-120°	53.9	1.4
90°-150°	56.5	1.4
90°-180°	57.0	1.4
0°-180°	3941.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1308	1308	1308	1308	1308	
5°	1305	1302	1307	1322	1325	124
15°	1235	1283	1295	1252	1253	348
25°	1114	1185	1131	1165	1184	512
35°	951	977	992	1082	1118	594
45°	777	780	844	978	1015	599
55°	572	582	674	821	886	514
65°	362	374	475	628	685	359
75°	137	182	265	407	432	149
85°	12	43	103	200	230	19
90°	0	13	54	127	150	1
95°	0	3	24	70	85	0
105°	0	2	5	14	19	0
115°	0	1	4	6	6	0
125°	0	0	2	4	6	0
135°	0	0	0	1	2	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517480

CATALOG NUMBER: HVL12-4-LD4-1STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1308.2	1308.2	1308.2	1308.2	1308.2
2.5°	1309.8	1306.3	1299.1	1306.1	1307.9
5°	1305.0	1302.3	1306.9	1321.5	1325.3
7.5°	1294.1	1304.2	1316.2	1342.8	1351.4
10°	1277.8	1297.0	1333.0	1355.6	1346.8
12.5°	1258.1	1290.6	1338.8	1294.6	1274.1
15°	1235.2	1282.6	1295.1	1252.2	1253.0
17.5°	1208.3	1276.0	1237.3	1236.2	1228.5
20°	1179.2	1253.6	1202.4	1200.3	1192.0
22.5°	1148.0	1224.0	1171.5	1167.2	1189.6
25°	1114.2	1185.3	1131.2	1165.1	1184.0
27.5°	1071.8	1134.7	1097.7	1145.6	1169.4
30°	1028.9	1082.5	1063.3	1130.2	1172.3
32.5°	988.7	1027.9	1035.0	1124.3	1131.2
35°	950.6	977.0	991.6	1081.7	1118.5
37.5°	908.7	915.9	954.8	1063.8	1099.3
40°	866.1	861.6	923.9	1034.5	1083.5
42.5°	820.3	818.7	891.1	1019.9	1044.4
45°	776.8	780.3	844.5	978.3	1014.8
47.5°	732.3	736.8	800.3	932.7	978.0
50°	680.6	686.5	760.8	892.2	950.6
52.5°	624.7	635.8	722.5	853.8	912.7
55°	572.2	581.5	673.7	821.1	886.3
57.5°	524.2	529.8	623.3	779.7	829.0
60°	477.0	478.3	575.9	733.9	781.1
62.5°	422.9	425.3	527.1	679.8	743.0
65°	362.2	373.6	474.6	628.1	685.1
67.5°	305.4	325.4	421.1	580.7	610.5
70°	244.6	278.5	368.6	525.0	546.0
72.5°	188.9	228.6	314.7	462.6	492.2
75°	137.0	181.5	264.6	406.7	432.2
77.5°	92.2	137.5	217.7	344.8	378.7
80°	55.2	100.5	175.9	287.5	325.7
82.5°	28.2	67.4	136.4	241.2	275.3
85°	12.3	42.6	103.1	200.1	229.7
87.5°	3.5	24.3	75.9	161.8	186.8
90°	0.3	12.8	54.1	126.8	149.5
92.5°	0.3	6.1	38.1	95.9	113.3
95°	0.3	3.2	23.7	69.6	85.0
97.5°	0.3	1.9	14.4	49.3	62.4
100°	0.3	1.6	8.5	32.8	44.5
102.5°	0.3	1.9	5.9	20.8	29.0
105°	0.3	1.9	4.8	13.6	19.2
107.5°	0.5	1.9	4.3	10.1	13.3
110°	0.3	1.6	4.5	7.7	10.4

TEST NUMBER: P517480

CATALOG NUMBER: HVL12-4-LD4-1STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	1.3	4.3	6.4	7.7
115°	0.3	1.1	3.7	6.1	6.4
117.5°	0.5	0.8	2.9	6.1	6.4
120°	0.5	0.5	2.4	5.9	6.7
122.5°	0.5	0.5	1.9	5.3	6.4
125°	0.3	0.5	1.6	4.0	5.6
127.5°	0.5	0.5	1.3	3.2	4.3
130°	0.5	0.5	1.1	2.4	3.2
132.5°	0.5	0.5	0.8	1.9	2.4
135°	0.5	0.5	0.5	1.3	1.9
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)