

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517516

Luminaire Tested: HVL12-4-LD4-2STD-30-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517516
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-2STD-30-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6943.0 lumens
Efficiency: N/A
Efficacy: 103.5 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 67.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517516

CATALOG NUMBER: HVL12-4-LD4-2STD-30-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517516

CATALOG NUMBER: HVL12-4-LD4-2STD-30-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6202	6202	6202
5°	6188	6140	6216
10°	6107	6254	6299
15°	5995	6115	5887
20°	5860	5757	5670
25°	5717	5537	5747
30°	5500	5364	5854
35°	5346	5202	5796
40°	5179	5089	5883
45°	5000	4935	5832
50°	4782	4773	5849
55°	4463	4600	5917
60°	4218	4350	5747
65°	3729	4046	5662
70°	3043	3636	5191
75°	2171	3127	4881
80°	1218	2616	4570
85°	452	2090	4301

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 5917 cd/sqm

TEST NUMBER: P517516

CATALOG NUMBER: HVL12-4-LD4-2STD-30-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	221.5	3.2
10°-20°	630.8	9.1
20°-30°	938.6	13.5
30°-40°	1128.1	16.2
40°-50°	1187.4	17.1
50°-60°	1101.8	15.9
60°-70°	871.2	12.5
70°-80°	532.1	7.7
80°-90°	231.9	3.3
90°-100°	72.2	1.0
100°-110°	16.2	0.2
110°-120°	6.5	0.1
120°-130°	3.6	0.1
130°-140°	1.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1790.9	25.8
0°-40°	2919.0	42.0
0°-60°	5208.3	75.0
0°-90°	6843.5	98.6
90°-120°	94.9	1.4
90°-150°	99.5	1.4
90°-180°	100.0	1.4
0°-180°	6943.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2305	2305	2305	2305	2305	
5°	2299	2294	2302	2328	2335	218
15°	2176	2260	2282	2206	2208	613
25°	1963	2088	1993	2053	2086	901
35°	1675	1721	1747	1906	1970	1047
45°	1368	1375	1488	1724	1788	1055
55°	1008	1024	1187	1446	1562	906
65°	638	658	836	1107	1207	632
75°	241	320	466	716	762	263
85°	22	75	182	353	405	33
90°	0	22	95	224	263	1
95°	0	6	42	122	150	0
105°	0	3	8	24	34	1
115°	0	2	7	11	11	1
125°	0	1	3	7	10	1
135°	1	1	1	2	3	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517516

CATALOG NUMBER: HVL12-4-LD4-2STD-30-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2304.7	2304.7	2304.7	2304.7	2304.7
2.5°	2307.5	2301.4	2288.7	2300.9	2304.2
5°	2299.1	2294.4	2302.4	2328.2	2334.7
7.5°	2279.8	2297.7	2318.8	2365.7	2380.8
10°	2251.2	2285.0	2348.4	2388.3	2372.8
12.5°	2216.4	2273.7	2358.7	2280.8	2244.6
15°	2176.1	2259.6	2281.7	2206.1	2207.5
17.5°	2128.6	2247.9	2179.8	2177.9	2164.3
20°	2077.5	2208.5	2118.3	2114.6	2100.0
22.5°	2022.5	2156.3	2063.9	2056.3	2095.8
25°	1962.9	2088.3	1993.0	2052.6	2085.9
27.5°	1888.3	1999.1	1933.8	2018.3	2060.1
30°	1812.7	1907.0	1873.2	1991.1	2065.3
32.5°	1741.8	1810.8	1823.5	1980.8	1993.0
35°	1674.7	1721.1	1747.0	1905.6	1970.4
37.5°	1600.9	1613.6	1682.2	1874.2	1936.6
40°	1525.8	1517.8	1627.7	1822.5	1908.9
42.5°	1445.1	1442.3	1570.0	1796.7	1839.9
45°	1368.5	1374.6	1487.8	1723.5	1787.8
47.5°	1290.1	1298.1	1409.9	1643.2	1723.0
50°	1199.1	1209.4	1340.4	1571.8	1674.7
52.5°	1100.5	1120.2	1272.8	1504.2	1608.0
55°	1008.0	1024.4	1186.9	1446.5	1561.5
57.5°	923.5	933.3	1098.1	1373.7	1460.6
60°	840.4	842.7	1014.6	1293.0	1376.1
62.5°	745.1	749.3	928.6	1197.7	1308.9
65°	638.0	658.2	836.2	1106.6	1207.0
67.5°	538.0	573.2	741.8	1023.0	1075.6
70°	431.0	490.6	649.3	924.9	962.0
72.5°	332.9	402.8	554.5	815.0	867.1
75°	241.3	319.7	466.2	716.4	761.5
77.5°	162.4	242.3	383.6	607.5	667.1
80°	97.2	177.0	309.9	506.6	573.7
82.5°	49.8	118.8	240.4	424.9	485.0
85°	21.6	75.1	181.7	352.6	404.7
87.5°	6.1	42.7	133.8	285.0	329.1
90°	0.5	22.5	95.3	223.5	263.4
92.5°	0.5	10.8	67.1	169.0	199.5
95°	0.5	5.6	41.8	122.5	149.8
97.5°	0.5	3.3	25.4	86.9	109.9
100°	0.5	2.8	15.0	57.7	78.4
102.5°	0.5	3.3	10.3	36.6	51.2
105°	0.5	3.3	8.5	23.9	33.8
107.5°	0.9	3.3	7.5	17.8	23.5
110°	0.5	2.8	8.0	13.6	18.3

TEST NUMBER: P517516

CATALOG NUMBER: HVL12-4-LD4-2STD-30-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.9	2.3	7.5	11.3	13.6
115°	0.5	1.9	6.6	10.8	11.3
117.5°	0.9	1.4	5.2	10.8	11.3
120°	0.9	0.9	4.2	10.3	11.7
122.5°	0.9	0.9	3.3	9.4	11.3
125°	0.5	0.9	2.8	7.0	9.9
127.5°	0.9	0.9	2.3	5.6	7.5
130°	0.9	0.9	1.9	4.2	5.6
132.5°	0.9	0.9	1.4	3.3	4.2
135°	0.9	0.9	0.9	2.3	3.3
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)