

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517524

Luminaire Tested: HVL12-4-LD4-2STD-40-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517524
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-2STD-40-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7360.0 lumens
Efficiency: N/A
Efficacy: 109.7 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 67.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517524

CATALOG NUMBER: HVL12-4-LD4-2STD-40-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517524

CATALOG NUMBER: HVL12-4-LD4-2STD-40-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6574	6574	6574
5°	6559	6509	6590
10°	6473	6630	6677
15°	6356	6482	6241
20°	6212	6103	6010
25°	6060	5870	6092
30°	5830	5687	6206
35°	5666	5515	6145
40°	5490	5394	6236
45°	5300	5231	6182
50°	5070	5060	6200
55°	4731	4876	6273
60°	4472	4611	6092
65°	3953	4289	6002
70°	3226	3855	5503
75°	2302	3315	5174
80°	1291	2773	4845
85°	479	2215	4559

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 6273 cd/sqm

TEST NUMBER: P517524

CATALOG NUMBER: HVL12-4-LD4-2STD-40-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	234.8	3.2
10°-20°	668.7	9.1
20°-30°	994.9	13.5
30°-40°	1195.9	16.2
40°-50°	1258.8	17.1
50°-60°	1168.0	15.9
60°-70°	923.5	12.5
70°-80°	564.1	7.7
80°-90°	245.8	3.3
90°-100°	76.5	1.0
100°-110°	17.2	0.2
110°-120°	6.9	0.1
120°-130°	3.9	0.1
130°-140°	1.1	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1898.4	25.8
0°-40°	3094.3	42.0
0°-60°	5521.1	75.0
0°-90°	7254.4	98.6
90°-120°	100.6	1.4
90°-150°	105.6	1.4
90°-180°	106.0	1.4
0°-180°	7360.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2443	2443	2443	2443	2443	
5°	2437	2432	2441	2468	2475	231
15°	2307	2395	2419	2339	2340	650
25°	2081	2214	2113	2176	2211	955
35°	1775	1824	1852	2020	2089	1110
45°	1451	1457	1577	1827	1895	1118
55°	1068	1086	1258	1533	1655	960
65°	676	698	886	1173	1280	670
75°	256	339	494	760	807	279
85°	23	80	193	374	429	35
90°	0	24	101	237	279	1
95°	0	6	44	130	159	0
105°	0	4	9	25	36	1
115°	0	2	7	11	12	1
125°	0	1	3	8	10	1
135°	1	1	1	2	4	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517524

CATALOG NUMBER: HVL12-4-LD4-2STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2443.1	2443.1	2443.1	2443.1	2443.1
2.5°	2446.1	2439.6	2426.2	2439.1	2442.6
5°	2437.1	2432.2	2440.6	2468.0	2475.0
7.5°	2416.7	2435.7	2458.1	2507.8	2523.7
10°	2386.4	2422.2	2489.4	2531.7	2515.3
12.5°	2349.6	2410.3	2500.4	2417.7	2379.4
15°	2306.8	2395.3	2418.7	2338.6	2340.1
17.5°	2256.5	2382.9	2310.7	2308.7	2294.3
20°	2202.2	2341.1	2245.5	2241.6	2226.1
22.5°	2144.0	2285.9	2187.8	2179.8	2221.7
25°	2080.8	2213.7	2112.7	2175.9	2211.2
27.5°	2001.7	2119.1	2050.0	2139.5	2183.8
30°	1921.5	2021.6	1985.8	2110.7	2189.3
32.5°	1846.4	1919.6	1933.0	2099.7	2112.7
35°	1775.2	1824.5	1851.9	2020.1	2088.8
37.5°	1697.1	1710.5	1783.2	1986.7	2052.9
40°	1617.5	1609.0	1725.5	1932.0	2023.6
42.5°	1531.9	1528.9	1664.2	1904.6	1950.4
45°	1450.7	1457.2	1577.2	1827.0	1895.2
47.5°	1367.6	1376.1	1494.5	1741.9	1826.5
50°	1271.1	1282.0	1420.9	1666.2	1775.2
52.5°	1166.6	1187.5	1349.2	1594.6	1704.6
55°	1068.5	1085.9	1258.1	1533.4	1655.3
57.5°	978.9	989.4	1164.1	1456.2	1548.3
60°	890.9	893.3	1075.5	1370.6	1458.7
62.5°	789.8	794.3	984.4	1269.6	1387.5
65°	676.3	697.7	886.4	1173.0	1279.5
67.5°	570.3	607.7	786.3	1084.4	1140.2
70°	456.9	520.1	688.3	980.4	1019.7
72.5°	352.9	427.0	587.8	864.0	919.2
75°	255.8	338.9	494.2	759.5	807.2
77.5°	172.2	256.8	406.6	644.0	707.2
80°	103.0	187.6	328.5	537.0	608.2
82.5°	52.8	125.9	254.8	450.4	514.1
85°	22.9	79.6	192.6	373.8	429.0
87.5°	6.5	45.3	141.8	302.1	348.9
90°	0.5	23.9	101.0	236.9	279.2
92.5°	0.5	11.4	71.2	179.2	211.5
95°	0.5	6.0	44.3	129.9	158.8
97.5°	0.5	3.5	26.9	92.1	116.5
100°	0.5	3.0	15.9	61.2	83.1
102.5°	0.5	3.5	10.9	38.8	54.2
105°	0.5	3.5	9.0	25.4	35.8
107.5°	1.0	3.5	8.0	18.9	24.9
110°	0.5	3.0	8.5	14.4	19.4

TEST NUMBER: P517524

CATALOG NUMBER: HVL12-4-LD4-2STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.0	2.5	8.0	11.9	14.4
115°	0.5	2.0	7.0	11.4	11.9
117.5°	1.0	1.5	5.5	11.4	11.9
120°	1.0	1.0	4.5	10.9	12.4
122.5°	1.0	1.0	3.5	10.0	11.9
125°	0.5	1.0	3.0	7.5	10.5
127.5°	1.0	1.0	2.5	6.0	8.0
130°	1.0	1.0	2.0	4.5	6.0
132.5°	1.0	1.0	1.5	3.5	4.5
135°	1.0	1.0	1.0	2.5	3.5
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)