

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517528

Luminaire Tested: HVL12-4-LD4-2STD-50-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517528
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-2STD-50-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7484.9 lumens
Efficiency: N/A
Efficacy: 111.5 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 67.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517528

CATALOG NUMBER: HVL12-4-LD4-2STD-50-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517528

CATALOG NUMBER: HVL12-4-LD4-2STD-50-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		0
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		99
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		81
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		67
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		56
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		47
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		41
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		36
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		32
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		28
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		25
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6686	6686	6686
5°	6671	6619	6701
10°	6583	6743	6790
15°	6463	6592	6346
20°	6318	6207	6112
25°	6163	5969	6195
30°	5930	5783	6311
35°	5763	5608	6249
40°	5583	5486	6342
45°	5390	5320	6287
50°	5156	5146	6305
55°	4812	4959	6379
60°	4548	4690	6195
65°	4020	4361	6104
70°	3280	3920	5597
75°	2341	3372	5262
80°	1314	2820	4927
85°	487	2253	4637

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 6379 cd/sqm

TEST NUMBER: P517528

CATALOG NUMBER: HVL12-4-LD4-2STD-50-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	238.8	3.2
10°-20°	680.0	9.1
20°-30°	1011.8	13.5
30°-40°	1216.2	16.2
40°-50°	1280.1	17.1
50°-60°	1187.8	15.9
60°-70°	939.2	12.5
70°-80°	573.7	7.7
80°-90°	249.9	3.3
90°-100°	77.8	1.0
100°-110°	17.5	0.2
110°-120°	7.0	0.1
120°-130°	3.9	0.1
130°-140°	1.1	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1930.7	25.8
0°-40°	3146.9	42.0
0°-60°	5614.8	75.0
0°-90°	7377.7	98.6
90°-120°	102.3	1.4
90°-150°	107.3	1.4
90°-180°	107.0	1.4
0°-180°	7484.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2485	2485	2485	2485	2485	
5°	2478	2474	2482	2510	2517	235
15°	2346	2436	2460	2378	2380	661
25°	2116	2251	2148	2213	2249	971
35°	1805	1856	1883	2054	2124	1128
45°	1475	1482	1604	1858	1927	1137
55°	1087	1104	1280	1559	1683	976
65°	688	710	901	1193	1301	681
75°	260	345	503	772	821	284
85°	23	81	196	380	436	36
90°	0	24	103	241	284	1
95°	0	6	45	132	162	0
105°	0	4	9	26	36	1
115°	0	2	7	12	12	1
125°	0	1	3	8	11	1
135°	1	1	1	2	4	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517528

CATALOG NUMBER: HVL12-4-LD4-2STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2484.6	2484.6	2484.6	2484.6	2484.6
2.5°	2487.6	2481.1	2467.4	2480.6	2484.1
5°	2478.5	2473.5	2482.1	2509.9	2517.0
7.5°	2457.8	2477.0	2499.8	2550.4	2566.6
10°	2426.9	2463.4	2531.7	2574.7	2558.0
12.5°	2389.5	2451.2	2542.8	2458.8	2419.8
15°	2345.9	2436.0	2459.8	2378.3	2379.8
17.5°	2294.8	2423.4	2350.0	2348.0	2333.3
20°	2239.6	2380.9	2283.7	2279.6	2263.9
22.5°	2180.4	2324.7	2225.0	2216.9	2259.4
25°	2116.1	2251.3	2148.5	2212.8	2248.8
27.5°	2035.7	2155.1	2084.8	2175.9	2220.9
30°	1954.2	2055.9	2019.5	2146.5	2226.5
32.5°	1877.8	1952.2	1965.8	2135.4	2148.5
35°	1805.4	1855.5	1883.3	2054.4	2124.2
37.5°	1725.9	1739.6	1813.5	2020.5	2087.8
40°	1644.9	1636.3	1754.8	1964.8	2057.9
42.5°	1557.9	1554.8	1692.5	1937.0	1983.5
45°	1475.4	1482.0	1603.9	1858.0	1927.4
47.5°	1390.9	1399.5	1519.9	1771.5	1857.5
50°	1292.7	1303.8	1445.0	1694.5	1805.4
52.5°	1186.4	1207.6	1372.1	1621.7	1733.5
55°	1086.7	1104.4	1279.5	1559.4	1683.4
57.5°	995.6	1006.2	1183.8	1480.9	1574.6
60°	906.0	908.5	1093.8	1393.9	1483.5
62.5°	803.2	807.8	1001.1	1291.1	1411.1
65°	687.8	709.6	901.4	1193.0	1301.3
67.5°	580.0	618.0	799.7	1102.9	1159.6
70°	464.6	528.9	700.0	997.1	1037.1
72.5°	358.8	434.3	597.7	878.6	934.8
75°	260.2	344.7	502.6	772.4	820.9
77.5°	175.1	261.2	413.5	654.9	719.2
80°	104.8	190.8	334.0	546.1	618.5
82.5°	53.7	128.1	259.1	458.1	522.8
85°	23.3	81.0	195.9	380.1	436.3
87.5°	6.6	46.1	144.2	307.2	354.8
90°	0.5	24.3	102.7	240.9	283.9
92.5°	0.5	11.6	72.4	182.2	215.1
95°	0.5	6.1	45.0	132.1	161.5
97.5°	0.5	3.5	27.3	93.6	118.4
100°	0.5	3.0	16.2	62.3	84.5
102.5°	0.5	3.5	11.1	39.5	55.2
105°	0.5	3.5	9.1	25.8	36.4
107.5°	1.0	3.5	8.1	19.2	25.3
110°	0.5	3.0	8.6	14.7	19.7

TEST NUMBER: P517528

CATALOG NUMBER: HVL12-4-LD4-2STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.0	2.5	8.1	12.1	14.7
115°	0.5	2.0	7.1	11.6	12.1
117.5°	1.0	1.5	5.6	11.6	12.1
120°	1.0	1.0	4.6	11.1	12.7
122.5°	1.0	1.0	3.5	10.1	12.1
125°	0.5	1.0	3.0	7.6	10.6
127.5°	1.0	1.0	2.5	6.1	8.1
130°	1.0	1.0	2.0	4.6	6.1
132.5°	1.0	1.0	1.5	3.5	4.6
135°	1.0	1.0	1.0	2.5	3.5
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)