

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517564

Luminaire Tested: HVL12-4-LD4-3STD-30-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517564
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-3STD-30-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 10949.0 lumens
Efficiency: N/A
Efficacy: 111.6 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 98.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517564

CATALOG NUMBER: HVL12-4-LD4-3STD-30-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517564

CATALOG NUMBER: HVL12-4-LD4-3STD-30-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	9780	9780	9780
5°	9758	9683	9803
10°	9630	9863	9932
15°	9455	9644	9284
20°	9242	9079	8941
25°	9016	8732	9063
30°	8674	8460	9232
35°	8430	8204	9141
40°	8167	8025	9277
45°	7885	7782	9196
50°	7542	7527	9224
55°	7039	7255	9331
60°	6653	6860	9062
65°	5881	6380	8928
70°	4798	5734	8186
75°	3424	4932	7697
80°	1922	4125	7207
85°	713	3296	6782

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 9331 cd/sqm

TEST NUMBER: P517564

CATALOG NUMBER: HVL12-4-LD4-3STD-30-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	349.3	3.2
10°-20°	994.8	9.1
20°-30°	1480.1	13.5
30°-40°	1779.1	16.2
40°-50°	1872.6	17.1
50°-60°	1737.5	15.9
60°-70°	1373.8	12.5
70°-80°	839.2	7.7
80°-90°	365.6	3.3
90°-100°	113.8	1.0
100°-110°	25.6	0.2
110°-120°	10.3	0.1
120°-130°	5.8	0.1
130°-140°	1.6	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2824.2	25.8
0°-40°	4603.2	42.0
0°-60°	8213.4	75.0
0°-90°	10792.0	98.6
90°-120°	149.7	1.4
90°-150°	157.0	1.4
90°-180°	157.0	1.4
0°-180°	10949.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3634	3634	3634	3634	3634	
5°	3626	3618	3631	3672	3682	344
15°	3432	3563	3598	3479	3481	967
25°	3096	3293	3143	3237	3290	1421
35°	2641	2714	2755	3005	3107	1651
45°	2158	2168	2346	2718	2819	1664
55°	1590	1616	1872	2281	2462	1428
65°	1006	1038	1319	1745	1904	997
75°	380	504	735	1130	1201	415
85°	34	118	286	556	638	53
90°	1	36	150	352	415	2
95°	1	9	66	193	236	1
105°	1	5	13	38	53	1
115°	1	3	10	17	18	1
125°	1	2	4	11	16	1
135°	2	2	2	4	5	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517564

CATALOG NUMBER: HVL12-4-LD4-3STD-30-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3634.5	3634.5	3634.5	3634.5	3634.5
2.5°	3638.9	3629.3	3609.3	3628.5	3633.7
5°	3625.6	3618.2	3630.8	3671.5	3681.9
7.5°	3595.2	3623.4	3656.7	3730.7	3754.4
10°	3550.1	3603.4	3703.3	3766.3	3741.8
12.5°	3495.3	3585.6	3719.6	3596.7	3539.7
15°	3431.6	3563.4	3598.2	3479.0	3481.2
17.5°	3356.8	3544.9	3437.5	3434.6	3413.1
20°	3276.1	3482.7	3340.5	3334.6	3311.7
22.5°	3189.5	3400.5	3254.7	3242.8	3305.0
25°	3095.5	3293.2	3142.9	3236.9	3289.5
27.5°	2977.8	3152.5	3049.6	3182.8	3248.7
30°	2858.6	3007.4	2954.1	3139.9	3256.9
32.5°	2746.8	2855.6	2875.6	3123.6	3142.9
35°	2640.9	2714.2	2754.9	3005.2	3107.3
37.5°	2524.7	2544.6	2652.7	2955.6	3054.0
40°	2406.2	2393.6	2566.9	2874.1	3010.3
42.5°	2278.9	2274.4	2475.8	2833.4	2901.5
45°	2158.2	2167.8	2346.2	2717.9	2819.3
47.5°	2034.5	2047.1	2223.3	2591.3	2717.2
50°	1890.9	1907.2	2113.8	2478.8	2640.9
52.5°	1735.4	1766.5	2007.1	2372.1	2535.8
55°	1589.6	1615.5	1871.7	2281.1	2462.5
57.5°	1456.3	1471.9	1731.7	2166.3	2303.3
60°	1325.3	1329.0	1599.9	2039.0	2170.0
62.5°	1175.0	1181.6	1464.5	1888.7	2064.1
65°	1006.2	1038.0	1318.6	1745.1	1903.5
67.5°	848.5	904.0	1169.8	1613.3	1696.2
70°	679.7	773.7	1023.9	1458.5	1517.0
72.5°	524.9	635.2	874.4	1285.3	1367.5
75°	380.5	504.2	735.2	1129.8	1200.9
77.5°	256.2	382.0	604.9	958.0	1052.1
80°	153.3	279.1	488.6	798.9	904.7
82.5°	78.5	187.3	379.1	670.0	764.8
85°	34.1	118.5	286.5	556.0	638.2
87.5°	9.6	67.4	211.0	449.4	519.0
90°	0.7	35.5	150.3	352.4	415.3
92.5°	0.7	17.0	105.9	266.5	314.7
95°	0.7	8.9	65.9	193.2	236.2
97.5°	0.7	5.2	40.0	137.0	173.2
100°	0.7	4.4	23.7	91.1	123.6
102.5°	0.7	5.2	16.3	57.7	80.7
105°	0.7	5.2	13.3	37.8	53.3
107.5°	1.5	5.2	11.8	28.1	37.0
110°	0.7	4.4	12.6	21.5	28.9

TEST NUMBER: P517564

CATALOG NUMBER: HVL12-4-LD4-3STD-30-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.5	3.7	11.8	17.8	21.5
115°	0.7	3.0	10.4	17.0	17.8
117.5°	1.5	2.2	8.1	17.0	17.8
120°	1.5	1.5	6.7	16.3	18.5
122.5°	1.5	1.5	5.2	14.8	17.8
125°	0.7	1.5	4.4	11.1	15.5
127.5°	1.5	1.5	3.7	8.9	11.8
130°	1.5	1.5	3.0	6.7	8.9
132.5°	1.5	1.5	2.2	5.2	6.7
135°	1.5	1.5	1.5	3.7	5.2
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)