

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517572

Luminaire Tested: HVL12-4-LD4-3STD-40-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517572
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-3STD-40-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 11607.0 lumens
Efficiency: N/A
Efficacy: 118.3 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 98.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517572

CATALOG NUMBER: HVL12-4-LD4-3STD-40-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517572

CATALOG NUMBER: HVL12-4-LD4-3STD-40-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	10368	10368	10368
5°	10345	10265	10392
10°	10208	10456	10529
15°	10023	10223	9842
20°	9797	9625	9478
25°	9558	9256	9607
30°	9195	8968	9786
35°	8936	8697	9690
40°	8658	8507	9835
45°	8359	8250	9749
50°	7995	7980	9778
55°	7462	7690	9892
60°	7052	7272	9607
65°	6234	6763	9465
70°	5086	6079	8678
75°	3630	5228	8159
80°	2037	4373	7640
85°	755	3493	7190

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 9892 cd/sqm

TEST NUMBER: P517572

CATALOG NUMBER: HVL12-4-LD4-3STD-40-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	370.3	3.2
10°-20°	1054.5	9.1
20°-30°	1569.0	13.5
30°-40°	1886.0	16.2
40°-50°	1985.1	17.1
50°-60°	1842.0	15.9
60°-70°	1456.4	12.5
70°-80°	889.6	7.7
80°-90°	387.6	3.3
90°-100°	120.7	1.0
100°-110°	27.1	0.2
110°-120°	10.9	0.1
120°-130°	6.1	0.1
130°-140°	1.7	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2993.9	25.8
0°-40°	4879.9	42.0
0°-60°	8706.9	75.0
0°-90°	11440.5	98.6
90°-120°	158.7	1.4
90°-150°	166.5	1.4
90°-180°	166.0	1.4
0°-180°	11607.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3853	3853	3853	3853	3853	
5°	3844	3836	3849	3892	3903	364
15°	3638	3778	3814	3688	3690	1025
25°	3282	3491	3332	3431	3487	1507
35°	2800	2877	2920	3186	3294	1750
45°	2288	2298	2487	2881	2989	1764
55°	1685	1713	1984	2418	2610	1514
65°	1067	1100	1398	1850	2018	1056
75°	403	534	779	1198	1273	440
85°	36	126	304	589	677	56
90°	1	38	159	374	440	2
95°	1	9	70	205	250	1
105°	1	6	14	40	56	1
115°	1	3	11	18	19	1
125°	1	2	5	12	16	1
135°	2	2	2	4	6	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517572

CATALOG NUMBER: HVL12-4-LD4-3STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3852.9	3852.9	3852.9	3852.9	3852.9
2.5°	3857.6	3847.4	3826.2	3846.6	3852.1
5°	3843.5	3835.6	3849.0	3892.1	3903.1
7.5°	3811.3	3841.1	3876.4	3954.9	3980.0
10°	3763.4	3819.9	3925.9	3992.6	3966.7
12.5°	3705.3	3801.1	3943.2	3812.9	3752.4
15°	3637.8	3777.5	3814.4	3688.1	3690.4
17.5°	3558.6	3757.9	3644.1	3641.0	3618.2
20°	3473.0	3692.0	3541.3	3535.0	3510.7
22.5°	3381.2	3604.9	3450.3	3437.7	3503.6
25°	3281.5	3491.1	3331.7	3431.4	3487.1
27.5°	3156.7	3341.9	3232.9	3374.1	3444.0
30°	3030.4	3188.1	3131.6	3328.6	3452.6
32.5°	2911.8	3027.2	3048.4	3311.3	3331.7
35°	2799.6	2877.3	2920.5	3185.8	3294.1
37.5°	2676.4	2697.6	2812.2	3133.2	3237.6
40°	2550.8	2537.5	2721.1	3046.8	3191.3
42.5°	2415.8	2411.1	2624.6	3003.7	3075.9
45°	2287.9	2298.1	2487.2	2881.2	2988.8
47.5°	2156.8	2170.1	2356.9	2747.0	2880.4
50°	2004.5	2021.8	2240.8	2627.7	2799.6
52.5°	1839.7	1872.7	2127.8	2514.7	2688.2
55°	1685.1	1712.6	1984.1	2418.2	2610.5
57.5°	1543.8	1560.3	1835.8	2296.5	2441.7
60°	1404.9	1408.8	1696.1	2161.5	2300.4
62.5°	1245.6	1252.6	1552.5	2002.2	2188.2
65°	1066.6	1100.4	1397.8	1849.9	2017.9
67.5°	899.5	958.3	1240.1	1710.2	1798.1
70°	720.5	820.2	1085.5	1546.2	1608.2
72.5°	556.5	673.4	926.9	1362.5	1449.6
75°	403.4	534.5	779.4	1197.7	1273.0
77.5°	271.6	405.0	641.2	1015.6	1115.3
80°	162.5	295.9	518.0	846.9	959.1
82.5°	83.2	198.6	401.8	710.3	810.8
85°	36.1	125.6	303.7	589.4	676.6
87.5°	10.2	71.4	223.7	476.4	550.2
90°	0.8	37.7	159.3	373.6	440.3
92.5°	0.8	18.1	112.2	282.6	333.6
95°	0.8	9.4	69.9	204.8	250.4
97.5°	0.8	5.5	42.4	145.2	183.7
100°	0.8	4.7	25.1	96.5	131.1
102.5°	0.8	5.5	17.3	61.2	85.6
105°	0.8	5.5	14.1	40.0	56.5
107.5°	1.6	5.5	12.6	29.8	39.2
110°	0.8	4.7	13.3	22.8	30.6

TEST NUMBER: P517572

CATALOG NUMBER: HVL12-4-LD4-3STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.6	3.9	12.6	18.8	22.8
115°	0.8	3.1	11.0	18.1	18.8
117.5°	1.6	2.4	8.6	18.1	18.8
120°	1.6	1.6	7.1	17.3	19.6
122.5°	1.6	1.6	5.5	15.7	18.8
125°	0.8	1.6	4.7	11.8	16.5
127.5°	1.6	1.6	3.9	9.4	12.6
130°	1.6	1.6	3.1	7.1	9.4
132.5°	1.6	1.6	2.4	5.5	7.1
135°	1.6	1.6	1.6	3.9	5.5
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)