

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517576

Luminaire Tested: HVL12-4-LD4-3STD-50-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517576
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL12-4-LD4-3STD-50-UNV-C-EDD
Description: 4 FOOT, 12 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 11804.0 lumens
Efficiency: N/A
Efficacy: 120.3 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 1' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 98.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517576

CATALOG NUMBER: HVL12-4-LD4-3STD-50-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517576

CATALOG NUMBER: HVL12-4-LD4-3STD-50-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	10544	10544	10544
5°	10520	10439	10568
10°	10382	10633	10708
15°	10193	10397	10009
20°	9963	9788	9639
25°	9720	9414	9770
30°	9351	9120	9952
35°	9088	8844	9855
40°	8805	8651	10002
45°	8500	8390	9914
50°	8131	8115	9944
55°	7588	7821	10060
60°	7172	7396	9770
65°	6340	6878	9626
70°	5173	6183	8826
75°	3692	5317	8298
80°	2071	4447	7770
85°	768	3553	7311

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 55°

Luminance: 10060 cd/sqm

TEST NUMBER: P517576

CATALOG NUMBER: HVL12-4-LD4-3STD-50-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	376.6	3.2
10°-20°	1072.4	9.1
20°-30°	1595.7	13.5
30°-40°	1918.0	16.2
40°-50°	2018.8	17.1
50°-60°	1873.2	15.9
60°-70°	1481.1	12.5
70°-80°	904.7	7.7
80°-90°	394.2	3.3
90°-100°	122.7	1.0
100°-110°	27.6	0.2
110°-120°	11.1	0.1
120°-130°	6.2	0.1
130°-140°	1.7	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3044.7	25.8
0°-40°	4962.7	42.0
0°-60°	8854.7	75.0
0°-90°	11634.7	98.6
90°-120°	161.4	1.4
90°-150°	169.3	1.4
90°-180°	169.0	1.4
0°-180°	11804.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3918	3918	3918	3918	3918	
5°	3909	3901	3914	3958	3969	370
15°	3700	3842	3879	3751	3753	1042
25°	3337	3550	3388	3490	3546	1532
35°	2847	2926	2970	3240	3350	1779
45°	2327	2337	2529	2930	3040	1794
55°	1714	1742	2018	2459	2655	1540
65°	1085	1119	1422	1881	2052	1074
75°	410	544	793	1218	1295	448
85°	37	128	309	599	688	57
90°	1	38	162	380	448	2
95°	1	10	71	208	255	1
105°	1	6	14	41	58	1
115°	1	3	11	18	19	1
125°	1	2	5	12	17	1
135°	2	2	2	4	6	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517576

CATALOG NUMBER: HVL12-4-LD4-3STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3918.3	3918.3	3918.3	3918.3	3918.3
2.5°	3923.1	3912.7	3891.1	3911.9	3917.5
5°	3908.7	3900.7	3914.3	3958.2	3969.4
7.5°	3876.0	3906.3	3942.2	4022.0	4047.6
10°	3827.3	3884.8	3992.5	4060.4	4034.0
12.5°	3768.2	3865.6	4010.1	3877.6	3816.1
15°	3699.6	3841.7	3879.2	3750.7	3753.1
17.5°	3619.0	3821.7	3706.0	3702.8	3679.6
20°	3532.0	3754.7	3601.4	3595.0	3570.3
22.5°	3438.6	3666.1	3508.8	3496.0	3563.1
25°	3337.2	3550.3	3388.3	3489.7	3546.3
27.5°	3210.3	3398.7	3287.7	3431.4	3502.4
30°	3081.8	3242.2	3184.8	3385.1	3511.2
32.5°	2961.3	3078.6	3100.1	3367.5	3388.3
35°	2847.1	2926.1	2970.0	3239.8	3350.0
37.5°	2721.8	2743.4	2859.9	3186.4	3292.5
40°	2594.1	2580.5	2767.3	3098.6	3245.4
42.5°	2456.8	2452.0	2669.1	3054.7	3128.1
45°	2326.7	2337.1	2529.4	2930.1	3039.5
47.5°	2193.4	2207.0	2396.9	2793.6	2929.3
50°	2038.6	2056.1	2278.8	2672.3	2847.1
52.5°	1870.9	1904.5	2163.9	2557.4	2733.8
55°	1713.7	1741.6	2017.8	2459.2	2654.8
57.5°	1570.0	1586.8	1867.0	2335.5	2483.2
60°	1428.7	1432.7	1724.9	2198.2	2339.5
62.5°	1266.7	1273.9	1578.8	2036.2	2225.3
65°	1084.7	1119.1	1421.6	1881.3	2052.1
67.5°	914.7	974.6	1261.1	1739.2	1828.6
70°	732.7	834.1	1103.9	1572.4	1635.5
72.5°	565.9	684.8	942.7	1385.6	1474.2
75°	410.3	543.6	792.6	1218.0	1294.7
77.5°	276.2	411.9	652.1	1032.9	1134.2
80°	165.2	300.9	526.8	861.2	975.4
82.5°	84.6	201.9	408.7	722.4	824.5
85°	36.7	127.7	308.9	599.4	688.0
87.5°	10.4	72.6	227.5	484.5	559.5
90°	0.8	38.3	162.0	379.9	447.8
92.5°	0.8	18.4	114.1	287.3	339.2
95°	0.8	9.6	71.0	208.3	254.6
97.5°	0.8	5.6	43.1	147.7	186.8
100°	0.8	4.8	25.5	98.2	133.3
102.5°	0.8	5.6	17.6	62.3	87.0
105°	0.8	5.6	14.4	40.7	57.5
107.5°	1.6	5.6	12.8	30.3	39.9
110°	0.8	4.8	13.6	23.1	31.1

TEST NUMBER: P517576

CATALOG NUMBER: HVL12-4-LD4-3STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.6	4.0	12.8	19.2	23.1
115°	0.8	3.2	11.2	18.4	19.2
117.5°	1.6	2.4	8.8	18.4	19.2
120°	1.6	1.6	7.2	17.6	20.0
122.5°	1.6	1.6	5.6	16.0	19.2
125°	0.8	1.6	4.8	12.0	16.8
127.5°	1.6	1.6	4.0	9.6	12.8
130°	1.6	1.6	3.2	7.2	9.6
132.5°	1.6	1.6	2.4	5.6	7.2
135°	1.6	1.6	1.6	4.0	5.6
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)