

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517868

Luminaire Tested: HVL8-2-LD4-1HI-30-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517868
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-2-LD4-1HI-30-UNV-C-EDD
Description: 2 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2253.0 lumens
Efficiency: N/A
Efficacy: 104.8 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 2' x H: 0.17')
CIE Type: Direct


Input Watts (W): 21.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517868

CATALOG NUMBER: HVL8-2-LD4-1HI-30-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517868

CATALOG NUMBER: HVL8-2-LD4-1HI-30-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6038	6038	6038
5°	6002	5932	6008
10°	5902	5997	6046
15°	5772	5820	5611
20°	5621	5439	5366
25°	5462	5190	5400
30°	5231	4988	5459
35°	5060	4795	5363
40°	4877	4647	5395
45°	4680	4460	5298
50°	4445	4265	5258
55°	4114	4055	5255
60°	3848	3774	5030
65°	3355	3442	4871
70°	2687	3018	4368
75°	1863	2510	3987
80°	994	1999	3580
85°	332	1479	3152

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 5298 cd/sqm

TEST NUMBER: P517868

CATALOG NUMBER: HVL8-2-LD4-1HI-30-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	71.9	3.2
10°-20°	204.7	9.1
20°-30°	304.6	13.5
30°-40°	366.1	16.2
40°-50°	385.3	17.1
50°-60°	357.5	15.9
60°-70°	282.7	12.5
70°-80°	172.7	7.7
80°-90°	75.2	3.3
90°-100°	23.4	1.0
100°-110°	5.3	0.2
110°-120°	2.1	0.1
120°-130°	1.2	0.1
130°-140°	0.3	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	581.1	25.8
0°-40°	947.2	42.0
0°-60°	1690.1	75.0
0°-90°	2220.7	98.6
90°-120°	30.8	1.4
90°-150°	32.3	1.4
90°-180°	32.0	1.4
0°-180°	2253.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	748	748	748	748	748	
5°	746	744	747	756	758	71
15°	706	733	740	716	716	199
25°	637	678	647	666	677	292
35°	543	558	567	618	639	340
45°	444	446	483	559	580	342
55°	327	332	385	469	507	294
65°	207	214	271	359	392	205
75°	78	104	151	232	247	85
85°	7	24	59	114	131	11
90°	0	7	31	72	86	0
95°	0	2	14	40	49	0
105°	0	1	3	8	11	0
115°	0	1	2	4	4	0
125°	0	0	1	2	3	0
135°	0	0	0	1	1	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517868

CATALOG NUMBER: HVL8-2-LD4-1HI-30-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	747.9	747.9	747.9	747.9	747.9
2.5°	748.8	746.8	742.7	746.7	747.7
5°	746.0	744.5	747.1	755.5	757.6
7.5°	739.8	745.6	752.4	767.7	772.6
10°	730.5	741.5	762.0	775.0	770.0
12.5°	719.2	737.8	765.4	740.1	728.4
15°	706.1	733.2	740.4	715.9	716.3
17.5°	690.7	729.4	707.3	706.7	702.3
20°	674.1	716.6	687.4	686.2	681.4
22.5°	656.3	699.7	669.7	667.3	680.1
25°	637.0	677.6	646.7	666.1	676.9
27.5°	612.7	648.7	627.5	654.9	668.5
30°	588.2	618.8	607.9	646.1	670.2
32.5°	565.2	587.6	591.7	642.8	646.7
35°	543.4	558.5	566.9	618.4	639.4
37.5°	519.5	523.6	545.9	608.2	628.4
40°	495.1	492.5	528.2	591.4	619.4
42.5°	468.9	468.0	509.4	583.0	597.0
45°	444.1	446.1	482.8	559.3	580.1
47.5°	418.7	421.2	457.5	533.2	559.1
50°	389.1	392.4	435.0	510.1	543.4
52.5°	357.1	363.5	413.0	488.1	521.8
55°	327.1	332.4	385.1	469.4	506.7
57.5°	299.7	302.9	356.3	445.8	474.0
60°	272.7	273.5	329.2	419.6	446.5
62.5°	241.8	243.1	301.3	388.6	424.7
65°	207.0	213.6	271.3	359.1	391.7
67.5°	174.6	186.0	240.7	332.0	349.0
70°	139.9	159.2	210.7	300.1	312.2
72.5°	108.0	130.7	179.9	264.5	281.4
75°	78.3	103.7	151.3	232.5	247.1
77.5°	52.7	78.6	124.5	197.1	216.5
80°	31.5	57.4	100.5	164.4	186.2
82.5°	16.1	38.5	78.0	137.9	157.4
85°	7.0	24.4	59.0	114.4	131.3
87.5°	2.0	13.9	43.4	92.5	106.8
90°	0.2	7.3	30.9	72.5	85.5
92.5°	0.2	3.5	21.8	54.8	64.7
95°	0.2	1.8	13.6	39.8	48.6
97.5°	0.2	1.1	8.2	28.2	35.6
100°	0.2	0.9	4.9	18.7	25.4
102.5°	0.2	1.1	3.4	11.9	16.6
105°	0.2	1.1	2.7	7.8	11.0
107.5°	0.3	1.1	2.4	5.8	7.6
110°	0.2	0.9	2.6	4.4	5.9

TEST NUMBER: P517868

CATALOG NUMBER: HVL8-2-LD4-1HI-30-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.3	0.8	2.4	3.7	4.4
115°	0.2	0.6	2.1	3.5	3.7
117.5°	0.3	0.5	1.7	3.5	3.7
120°	0.3	0.3	1.4	3.4	3.8
122.5°	0.3	0.3	1.1	3.0	3.7
125°	0.2	0.3	0.9	2.3	3.2
127.5°	0.3	0.3	0.8	1.8	2.4
130°	0.3	0.3	0.6	1.4	1.8
132.5°	0.3	0.3	0.5	1.1	1.4
135°	0.3	0.3	0.3	0.8	1.1
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)