

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518016

Luminaire Tested: HVL8-4-LD4-1HI-35-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518016
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-1HI-35-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4729.9 lumens
Efficiency: N/A
Efficacy: 110.0 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 43
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518016

CATALOG NUMBER: HVL8-4-LD4-1HI-35-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518016

CATALOG NUMBER: HVL8-4-LD4-1HI-35-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6338	6338	6338
5°	6323	6243	6307
10°	6240	6327	6346
15°	6127	6155	5890
20°	5989	5766	5633
25°	5842	5516	5668
30°	5621	5315	5731
35°	5463	5124	5629
40°	5292	4981	5664
45°	5109	4797	5562
50°	4887	4602	5520
55°	4561	4396	5516
60°	4311	4111	5281
65°	3811	3772	5112
70°	3109	3332	4585
75°	2219	2799	4185
80°	1245	2261	3757
85°	461	1708	3310

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 5562 cd/sqm

TEST NUMBER: P518016

CATALOG NUMBER: HVL8-4-LD4-1HI-35-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	150.9	3.2
10°-20°	429.7	9.1
20°-30°	639.4	13.5
30°-40°	768.6	16.2
40°-50°	809.0	17.1
50°-60°	750.6	15.9
60°-70°	593.5	12.5
70°-80°	362.5	7.7
80°-90°	158.0	3.3
90°-100°	49.2	1.0
100°-110°	11.0	0.2
110°-120°	4.4	0.1
120°-130°	2.5	0.1
130°-140°	0.7	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1220.0	25.8
0°-40°	1988.6	42.0
0°-60°	3548.2	75.0
0°-90°	4662.1	98.6
90°-120°	64.6	1.4
90°-150°	67.8	1.4
90°-180°	68.0	1.4
0°-180°	4729.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1570	1570	1570	1570	1570	
5°	1566	1563	1568	1586	1591	148
15°	1482	1539	1554	1503	1504	418
25°	1337	1423	1358	1398	1421	614
35°	1141	1172	1190	1298	1342	713
45°	932	936	1014	1174	1218	719
55°	687	698	809	985	1064	617
65°	435	448	570	754	822	430
75°	164	218	318	488	519	179
85°	15	51	124	240	276	23
90°	0	15	65	152	179	1
95°	0	4	28	84	102	0
105°	0	2	6	16	23	0
115°	0	1	4	7	8	0
125°	0	1	2	5	7	0
135°	1	1	1	2	2	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518016

CATALOG NUMBER: HVL8-4-LD4-1HI-35-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1570.1	1570.1	1570.1	1570.1	1570.1
2.5°	1572.0	1567.9	1559.2	1567.5	1569.8
5°	1566.3	1563.1	1568.5	1586.1	1590.6
7.5°	1553.2	1565.3	1579.7	1611.7	1621.9
10°	1533.6	1556.7	1599.8	1627.0	1616.5
12.5°	1510.0	1549.0	1606.9	1553.8	1529.2
15°	1482.5	1539.4	1554.4	1502.9	1503.9
17.5°	1450.2	1531.4	1485.0	1483.7	1474.5
20°	1415.3	1504.5	1443.1	1440.6	1430.7
22.5°	1377.9	1469.0	1406.0	1400.9	1427.8
25°	1337.3	1422.7	1357.7	1398.3	1421.1
27.5°	1286.4	1361.9	1317.4	1375.0	1403.5
30°	1234.9	1299.2	1276.2	1356.4	1407.0
32.5°	1186.6	1233.6	1242.3	1349.4	1357.7
35°	1140.9	1172.5	1190.1	1298.2	1342.4
37.5°	1090.7	1099.3	1146.0	1276.8	1319.3
40°	1039.5	1034.0	1108.9	1241.6	1300.5
42.5°	984.5	982.6	1069.6	1224.0	1253.5
45°	932.3	936.5	1013.6	1174.1	1218.0
47.5°	878.9	884.4	960.5	1119.4	1173.8
50°	816.9	823.9	913.1	1070.8	1140.9
52.5°	749.7	763.1	867.1	1024.8	1095.5
55°	686.7	697.9	808.6	985.4	1063.8
57.5°	629.1	635.8	748.1	935.9	995.0
60°	572.5	574.1	691.2	880.8	937.5
62.5°	507.6	510.5	632.6	815.9	891.7
65°	434.7	448.4	569.6	753.9	822.3
67.5°	366.5	390.5	505.3	696.9	732.8
70°	293.6	334.2	442.3	630.1	655.4
72.5°	226.8	274.4	377.7	555.2	590.7
75°	164.4	217.8	317.6	488.1	518.8
77.5°	110.7	165.0	261.3	413.9	454.5
80°	66.2	120.6	211.1	345.1	390.8
82.5°	33.9	80.9	163.8	289.5	330.4
85°	14.7	51.2	123.8	240.2	275.7
87.5°	4.2	29.1	91.2	194.1	224.2
90°	0.3	15.4	64.9	152.2	179.4
92.5°	0.3	7.4	45.7	115.1	135.9
95°	0.3	3.8	28.5	83.5	102.0
97.5°	0.3	2.2	17.3	59.2	74.8
100°	0.3	1.9	10.2	39.3	53.4
102.5°	0.3	2.2	7.0	24.9	34.9
105°	0.3	2.2	5.8	16.3	23.0
107.5°	0.6	2.2	5.1	12.2	16.0
110°	0.3	1.9	5.4	9.3	12.5

TEST NUMBER: P518016

CATALOG NUMBER: HVL8-4-LD4-1HI-35-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.6	1.6	5.1	7.7	9.3
115°	0.3	1.3	4.5	7.4	7.7
117.5°	0.6	1.0	3.5	7.4	7.7
120°	0.6	0.6	2.9	7.0	8.0
122.5°	0.6	0.6	2.2	6.4	7.7
125°	0.3	0.6	1.9	4.8	6.7
127.5°	0.6	0.6	1.6	3.8	5.1
130°	0.6	0.6	1.3	2.9	3.8
132.5°	0.6	0.6	1.0	2.2	2.9
135°	0.6	0.6	0.6	1.6	2.2
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)