

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518032

Luminaire Tested: HVL8-4-LD4-1LO-35-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518032
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-1LO-35-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2853.0 lumens
Efficiency: N/A
Efficacy: 124.0 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct

Input Watts (W): 23
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518032
CATALOG NUMBER: HVL8-4-LD4-1LO-35-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518032

CATALOG NUMBER: HVL8-4-LD4-1LO-35-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3823	3823	3823
5°	3814	3766	3804
10°	3764	3816	3828
15°	3695	3713	3553
20°	3612	3478	3397
25°	3524	3327	3419
30°	3390	3206	3457
35°	3295	3091	3395
40°	3192	3005	3416
45°	3082	2893	3355
50°	2948	2776	3329
55°	2751	2651	3327
60°	2600	2480	3185
65°	2299	2275	3084
70°	1875	2010	2765
75°	1339	1688	2524
80°	750	1364	2266
85°	279	1030	1996

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 3355 cd/sqm

TEST NUMBER: P518032

CATALOG NUMBER: HVL8-4-LD4-1LO-35-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	91.0	3.2
10°-20°	259.2	9.1
20°-30°	385.7	13.5
30°-40°	463.6	16.2
40°-50°	487.9	17.1
50°-60°	452.7	15.9
60°-70°	358.0	12.5
70°-80°	218.7	7.7
80°-90°	95.3	3.3
90°-100°	29.7	1.0
100°-110°	6.7	0.2
110°-120°	2.7	0.1
120°-130°	1.5	0.1
130°-140°	0.4	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	735.9	25.8
0°-40°	1199.5	42.0
0°-60°	2140.2	75.0
0°-90°	2812.1	98.6
90°-120°	39.0	1.4
90°-150°	40.9	1.4
90°-180°	41.0	1.4
0°-180°	2853.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	947	947	947	947	947	
5°	945	943	946	957	959	90
15°	894	928	938	906	907	252
25°	807	858	819	843	857	370
35°	688	707	718	783	810	430
45°	562	565	611	708	735	433
55°	414	421	488	594	642	372
65°	262	270	344	455	496	260
75°	99	131	192	294	313	108
85°	9	31	75	145	166	14
90°	0	9	39	92	108	0
95°	0	2	17	50	62	0
105°	0	1	4	10	14	0
115°	0	1	3	4	5	0
125°	0	0	1	3	4	0
135°	0	0	0	1	1	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518032

CATALOG NUMBER: HVL8-4-LD4-1LO-35-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	947.0	947.0	947.0	947.0	947.0
2.5°	948.2	945.7	940.5	945.5	946.8
5°	944.7	942.8	946.1	956.7	959.4
7.5°	936.8	944.1	952.8	972.1	978.3
10°	925.0	938.9	965.0	981.4	975.0
12.5°	910.8	934.3	969.2	937.2	922.3
15°	894.2	928.5	937.6	906.5	907.1
17.5°	874.7	923.7	895.7	895.0	889.4
20°	853.7	907.5	870.5	868.9	862.9
22.5°	831.1	886.1	848.1	845.0	861.2
25°	806.6	858.1	818.9	843.4	857.1
27.5°	775.9	821.5	794.6	829.4	846.5
30°	744.9	783.6	769.7	818.2	848.7
32.5°	715.7	744.1	749.3	813.9	818.9
35°	688.1	707.2	717.9	783.1	809.7
37.5°	657.9	663.1	691.2	770.1	795.8
40°	627.0	623.7	668.9	748.9	784.4
42.5°	593.8	592.6	645.1	738.3	756.1
45°	562.4	564.9	611.4	708.2	734.6
47.5°	530.1	533.4	579.3	675.2	708.0
50°	492.7	497.0	550.8	645.9	688.1
52.5°	452.2	460.3	523.0	618.1	660.7
55°	414.2	420.9	487.7	594.4	641.6
57.5°	379.5	383.5	451.2	564.5	600.2
60°	345.3	346.3	416.9	531.3	565.4
62.5°	306.2	307.9	381.6	492.1	537.9
65°	262.2	270.5	343.6	454.7	496.0
67.5°	221.1	235.6	304.8	420.4	442.0
70°	177.1	201.6	266.8	380.1	395.3
72.5°	136.8	165.5	227.8	334.9	356.3
75°	99.2	131.4	191.6	294.4	312.9
77.5°	66.8	99.5	157.6	249.6	274.1
80°	39.9	72.7	127.3	208.2	235.7
82.5°	20.4	48.8	98.8	174.6	199.3
85°	8.9	30.9	74.7	144.9	166.3
87.5°	2.5	17.6	55.0	117.1	135.2
90°	0.2	9.3	39.2	91.8	108.2
92.5°	0.2	4.4	27.6	69.5	82.0
95°	0.2	2.3	17.2	50.4	61.5
97.5°	0.2	1.4	10.4	35.7	45.1
100°	0.2	1.2	6.2	23.7	32.2
102.5°	0.2	1.4	4.2	15.0	21.0
105°	0.2	1.4	3.5	9.8	13.9
107.5°	0.4	1.4	3.1	7.3	9.6
110°	0.2	1.2	3.3	5.6	7.5

TEST NUMBER: P518032

CATALOG NUMBER: HVL8-4-LD4-1LO-35-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.4	1.0	3.1	4.6	5.6
115°	0.2	0.8	2.7	4.4	4.6
117.5°	0.4	0.6	2.1	4.4	4.6
120°	0.4	0.4	1.7	4.2	4.8
122.5°	0.4	0.4	1.4	3.9	4.6
125°	0.2	0.4	1.2	2.9	4.1
127.5°	0.4	0.4	1.0	2.3	3.1
130°	0.4	0.4	0.8	1.7	2.3
132.5°	0.4	0.4	0.6	1.4	1.7
135°	0.4	0.4	0.4	1.0	1.4
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)