

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518040

Luminaire Tested: HVL8-4-LD4-1LO-50-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518040
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-1LO-50-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2931.0 lumens
Efficiency: N/A
Efficacy: 127.4 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 23
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518040

CATALOG NUMBER: HVL8-4-LD4-1LO-50-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518040

CATALOG NUMBER: HVL8-4-LD4-1LO-50-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	3927	3927	3927
5°	3918	3868	3908
10°	3867	3921	3932
15°	3796	3814	3650
20°	3711	3573	3490
25°	3620	3418	3512
30°	3483	3294	3551
35°	3385	3175	3488
40°	3279	3086	3510
45°	3166	2972	3446
50°	3028	2852	3420
55°	2826	2723	3418
60°	2671	2547	3272
65°	2361	2337	3168
70°	1926	2065	2841
75°	1375	1734	2594
80°	771	1401	2328
85°	285	1058	2050

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 3446 cd/sqm

TEST NUMBER: P518040

CATALOG NUMBER: HVL8-4-LD4-1LO-50-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	93.5	3.2
10°-20°	266.3	9.1
20°-30°	396.2	13.5
30°-40°	476.3	16.2
40°-50°	501.3	17.1
50°-60°	465.1	15.9
60°-70°	367.8	12.5
70°-80°	224.7	7.7
80°-90°	97.9	3.3
90°-100°	30.5	1.0
100°-110°	6.9	0.2
110°-120°	2.8	0.1
120°-130°	1.6	0.1
130°-140°	0.4	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	756.0	25.8
0°-40°	1232.3	42.0
0°-60°	2198.7	75.0
0°-90°	2889.0	98.6
90°-120°	40.1	1.4
90°-150°	42.1	1.4
90°-180°	42.0	1.4
0°-180°	2931.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	973	973	973	973	973	
5°	971	969	972	983	986	92
15°	919	954	963	931	932	259
25°	829	882	841	866	881	380
35°	707	727	738	804	832	442
45°	578	580	628	728	755	445
55°	426	432	501	611	659	382
65°	269	278	353	467	510	267
75°	102	135	197	302	322	111
85°	9	32	77	149	171	14
90°	0	10	40	94	111	0
95°	0	2	18	52	63	0
105°	0	1	4	10	14	0
115°	0	1	3	5	5	0
125°	0	0	1	3	4	0
135°	0	0	0	1	1	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518040

CATALOG NUMBER: HVL8-4-LD4-1LO-50-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	972.9	972.9	972.9	972.9	972.9
2.5°	974.1	971.5	966.2	971.3	972.7
5°	970.6	968.6	971.9	982.8	985.6
7.5°	962.4	970.0	978.9	998.7	1005.0
10°	950.3	964.6	991.4	1008.2	1001.7
12.5°	935.7	959.9	995.7	962.8	947.6
15°	918.6	953.9	963.2	931.3	931.9
17.5°	898.6	949.0	920.2	919.4	913.7
20°	877.0	932.3	894.2	892.7	886.5
22.5°	853.8	910.3	871.3	868.1	884.7
25°	828.6	881.6	841.3	866.5	880.6
27.5°	797.1	843.9	816.4	852.0	869.7
30°	765.2	805.1	790.8	840.5	871.9
32.5°	735.3	764.4	769.8	836.2	841.3
35°	707.0	726.6	737.5	804.5	831.8
37.5°	675.8	681.2	710.1	791.2	817.5
40°	644.1	640.8	687.1	769.4	805.9
42.5°	610.0	608.9	662.8	758.5	776.7
45°	577.7	580.3	628.1	727.6	754.7
47.5°	544.6	548.0	595.2	693.7	727.4
50°	506.2	510.5	565.8	663.6	707.0
52.5°	464.6	472.9	537.3	635.0	678.8
55°	425.5	432.5	501.0	610.6	659.2
57.5°	389.8	394.0	463.6	579.9	616.6
60°	354.8	355.8	428.3	545.8	580.9
62.5°	314.5	316.3	392.0	505.6	552.6
65°	269.3	277.9	353.0	467.1	509.6
67.5°	227.1	242.0	313.1	431.9	454.1
70°	181.9	207.1	274.1	390.4	406.1
72.5°	140.5	170.1	234.1	344.1	366.1
75°	101.9	135.0	196.8	302.4	321.5
77.5°	68.6	102.3	161.9	256.5	281.6
80°	41.0	74.7	130.8	213.9	242.2
82.5°	21.0	50.1	101.5	179.4	204.7
85°	9.1	31.7	76.7	148.8	170.8
87.5°	2.6	18.0	56.5	120.3	138.9
90°	0.2	9.5	40.2	94.3	111.2
92.5°	0.2	4.6	28.3	71.3	84.2
95°	0.2	2.4	17.6	51.7	63.2
97.5°	0.2	1.4	10.7	36.7	46.4
100°	0.2	1.2	6.3	24.4	33.1
102.5°	0.2	1.4	4.4	15.5	21.6
105°	0.2	1.4	3.6	10.1	14.3
107.5°	0.4	1.4	3.2	7.5	9.9
110°	0.2	1.2	3.4	5.7	7.7

TEST NUMBER: P518040

CATALOG NUMBER: HVL8-4-LD4-1LO-50-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.4	1.0	3.2	4.8	5.7
115°	0.2	0.8	2.8	4.6	4.8
117.5°	0.4	0.6	2.2	4.6	4.8
120°	0.4	0.4	1.8	4.4	5.0
122.5°	0.4	0.4	1.4	4.0	4.8
125°	0.2	0.4	1.2	3.0	4.2
127.5°	0.4	0.4	1.0	2.4	3.2
130°	0.4	0.4	0.8	1.8	2.4
132.5°	0.4	0.4	0.6	1.4	1.8
135°	0.4	0.4	0.4	1.0	1.4
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)