

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518044

Luminaire Tested: HVL8-4-LD4-1STD-30-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518044
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-1STD-30-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3502.0 lumens
Efficiency: N/A
Efficacy: 107.4 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 32.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518044

CATALOG NUMBER: HVL8-4-LD4-1STD-30-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518044

CATALOG NUMBER: HVL8-4-LD4-1STD-30-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4692	4692	4692
5°	4681	4622	4669
10°	4620	4685	4698
15°	4536	4558	4361
20°	4434	4269	4170
25°	4326	4084	4196
30°	4161	3935	4243
35°	4044	3794	4168
40°	3918	3688	4193
45°	3783	3551	4118
50°	3618	3408	4087
55°	3377	3254	4084
60°	3192	3044	3910
65°	2821	2792	3785
70°	2302	2467	3394
75°	1643	2072	3099
80°	921	1674	2782
85°	342	1263	2450

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 4118 cd/sqm

TEST NUMBER: P518044

CATALOG NUMBER: HVL8-4-LD4-1STD-30-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	111.7	3.2
10°-20°	318.2	9.1
20°-30°	473.4	13.5
30°-40°	569.0	16.2
40°-50°	598.9	17.1
50°-60°	555.8	15.9
60°-70°	439.4	12.5
70°-80°	268.4	7.7
80°-90°	116.9	3.3
90°-100°	36.4	1.0
100°-110°	8.2	0.2
110°-120°	3.3	0.1
120°-130°	1.9	0.1
130°-140°	0.5	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	903.3	25.8
0°-40°	1472.3	42.0
0°-60°	2627.0	75.0
0°-90°	3451.8	98.6
90°-120°	47.9	1.4
90°-150°	50.2	1.4
90°-180°	50.0	1.4
0°-180°	3502.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1162	1162	1162	1162	1162	
5°	1160	1157	1161	1174	1178	110
15°	1098	1140	1151	1113	1114	309
25°	990	1053	1005	1035	1052	455
35°	845	868	881	961	994	528
45°	690	693	750	869	902	532
55°	508	517	599	730	788	457
65°	322	332	422	558	609	319
75°	122	161	235	361	384	133
85°	11	38	92	178	204	17
90°	0	11	48	113	133	1
95°	0	3	21	62	76	0
105°	0	2	4	12	17	0
115°	0	1	3	5	6	0
125°	0	0	1	4	5	0
135°	0	0	0	1	2	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518044

CATALOG NUMBER: HVL8-4-LD4-1STD-30-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1162.5	1162.5	1162.5	1162.5	1162.5
2.5°	1163.9	1160.8	1154.4	1160.6	1162.2
5°	1159.6	1157.3	1161.3	1174.3	1177.6
7.5°	1149.9	1158.9	1169.6	1193.3	1200.8
10°	1135.5	1152.5	1184.5	1204.6	1196.8
12.5°	1118.0	1146.8	1189.7	1150.4	1132.2
15°	1097.6	1139.7	1150.9	1112.7	1113.5
17.5°	1073.7	1133.8	1099.5	1098.5	1091.7
20°	1047.9	1113.9	1068.5	1066.6	1059.2
22.5°	1020.2	1087.6	1041.0	1037.2	1057.1
25°	990.1	1053.3	1005.2	1035.3	1052.1
27.5°	952.4	1008.3	975.4	1018.0	1039.1
30°	914.3	961.9	944.9	1004.3	1041.7
32.5°	878.5	913.4	919.7	999.1	1005.2
35°	844.7	868.1	881.1	961.2	993.9
37.5°	807.5	813.9	848.5	945.3	976.8
40°	769.6	765.6	821.0	919.3	962.8
42.5°	728.9	727.5	791.9	906.3	928.0
45°	690.3	693.4	750.4	869.3	901.8
47.5°	650.7	654.8	711.1	828.8	869.1
50°	604.8	610.0	676.1	792.8	844.7
52.5°	555.1	565.0	642.0	758.7	811.1
55°	508.4	516.7	598.6	729.6	787.6
57.5°	465.8	470.8	553.9	692.9	736.7
60°	423.9	425.1	511.7	652.2	694.1
62.5°	375.8	377.9	468.4	604.1	660.2
65°	321.8	332.0	421.7	558.1	608.8
67.5°	271.4	289.1	374.2	516.0	542.5
70°	217.4	247.5	327.5	466.5	485.2
72.5°	167.9	203.2	279.7	411.1	437.4
75°	121.7	161.3	235.1	361.4	384.1
77.5°	81.9	122.2	193.5	306.4	336.5
80°	49.0	89.3	156.3	255.5	289.4
82.5°	25.1	59.9	121.2	214.3	244.6
85°	10.9	37.9	91.6	177.8	204.1
87.5°	3.1	21.5	67.5	143.7	166.0
90°	0.2	11.4	48.1	112.7	132.8
92.5°	0.2	5.4	33.9	85.2	100.6
95°	0.2	2.8	21.1	61.8	75.5
97.5°	0.2	1.7	12.8	43.8	55.4
100°	0.2	1.4	7.6	29.1	39.5
102.5°	0.2	1.7	5.2	18.5	25.8
105°	0.2	1.7	4.3	12.1	17.0
107.5°	0.5	1.7	3.8	9.0	11.8
110°	0.2	1.4	4.0	6.9	9.2

TEST NUMBER: P518044

CATALOG NUMBER: HVL8-4-LD4-1STD-30-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	1.2	3.8	5.7	6.9
115°	0.2	0.9	3.3	5.4	5.7
117.5°	0.5	0.7	2.6	5.4	5.7
120°	0.5	0.5	2.1	5.2	5.9
122.5°	0.5	0.5	1.7	4.7	5.7
125°	0.2	0.5	1.4	3.6	5.0
127.5°	0.5	0.5	1.2	2.8	3.8
130°	0.5	0.5	0.9	2.1	2.8
132.5°	0.5	0.5	0.7	1.7	2.1
135°	0.5	0.5	0.5	1.2	1.7
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)