

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518048

Luminaire Tested: HVL8-4-LD4-1STD-35-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518048
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-1STD-35-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3675.0 lumens
Efficiency: N/A
Efficacy: 112.7 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 32.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518048

CATALOG NUMBER: HVL8-4-LD4-1STD-35-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518048

CATALOG NUMBER: HVL8-4-LD4-1STD-35-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4924	4924	4924
5°	4913	4850	4900
10°	4848	4916	4930
15°	4760	4782	4576
20°	4653	4480	4377
25°	4539	4286	4404
30°	4367	4129	4453
35°	4244	3981	4374
40°	4112	3870	4401
45°	3970	3727	4321
50°	3797	3576	4288
55°	3544	3415	4286
60°	3349	3194	4103
65°	2961	2931	3972
70°	2415	2589	3562
75°	1724	2175	3252
80°	966	1757	2919
85°	358	1327	2571

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 4321 cd/sqm

TEST NUMBER: P518048

CATALOG NUMBER: HVL8-4-LD4-1STD-35-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	117.2	3.2
10°-20°	333.9	9.1
20°-30°	496.8	13.5
30°-40°	597.1	16.2
40°-50°	628.5	17.1
50°-60°	583.2	15.9
60°-70°	461.1	12.5
70°-80°	281.7	7.7
80°-90°	122.7	3.3
90°-100°	38.2	1.0
100°-110°	8.6	0.2
110°-120°	3.4	0.1
120°-130°	1.9	0.1
130°-140°	0.5	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	947.9	25.8
0°-40°	1545.1	42.0
0°-60°	2756.8	75.0
0°-90°	3622.3	98.6
90°-120°	50.2	1.4
90°-150°	52.7	1.4
90°-180°	53.0	1.4
0°-180°	3675.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1220	1220	1220	1220	1220	
5°	1217	1214	1219	1232	1236	115
15°	1152	1196	1208	1168	1168	324
25°	1039	1105	1055	1086	1104	477
35°	886	911	925	1009	1043	554
45°	724	728	788	912	946	558
55°	534	542	628	766	826	479
65°	338	348	443	586	639	334
75°	128	169	247	379	403	139
85°	11	40	96	187	214	18
90°	0	12	50	118	139	1
95°	0	3	22	65	79	0
105°	0	2	4	13	18	0
115°	0	1	4	6	6	0
125°	0	0	2	4	5	0
135°	0	0	0	1	2	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518048

CATALOG NUMBER: HVL8-4-LD4-1STD-35-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1219.9	1219.9	1219.9	1219.9	1219.9
2.5°	1221.4	1218.2	1211.5	1217.9	1219.7
5°	1216.9	1214.4	1218.7	1232.3	1235.8
7.5°	1206.7	1216.2	1227.4	1252.2	1260.2
10°	1191.6	1209.5	1243.0	1264.1	1255.9
12.5°	1173.2	1203.5	1248.5	1207.2	1188.1
15°	1151.8	1196.0	1207.7	1167.7	1168.5
17.5°	1126.7	1189.8	1153.8	1152.8	1145.6
20°	1099.6	1169.0	1121.2	1119.3	1111.6
22.5°	1070.5	1141.4	1092.4	1088.4	1109.3
25°	1039.0	1105.3	1054.9	1086.5	1104.1
27.5°	999.5	1058.1	1023.6	1068.3	1090.4
30°	959.5	1009.4	991.5	1053.9	1093.2
32.5°	921.9	958.5	965.2	1048.4	1054.9
35°	886.4	911.0	924.7	1008.7	1043.0
37.5°	847.4	854.1	890.4	992.0	1025.1
40°	807.6	803.4	861.6	964.7	1010.4
42.5°	764.9	763.4	831.0	951.0	973.9
45°	724.4	727.6	787.5	912.3	946.3
47.5°	682.9	687.1	746.3	869.8	912.0
50°	634.7	640.1	709.5	832.0	886.4
52.5°	582.5	592.9	673.7	796.2	851.1
55°	533.5	542.2	628.2	765.6	826.5
57.5°	488.8	494.0	581.2	727.1	773.1
60°	444.8	446.1	537.0	684.4	728.4
62.5°	394.4	396.6	491.5	633.9	692.8
65°	337.7	348.4	442.6	585.7	638.9
67.5°	284.8	303.4	392.6	541.5	569.3
70°	228.1	259.7	343.7	489.6	509.2
72.5°	176.2	213.2	293.5	431.4	459.0
75°	127.7	169.2	246.8	379.2	403.1
77.5°	86.0	128.2	203.0	321.6	353.1
80°	51.4	93.7	164.0	268.1	303.7
82.5°	26.3	62.9	127.2	224.9	256.7
85°	11.4	39.8	96.2	186.6	214.2
87.5°	3.2	22.6	70.8	150.8	174.2
90°	0.2	11.9	50.4	118.3	139.4
92.5°	0.2	5.7	35.5	89.5	105.6
95°	0.2	3.0	22.1	64.9	79.3
97.5°	0.2	1.7	13.4	46.0	58.1
100°	0.2	1.5	8.0	30.6	41.5
102.5°	0.2	1.7	5.5	19.4	27.1
105°	0.2	1.7	4.5	12.7	17.9
107.5°	0.5	1.7	4.0	9.4	12.4
110°	0.2	1.5	4.2	7.2	9.7

TEST NUMBER: P518048

CATALOG NUMBER: HVL8-4-LD4-1STD-35-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	1.2	4.0	6.0	7.2
115°	0.2	1.0	3.5	5.7	6.0
117.5°	0.5	0.7	2.7	5.7	6.0
120°	0.5	0.5	2.2	5.5	6.2
122.5°	0.5	0.5	1.7	5.0	6.0
125°	0.2	0.5	1.5	3.7	5.2
127.5°	0.5	0.5	1.2	3.0	4.0
130°	0.5	0.5	1.0	2.2	3.0
132.5°	0.5	0.5	0.7	1.7	2.2
135°	0.5	0.5	0.5	1.2	1.7
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)