

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518052

Luminaire Tested: HVL8-4-LD4-1STD-40-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518052
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-1STD-40-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3712.0 lumens
Efficiency: N/A
Efficacy: 113.9 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 32.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518052

CATALOG NUMBER: HVL8-4-LD4-1STD-40-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518052

CATALOG NUMBER: HVL8-4-LD4-1STD-40-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4974	4974	4974
5°	4962	4899	4949
10°	4897	4965	4980
15°	4808	4831	4622
20°	4700	4525	4420
25°	4585	4329	4448
30°	4411	4171	4497
35°	4287	4022	4418
40°	4153	3909	4445
45°	4010	3764	4365
50°	3835	3612	4331
55°	3579	3449	4329
60°	3383	3226	4144
65°	2991	2960	4012
70°	2440	2615	3598
75°	1741	2196	3284
80°	978	1775	2948
85°	361	1339	2598

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 4365 cd/sqm

TEST NUMBER: P518052

CATALOG NUMBER: HVL8-4-LD4-1STD-40-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	118.4	3.2
10°-20°	337.2	9.1
20°-30°	501.8	13.5
30°-40°	603.1	16.2
40°-50°	634.9	17.1
50°-60°	589.1	15.9
60°-70°	465.8	12.5
70°-80°	284.5	7.7
80°-90°	124.0	3.3
90°-100°	38.6	1.0
100°-110°	8.7	0.2
110°-120°	3.5	0.1
120°-130°	2.0	0.1
130°-140°	0.5	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	957.5	25.8
0°-40°	1560.6	42.0
0°-60°	2784.5	75.0
0°-90°	3658.7	98.6
90°-120°	50.8	1.4
90°-150°	53.3	1.4
90°-180°	53.0	1.4
0°-180°	3712.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1232	1232	1232	1232	1232	
5°	1229	1227	1231	1245	1248	116
15°	1163	1208	1220	1180	1180	328
25°	1050	1116	1066	1097	1115	482
35°	895	920	934	1019	1054	560
45°	732	735	795	921	956	564
55°	539	548	634	773	835	484
65°	341	352	447	592	645	338
75°	129	171	249	383	407	141
85°	12	40	97	188	216	18
90°	0	12	51	120	141	1
95°	0	3	22	66	80	0
105°	0	2	4	13	18	0
115°	0	1	4	6	6	0
125°	0	0	2	4	5	0
135°	0	0	0	1	2	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518052

CATALOG NUMBER: HVL8-4-LD4-1STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1232.2	1232.2	1232.2	1232.2	1232.2
2.5°	1233.7	1230.4	1223.6	1230.2	1231.9
5°	1229.2	1226.7	1230.9	1244.7	1248.2
7.5°	1218.9	1228.4	1239.7	1264.8	1272.8
10°	1203.6	1221.6	1255.5	1276.9	1268.6
12.5°	1185.0	1215.6	1261.0	1219.4	1200.1
15°	1163.4	1208.1	1219.9	1179.5	1180.2
17.5°	1138.1	1201.8	1165.4	1164.4	1157.1
20°	1110.7	1180.7	1132.5	1130.5	1122.7
22.5°	1081.3	1152.9	1103.4	1099.4	1120.5
25°	1049.5	1116.5	1065.5	1097.4	1115.2
27.5°	1009.5	1068.8	1033.9	1079.1	1101.4
30°	969.1	1019.6	1001.5	1064.5	1104.2
32.5°	931.2	968.1	974.9	1059.0	1065.5
35°	895.3	920.2	934.0	1018.8	1053.5
37.5°	855.9	862.7	899.3	1002.0	1035.4
40°	815.8	811.5	870.2	974.4	1020.6
42.5°	772.6	771.1	839.4	960.6	983.7
45°	731.7	734.9	795.4	921.4	955.8
47.5°	689.8	694.0	753.8	878.5	921.2
50°	641.1	646.6	716.6	840.4	895.3
52.5°	588.4	598.9	680.5	804.2	859.7
55°	538.9	547.7	634.5	773.3	834.8
57.5°	493.7	499.0	587.1	734.4	780.9
60°	449.3	450.6	542.4	691.3	735.7
62.5°	398.3	400.6	496.5	640.3	699.8
65°	341.1	351.9	447.0	591.6	645.3
67.5°	287.7	306.5	396.6	546.9	575.1
70°	230.4	262.3	347.1	494.5	514.3
72.5°	178.0	215.4	296.4	435.7	463.6
75°	129.0	170.9	249.2	383.0	407.1
77.5°	86.8	129.5	205.1	324.8	356.7
80°	52.0	94.6	165.7	270.8	306.7
82.5°	26.6	63.5	128.5	227.2	259.3
85°	11.5	40.2	97.1	188.5	216.4
87.5°	3.3	22.8	71.5	152.4	176.0
90°	0.3	12.0	51.0	119.5	140.8
92.5°	0.3	5.8	35.9	90.4	106.7
95°	0.3	3.0	22.3	65.5	80.1
97.5°	0.3	1.8	13.6	46.4	58.7
100°	0.3	1.5	8.0	30.9	41.9
102.5°	0.3	1.8	5.5	19.6	27.4
105°	0.3	1.8	4.5	12.8	18.1
107.5°	0.5	1.8	4.0	9.5	12.6
110°	0.3	1.5	4.3	7.3	9.8

TEST NUMBER: P518052

CATALOG NUMBER: HVL8-4-LD4-1STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	1.3	4.0	6.0	7.3
115°	0.3	1.0	3.5	5.8	6.0
117.5°	0.5	0.8	2.8	5.8	6.0
120°	0.5	0.5	2.3	5.5	6.3
122.5°	0.5	0.5	1.8	5.0	6.0
125°	0.3	0.5	1.5	3.8	5.3
127.5°	0.5	0.5	1.3	3.0	4.0
130°	0.5	0.5	1.0	2.3	3.0
132.5°	0.5	0.5	0.8	1.8	2.3
135°	0.5	0.5	0.5	1.3	1.8
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)