

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518060

Luminaire Tested: HVL8-4-LD4-2HI-30-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518060
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2HI-30-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8558.0 lumens
Efficiency: N/A
Efficacy: 99.4 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct

Input Watts (W): 86.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518060
CATALOG NUMBER: HVL8-4-LD4-2HI-30-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518060

CATALOG NUMBER: HVL8-4-LD4-2HI-30-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	11467	11467	11467
5°	11441	11295	11411
10°	11290	11448	11481
15°	11085	11137	10657
20°	10835	10433	10191
25°	10570	9981	10255
30°	10169	9617	10368
35°	9883	9271	10185
40°	9575	9012	10248
45°	9244	8678	10063
50°	8842	8328	9986
55°	8252	7952	9981
60°	7800	7438	9554
65°	6895	6824	9250
70°	5625	6028	8295
75°	4014	5063	7572
80°	2252	4091	6798
85°	834	3090	5988

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 10063 cd/sqm

TEST NUMBER: P518060

CATALOG NUMBER: HVL8-4-LD4-2HI-30-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	273.0	3.2
10°-20°	777.5	9.1
20°-30°	1156.9	13.5
30°-40°	1390.6	16.2
40°-50°	1463.6	17.1
50°-60°	1358.1	15.9
60°-70°	1073.8	12.5
70°-80°	655.9	7.7
80°-90°	285.8	3.3
90°-100°	89.0	1.0
100°-110°	20.0	0.2
110°-120°	8.0	0.1
120°-130°	4.5	0.1
130°-140°	1.2	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2207.4	25.8
0°-40°	3598.0	42.0
0°-60°	6419.7	75.0
0°-90°	8435.2	98.6
90°-120°	117.0	1.4
90°-150°	122.8	1.4
90°-180°	123.0	1.4
0°-180°	8558.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2841	2841	2841	2841	2841	
5°	2834	2828	2838	2870	2878	269
15°	2682	2785	2812	2719	2721	756
25°	2420	2574	2456	2530	2571	1111
35°	2064	2122	2153	2349	2429	1290
45°	1687	1694	1834	2124	2204	1300
55°	1242	1263	1463	1783	1925	1116
65°	786	811	1031	1364	1488	779
75°	297	394	575	883	939	325
85°	27	93	224	435	499	41
90°	1	28	118	276	325	1
95°	1	7	52	151	185	0
105°	1	4	10	30	42	1
115°	1	2	8	13	14	1
125°	1	1	4	9	12	1
135°	1	1	1	3	4	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518060

CATALOG NUMBER: HVL8-4-LD4-2HI-30-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2840.8	2840.8	2840.8	2840.8	2840.8
2.5°	2844.3	2836.7	2821.1	2836.2	2840.2
5°	2833.8	2828.1	2837.9	2869.7	2877.8
7.5°	2810.1	2832.1	2858.2	2916.0	2934.5
10°	2774.8	2816.5	2894.6	2943.8	2924.7
12.5°	2732.0	2802.6	2907.3	2811.3	2766.7
15°	2682.2	2785.2	2812.4	2719.3	2721.0
17.5°	2623.8	2770.8	2686.9	2684.5	2667.8
20°	2560.7	2722.2	2611.1	2606.4	2588.5
22.5°	2493.0	2657.9	2543.9	2534.7	2583.3
25°	2419.5	2574.0	2456.5	2530.0	2571.1
27.5°	2327.5	2464.1	2383.6	2487.8	2539.3
30°	2234.3	2350.6	2309.0	2454.2	2545.7
32.5°	2146.9	2232.0	2247.6	2441.5	2456.5
35°	2064.2	2121.5	2153.3	2348.9	2428.8
37.5°	1973.3	1989.0	2073.4	2310.1	2387.1
40°	1880.7	1870.9	2006.3	2246.5	2353.0
42.5°	1781.2	1777.7	1935.1	2214.6	2267.9
45°	1686.9	1694.4	1833.9	2124.4	2203.7
47.5°	1590.2	1600.1	1737.8	2025.4	2123.8
50°	1478.0	1490.7	1652.2	1937.5	2064.2
52.5°	1356.4	1380.8	1568.8	1854.1	1982.0
55°	1242.4	1262.7	1462.9	1782.9	1924.7
57.5°	1138.3	1150.4	1353.6	1693.2	1800.3
60°	1035.9	1038.7	1250.5	1593.7	1696.1
62.5°	918.4	923.6	1144.6	1476.2	1613.4
65°	786.4	811.3	1030.6	1364.0	1487.8
67.5°	663.2	706.6	914.3	1261.0	1325.8
70°	531.2	604.7	800.3	1140.0	1185.7
72.5°	410.3	496.5	683.4	1004.6	1068.8
75°	297.4	394.1	574.6	883.1	938.6
77.5°	200.2	298.6	472.8	748.8	822.3
80°	119.8	218.2	381.9	624.4	707.2
82.5°	61.3	146.4	296.3	523.7	597.8
85°	26.6	92.6	224.0	434.6	498.8
87.5°	7.5	52.7	164.9	351.3	405.7
90°	0.6	27.8	117.5	275.5	324.6
92.5°	0.6	13.3	82.8	208.3	245.9
95°	0.6	6.9	51.5	151.0	184.6
97.5°	0.6	4.1	31.2	107.1	135.4
100°	0.6	3.5	18.5	71.2	96.6
102.5°	0.6	4.1	12.7	45.1	63.1
105°	0.6	4.1	10.4	29.5	41.7
107.5°	1.2	4.1	9.3	22.0	28.9
110°	0.6	3.5	9.8	16.8	22.6

TEST NUMBER: P518060

CATALOG NUMBER: HVL8-4-LD4-2HI-30-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.2	2.9	9.3	13.9	16.8
115°	0.6	2.3	8.1	13.3	13.9
117.5°	1.2	1.7	6.4	13.3	13.9
120°	1.2	1.2	5.2	12.7	14.5
122.5°	1.2	1.2	4.1	11.6	13.9
125°	0.6	1.2	3.5	8.7	12.2
127.5°	1.2	1.2	2.9	6.9	9.3
130°	1.2	1.2	2.3	5.2	6.9
132.5°	1.2	1.2	1.7	4.1	5.2
135°	1.2	1.2	1.2	2.9	4.1
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)