

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518068

Luminaire Tested: HVL8-4-LD4-2HI-40-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518068
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2HI-40-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 9072.0 lumens
Efficiency: N/A
Efficacy: 105.4 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 86.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518068

CATALOG NUMBER: HVL8-4-LD4-2HI-40-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518068

CATALOG NUMBER: HVL8-4-LD4-2HI-40-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	12155	12155	12155
5°	12128	11973	12096
10°	11968	12136	12171
15°	11751	11806	11297
20°	11486	11059	10803
25°	11205	10580	10871
30°	10780	10194	10991
35°	10477	9828	10796
40°	10150	9553	10864
45°	9799	9200	10667
50°	9373	8828	10586
55°	8748	8430	10580
60°	8268	7885	10128
65°	7309	7234	9806
70°	5963	6391	8794
75°	4255	5368	8027
80°	2388	4338	7206
85°	885	3274	6348

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 10667 cd/sqm

TEST NUMBER: P518068

CATALOG NUMBER: HVL8-4-LD4-2HI-40-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	289.4	3.2
10°-20°	824.2	9.1
20°-30°	1226.4	13.5
30°-40°	1474.1	16.2
40°-50°	1551.6	17.1
50°-60°	1439.7	15.9
60°-70°	1138.3	12.5
70°-80°	695.3	7.7
80°-90°	302.9	3.3
90°-100°	94.3	1.0
100°-110°	21.2	0.2
110°-120°	8.5	0.1
120°-130°	4.8	0.1
130°-140°	1.3	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2340.0	25.8
0°-40°	3814.1	42.0
0°-60°	6805.3	75.0
0°-90°	8941.9	98.6
90°-120°	124.0	1.4
90°-150°	130.1	1.4
90°-180°	130.0	1.4
0°-180°	9072.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3011	3011	3011	3011	3011	
5°	3004	2998	3008	3042	3051	285
15°	2843	2952	2981	2883	2884	801
25°	2565	2729	2604	2682	2726	1177
35°	2188	2249	2283	2490	2575	1368
45°	1788	1796	1944	2252	2336	1378
55°	1317	1338	1551	1890	2040	1183
65°	834	860	1092	1446	1577	826
75°	315	418	609	936	995	344
85°	28	98	237	461	529	44
90°	1	29	124	292	344	1
95°	1	7	55	160	196	0
105°	1	4	11	31	44	1
115°	1	2	9	14	15	1
125°	1	1	4	9	13	1
135°	1	1	1	3	4	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518068

CATALOG NUMBER: HVL8-4-LD4-2HI-40-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3011.4	3011.4	3011.4	3011.4	3011.4
2.5°	3015.1	3007.1	2990.6	3006.5	3010.8
5°	3004.0	2997.9	3008.3	3042.1	3050.7
7.5°	2978.9	3002.2	3029.8	3091.2	3110.8
10°	2941.5	2985.6	3068.5	3120.6	3100.4
12.5°	2896.1	2970.9	3082.0	2980.1	2932.9
15°	2843.3	2952.5	2981.4	2882.6	2884.4
17.5°	2781.4	2937.2	2848.2	2845.8	2828.0
20°	2714.5	2885.7	2767.9	2763.0	2743.9
22.5°	2642.7	2817.6	2696.7	2686.9	2738.4
25°	2564.8	2728.6	2604.1	2682.0	2725.5
27.5°	2467.3	2612.1	2526.8	2637.2	2691.8
30°	2368.5	2491.8	2447.7	2601.6	2698.6
32.5°	2275.9	2366.1	2382.6	2588.1	2604.1
35°	2188.2	2248.9	2282.6	2490.0	2574.6
37.5°	2091.9	2108.4	2198.0	2448.9	2530.5
40°	1993.7	1983.3	2126.8	2381.4	2494.3
42.5°	1888.2	1884.5	2051.4	2347.7	2404.1
45°	1788.2	1796.2	1944.0	2252.0	2336.0
47.5°	1685.8	1696.2	1842.2	2147.1	2251.3
50°	1566.7	1580.2	1751.4	2053.8	2188.2
52.5°	1437.9	1463.7	1663.1	1965.5	2101.1
55°	1317.1	1338.5	1550.8	1890.0	2040.3
57.5°	1206.6	1219.5	1434.9	1794.9	1908.4
60°	1098.1	1101.1	1325.7	1689.4	1798.0
62.5°	973.5	979.1	1213.4	1564.9	1710.3
65°	833.7	860.1	1092.5	1445.9	1577.2
67.5°	703.0	749.0	969.2	1336.7	1405.4
70°	563.1	641.1	848.4	1208.5	1257.0
72.5°	434.9	526.3	724.5	1064.9	1133.0
75°	315.3	417.8	609.2	936.1	995.0
77.5°	212.3	316.5	501.2	793.8	871.7
80°	127.0	231.3	404.9	661.9	749.6
82.5°	65.0	155.2	314.1	555.2	633.7
85°	28.2	98.2	237.4	460.7	528.8
87.5°	8.0	55.8	174.8	372.4	430.0
90°	0.6	29.4	124.5	292.0	344.1
92.5°	0.6	14.1	87.7	220.8	260.7
95°	0.6	7.4	54.6	160.1	195.7
97.5°	0.6	4.3	33.1	113.5	143.5
100°	0.6	3.7	19.6	75.5	102.4
102.5°	0.6	4.3	13.5	47.8	66.9
105°	0.6	4.3	11.0	31.3	44.2
107.5°	1.2	4.3	9.8	23.3	30.7
110°	0.6	3.7	10.4	17.8	23.9

TEST NUMBER: P518068

CATALOG NUMBER: HVL8-4-LD4-2HI-40-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.2	3.1	9.8	14.7	17.8
115°	0.6	2.5	8.6	14.1	14.7
117.5°	1.2	1.8	6.7	14.1	14.7
120°	1.2	1.2	5.5	13.5	15.3
122.5°	1.2	1.2	4.3	12.3	14.7
125°	0.6	1.2	3.7	9.2	12.9
127.5°	1.2	1.2	3.1	7.4	9.8
130°	1.2	1.2	2.5	5.5	7.4
132.5°	1.2	1.2	1.8	4.3	5.5
135°	1.2	1.2	1.2	3.1	4.3
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)