

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518091

Luminaire Tested: HVL8-4-LD4-2STD-30-UNV-C-EDD-90

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518091
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2STD-30-UNV-C-EDD-90
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 90 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6649.9 lumens
Efficiency: N/A
Efficacy: 101.7 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 65.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518091

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-C-EDD-90

Luminous Intensity Polar Plot



TEST NUMBER: P518091

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-C-EDD-90

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		0
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		99
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		81
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		67
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		56
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		47
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		41
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		36
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		32
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		28
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		25
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	8910	8910	8910
5°	8890	8777	8867
10°	8773	8896	8921
15°	8613	8654	8281
20°	8420	8107	7919
25°	8214	7756	7969
30°	7902	7473	8057
35°	7680	7204	7914
40°	7440	7003	7963
45°	7183	6743	7819
50°	6871	6471	7760
55°	6412	6180	7756
60°	6060	5780	7425
65°	5358	5303	7188
70°	4371	4685	6446
75°	3119	3935	5884
80°	1750	3180	5282
85°	649	2400	4653

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 7819 cd/sqm

TEST NUMBER: P518091

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-C-EDD-90

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	212.2	3.2
10°-20°	604.2	9.1
20°-30°	899.0	13.5
30°-40°	1080.5	16.2
40°-50°	1137.3	17.1
50°-60°	1055.3	15.9
60°-70°	834.4	12.5
70°-80°	509.7	7.7
80°-90°	222.1	3.3
90°-100°	69.1	1.0
100°-110°	15.5	0.2
110°-120°	6.2	0.1
120°-130°	3.5	0.1
130°-140°	0.9	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1715.3	25.8
0°-40°	2795.8	42.0
0°-60°	4988.5	75.0
0°-90°	6554.6	98.6
90°-120°	90.9	1.4
90°-150°	95.3	1.4
90°-180°	95.0	1.4
0°-180°	6649.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2207	2207	2207	2207	2207	
5°	2202	2198	2205	2230	2236	209
15°	2084	2164	2185	2113	2114	587
25°	1880	2000	1909	1966	1998	863
35°	1604	1648	1673	1825	1887	1002
45°	1311	1317	1425	1651	1712	1010
55°	965	981	1137	1385	1496	867
65°	611	630	801	1060	1156	605
75°	231	306	446	686	729	252
85°	21	72	174	338	388	32
90°	0	22	91	214	252	1
95°	0	5	40	117	143	0
105°	0	3	8	23	32	1
115°	0	2	6	10	11	1
125°	0	1	3	7	9	1
135°	1	1	1	2	3	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518091

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-C-EDD-90

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2207.4	2207.4	2207.4	2207.4	2207.4
2.5°	2210.1	2204.3	2192.1	2203.8	2207.0
5°	2202.0	2197.5	2205.2	2229.9	2236.2
7.5°	2183.6	2200.7	2220.9	2265.9	2280.3
10°	2156.2	2188.6	2249.3	2287.5	2272.6
12.5°	2122.9	2177.8	2259.2	2184.5	2149.9
15°	2084.2	2164.3	2185.4	2113.0	2114.4
17.5°	2038.8	2153.0	2087.8	2086.0	2073.0
20°	1989.8	2115.3	2028.9	2025.3	2011.4
22.5°	1937.2	2065.3	1976.8	1969.6	2007.3
25°	1880.1	2000.1	1908.9	1966.0	1997.9
27.5°	1808.6	1914.7	1852.2	1933.1	1973.2
30°	1736.2	1826.6	1794.2	1907.1	1978.1
32.5°	1668.3	1734.4	1746.5	1897.2	1908.9
35°	1604.0	1648.5	1673.2	1825.2	1887.3
37.5°	1533.4	1545.5	1611.2	1795.1	1854.9
40°	1461.4	1453.8	1559.0	1745.6	1828.4
42.5°	1384.1	1381.4	1503.7	1720.9	1762.3
45°	1310.8	1316.6	1425.0	1650.7	1712.3
47.5°	1235.7	1243.3	1350.4	1573.9	1650.3
50°	1148.5	1158.4	1283.8	1505.5	1604.0
52.5°	1054.0	1072.9	1219.1	1440.7	1540.1
55°	965.4	981.2	1136.8	1385.4	1495.6
57.5°	884.5	893.9	1051.8	1315.7	1398.9
60°	804.9	807.2	971.7	1238.4	1318.0
62.5°	713.6	717.7	889.5	1147.1	1253.7
65°	611.1	630.4	800.9	1059.9	1156.1
67.5°	515.3	549.0	710.5	979.8	1030.2
70°	412.8	469.9	621.9	885.9	921.4
72.5°	318.8	385.8	531.1	780.6	830.5
75°	231.1	306.2	446.5	686.2	729.4
77.5°	155.6	232.0	367.4	581.9	639.0
80°	93.1	169.5	296.8	485.2	549.5
82.5°	47.7	113.8	230.2	407.0	464.5
85°	20.7	71.9	174.0	337.7	387.6
87.5°	5.8	40.9	128.2	273.0	315.2
90°	0.4	21.6	91.3	214.0	252.3
92.5°	0.4	10.3	64.3	161.9	191.1
95°	0.4	5.4	40.0	117.4	143.4
97.5°	0.4	3.1	24.3	83.2	105.2
100°	0.4	2.7	14.4	55.3	75.1
102.5°	0.4	3.1	9.9	35.1	49.0
105°	0.4	3.1	8.1	22.9	32.4
107.5°	0.9	3.1	7.2	17.1	22.5
110°	0.4	2.7	7.6	13.0	17.5

TEST NUMBER: P518091

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-C-EDD-90

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.9	2.2	7.2	10.8	13.0
115°	0.4	1.8	6.3	10.3	10.8
117.5°	0.9	1.3	4.9	10.3	10.8
120°	0.9	0.9	4.0	9.9	11.2
122.5°	0.9	0.9	3.1	9.0	10.8
125°	0.4	0.9	2.7	6.7	9.4
127.5°	0.9	0.9	2.2	5.4	7.2
130°	0.9	0.9	1.8	4.0	5.4
132.5°	0.9	0.9	1.3	3.1	4.0
135°	0.9	0.9	0.9	2.2	3.1
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)