

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518100

Luminaire Tested: HVL8-4-LD4-2STD-40-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518100
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2STD-40-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7050.0 lumens
Efficiency: N/A
Efficacy: 107.8 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 65.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518100

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518100

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	9446	9446	9446
5°	9425	9305	9400
10°	9301	9431	9458
15°	9132	9175	8779
20°	8926	8594	8396
25°	8708	8222	8448
30°	8377	7922	8541
35°	8142	7638	8390
40°	7888	7424	8442
45°	7615	7149	8290
50°	7284	6860	8227
55°	6798	6551	8222
60°	6425	6127	7871
65°	5680	5622	7620
70°	4634	4966	6833
75°	3307	4172	6238
80°	1856	3370	5600
85°	687	2545	4933

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 8290 cd/sqm

TEST NUMBER: P518100

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	224.9	3.2
10°-20°	640.5	9.1
20°-30°	953.0	13.5
30°-40°	1145.5	16.2
40°-50°	1205.7	17.1
50°-60°	1118.8	15.9
60°-70°	884.6	12.5
70°-80°	540.3	7.7
80°-90°	235.4	3.3
90°-100°	73.3	1.0
100°-110°	16.5	0.2
110°-120°	6.6	0.1
120°-130°	3.7	0.1
130°-140°	1.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1818.5	25.8
0°-40°	2964.0	42.0
0°-60°	5288.5	75.0
0°-90°	6948.9	98.6
90°-120°	96.4	1.4
90°-150°	101.1	1.4
90°-180°	101.0	1.4
0°-180°	7050.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2340	2340	2340	2340	2340	
5°	2334	2330	2338	2364	2371	221
15°	2210	2294	2317	2240	2242	622
25°	1993	2120	2024	2084	2118	915
35°	1700	1748	1774	1935	2001	1063
45°	1390	1396	1511	1750	1815	1071
55°	1024	1040	1205	1469	1586	920
65°	648	668	849	1124	1226	642
75°	245	325	473	728	773	267
85°	22	76	184	358	411	34
90°	0	23	97	227	267	1
95°	0	6	42	124	152	0
105°	0	3	9	24	34	1
115°	0	2	7	11	11	1
125°	0	1	3	7	10	1
135°	1	1	1	2	3	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518100

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2340.2	2340.2	2340.2	2340.2	2340.2
2.5°	2343.1	2336.9	2324.0	2336.4	2339.7
5°	2334.5	2329.7	2337.8	2364.1	2370.7
7.5°	2315.0	2333.1	2354.5	2402.2	2417.4
10°	2285.9	2320.2	2384.6	2425.1	2409.3
12.5°	2250.6	2308.8	2395.0	2315.9	2279.2
15°	2209.6	2294.5	2316.9	2240.1	2241.5
17.5°	2161.4	2282.5	2213.4	2211.5	2197.7
20°	2109.5	2242.5	2151.0	2147.1	2132.4
22.5°	2053.7	2189.6	2095.7	2088.0	2128.1
25°	1993.2	2120.4	2023.7	2084.2	2118.1
27.5°	1917.4	2029.9	1963.6	2049.4	2091.8
30°	1840.6	1936.4	1902.1	2021.8	2097.1
32.5°	1768.6	1838.7	1851.6	2011.3	2023.7
35°	1700.5	1747.7	1773.9	1935.0	2000.8
37.5°	1625.6	1638.5	1708.1	1903.1	1966.5
40°	1549.3	1541.2	1652.8	1850.6	1938.3
42.5°	1467.3	1464.5	1594.2	1824.4	1868.3
45°	1389.6	1395.8	1510.7	1750.0	1815.3
47.5°	1310.0	1318.1	1431.6	1668.5	1749.6
50°	1217.5	1228.0	1361.0	1596.1	1700.5
52.5°	1117.4	1137.5	1292.4	1527.4	1632.8
55°	1023.5	1040.2	1205.1	1468.8	1585.6
57.5°	937.7	947.7	1115.0	1394.9	1483.1
60°	853.3	855.7	1030.2	1312.9	1397.3
62.5°	756.6	760.8	943.0	1216.1	1329.1
65°	647.9	668.4	849.0	1123.6	1225.6
67.5°	546.3	582.1	753.2	1038.8	1092.2
70°	437.6	498.2	659.3	939.1	976.8
72.5°	338.0	409.0	563.0	827.6	880.5
75°	245.0	324.6	473.4	727.5	773.2
77.5°	164.9	246.0	389.5	616.9	677.4
80°	98.7	179.7	314.6	514.4	582.6
82.5°	50.5	120.6	244.1	431.4	492.5
85°	21.9	76.3	184.5	358.0	410.9
87.5°	6.2	43.4	135.9	289.4	334.2
90°	0.5	22.9	96.8	226.9	267.4
92.5°	0.5	11.0	68.2	171.6	202.6
95°	0.5	5.7	42.4	124.4	152.1
97.5°	0.5	3.3	25.7	88.2	111.6
100°	0.5	2.9	15.3	58.6	79.6
102.5°	0.5	3.3	10.5	37.2	52.0
105°	0.5	3.3	8.6	24.3	34.3
107.5°	1.0	3.3	7.6	18.1	23.8
110°	0.5	2.9	8.1	13.8	18.6

TEST NUMBER: P518100

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.0	2.4	7.6	11.4	13.8
115°	0.5	1.9	6.7	11.0	11.4
117.5°	1.0	1.4	5.2	11.0	11.4
120°	1.0	1.0	4.3	10.5	11.9
122.5°	1.0	1.0	3.3	9.5	11.4
125°	0.5	1.0	2.9	7.2	10.0
127.5°	1.0	1.0	2.4	5.7	7.6
130°	1.0	1.0	1.9	4.3	5.7
132.5°	1.0	1.0	1.4	3.3	4.3
135°	1.0	1.0	1.0	2.4	3.3
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)