

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518104

Luminaire Tested: HVL8-4-LD4-2STD-50-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518104
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2STD-50-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7169.0 lumens
Efficiency: N/A
Efficacy: 109.6 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 65.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518104

CATALOG NUMBER: HVL8-4-LD4-2STD-50-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518104

CATALOG NUMBER: HVL8-4-LD4-2STD-50-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	9606	9606	9606
5°	9584	9462	9559
10°	9458	9590	9618
15°	9286	9330	8927
20°	9077	8739	8537
25°	8855	8361	8591
30°	8519	8056	8686
35°	8279	7767	8532
40°	8021	7549	8585
45°	7744	7270	8430
50°	7407	6976	8366
55°	6913	6662	8361
60°	6533	6231	8004
65°	5776	5717	7749
70°	4712	5050	6949
75°	3363	4242	6343
80°	1886	3427	5695
85°	700	2588	5017

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 8430 cd/sqm

TEST NUMBER: P518104

CATALOG NUMBER: HVL8-4-LD4-2STD-50-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	228.7	3.2
10°-20°	651.3	9.1
20°-30°	969.1	13.5
30°-40°	1164.9	16.2
40°-50°	1226.1	17.1
50°-60°	1137.7	15.9
60°-70°	899.5	12.5
70°-80°	549.5	7.7
80°-90°	239.4	3.3
90°-100°	74.5	1.0
100°-110°	16.7	0.2
110°-120°	6.7	0.1
120°-130°	3.8	0.1
130°-140°	1.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1849.2	25.8
0°-40°	3014.0	42.0
0°-60°	5377.8	75.0
0°-90°	7066.2	98.6
90°-120°	98.0	1.4
90°-150°	102.8	1.4
90°-180°	103.0	1.4
0°-180°	7169.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2380	2380	2380	2380	2380	
5°	2374	2369	2377	2404	2411	225
15°	2247	2333	2356	2278	2279	633
25°	2027	2156	2058	2119	2154	930
35°	1729	1777	1804	1968	2035	1081
45°	1413	1419	1536	1780	1846	1089
55°	1041	1058	1226	1494	1612	935
65°	659	680	863	1143	1246	652
75°	249	330	481	740	786	272
85°	22	78	188	364	418	35
90°	0	23	98	231	272	1
95°	0	6	43	126	155	0
105°	0	3	9	25	35	1
115°	0	2	7	11	12	1
125°	0	1	3	7	10	1
135°	1	1	1	2	3	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518104

CATALOG NUMBER: HVL8-4-LD4-2STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2379.7	2379.7	2379.7	2379.7	2379.7
2.5°	2382.6	2376.3	2363.2	2375.8	2379.2
5°	2373.9	2369.1	2377.3	2404.0	2410.7
7.5°	2354.0	2372.4	2394.3	2442.7	2458.3
10°	2324.5	2359.4	2424.8	2466.0	2450.0
12.5°	2288.6	2347.7	2435.5	2355.0	2317.7
15°	2246.9	2333.2	2356.0	2277.9	2279.4
17.5°	2197.9	2321.1	2250.8	2248.8	2234.8
20°	2145.1	2280.3	2187.3	2183.4	2168.4
22.5°	2088.4	2226.5	2131.0	2123.3	2164.0
25°	2026.8	2156.2	2057.8	2119.4	2153.8
27.5°	1949.7	2064.1	1996.8	2084.0	2127.2
30°	1871.7	1969.1	1934.2	2055.9	2132.5
32.5°	1798.5	1869.7	1882.8	2045.2	2057.8
35°	1729.2	1777.2	1803.8	1967.7	2034.6
37.5°	1653.1	1666.1	1736.9	1935.2	1999.7
40°	1575.5	1567.2	1680.7	1881.9	1971.1
42.5°	1492.1	1489.2	1621.1	1855.2	1899.8
45°	1413.1	1419.4	1536.2	1779.6	1846.0
47.5°	1332.1	1340.4	1455.8	1696.7	1779.1
50°	1238.1	1248.8	1384.0	1623.0	1729.2
52.5°	1136.3	1156.7	1314.2	1553.2	1660.3
55°	1040.8	1057.8	1225.5	1493.6	1612.3
57.5°	953.5	963.7	1133.9	1418.4	1508.1
60°	867.7	870.2	1047.6	1335.0	1420.9
62.5°	769.3	773.7	958.9	1236.6	1351.5
65°	658.8	679.6	863.4	1142.6	1246.3
67.5°	555.5	591.9	765.9	1056.3	1110.6
70°	445.0	506.6	670.4	955.0	993.3
72.5°	343.7	415.9	572.5	841.6	895.4
75°	249.2	330.1	481.4	739.8	786.3
77.5°	167.7	250.1	396.1	627.3	688.9
80°	100.3	182.8	319.9	523.1	592.4
82.5°	51.4	122.6	248.2	438.7	500.8
85°	22.3	77.6	187.6	364.1	417.9
87.5°	6.3	44.1	138.2	294.3	339.8
90°	0.5	23.3	98.4	230.7	272.0
92.5°	0.5	11.1	69.3	174.5	206.0
95°	0.5	5.8	43.1	126.5	154.6
97.5°	0.5	3.4	26.2	89.7	113.4
100°	0.5	2.9	15.5	59.6	81.0
102.5°	0.5	3.4	10.7	37.8	52.8
105°	0.5	3.4	8.7	24.7	34.9
107.5°	1.0	3.4	7.8	18.4	24.2
110°	0.5	2.9	8.2	14.1	18.9

TEST NUMBER: P518104

CATALOG NUMBER: HVL8-4-LD4-2STD-50-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.0	2.4	7.8	11.6	14.1
115°	0.5	1.9	6.8	11.1	11.6
117.5°	1.0	1.5	5.3	11.1	11.6
120°	1.0	1.0	4.4	10.7	12.1
122.5°	1.0	1.0	3.4	9.7	11.6
125°	0.5	1.0	2.9	7.3	10.2
127.5°	1.0	1.0	2.4	5.8	7.8
130°	1.0	1.0	1.9	4.4	5.8
132.5°	1.0	1.0	1.5	3.4	4.4
135°	1.0	1.0	1.0	2.4	3.4
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)