

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518120

Luminaire Tested: HVL8-4-LD4-3HI-50-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518120
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-3HI-50-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 14549.0 lumens
Efficiency: N/A
Efficacy: 115.6 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 125.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518120

CATALOG NUMBER: HVL8-4-LD4-3HI-50-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518120

CATALOG NUMBER: HVL8-4-LD4-3HI-50-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	19494	19494	19494
5°	19450	19202	19399
10°	19194	19462	19519
15°	18845	18934	18117
20°	18420	17736	17326
25°	17970	16968	17434
30°	17288	16349	17626
35°	16802	15762	17315
40°	16279	15320	17422
45°	15716	14754	17108
50°	15032	14158	16977
55°	14029	13519	16968
60°	13259	12645	16243
65°	11722	11602	15726
70°	9563	10249	14102
75°	6825	8608	12873
80°	3828	6956	11557
85°	1421	5251	10180

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 17108 cd/sqm

TEST NUMBER: P518120

CATALOG NUMBER: HVL8-4-LD4-3HI-50-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	464.2	3.2
10°-20°	1321.8	9.1
20°-30°	1966.7	13.5
30°-40°	2364.0	16.2
40°-50°	2488.3	17.1
50°-60°	2308.8	15.9
60°-70°	1825.5	12.5
70°-80°	1115.1	7.7
80°-90°	485.8	3.3
90°-100°	151.3	1.0
100°-110°	34.0	0.2
110°-120°	13.7	0.1
120°-130°	7.7	0.1
130°-140°	2.1	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3752.7	25.8
0°-40°	6116.8	42.0
0°-60°	10913.9	75.0
0°-90°	14340.3	98.6
90°-120°	198.9	1.4
90°-150°	208.7	1.4
90°-180°	209.0	1.4
0°-180°	14549.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4830	4830	4830	4830	4830	
5°	4818	4808	4825	4879	4892	457
15°	4560	4735	4781	4623	4626	1285
25°	4113	4376	4176	4301	4371	1888
35°	3509	3607	3661	3993	4129	2193
45°	2868	2881	3118	3612	3746	2211
55°	2112	2147	2487	3031	3272	1898
65°	1337	1379	1752	2319	2529	1324
75°	506	670	977	1501	1596	552
85°	45	157	381	739	848	70
90°	1	47	200	468	552	2
95°	1	12	88	257	314	1
105°	1	7	18	50	71	1
115°	1	4	14	23	24	2
125°	1	2	6	15	21	2
135°	2	2	2	5	7	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518120

CATALOG NUMBER: HVL8-4-LD4-3HI-50-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4829.5	4829.5	4829.5	4829.5	4829.5
2.5°	4835.4	4822.6	4796.0	4821.6	4828.5
5°	4817.7	4807.8	4824.6	4878.7	4892.4
7.5°	4777.3	4814.7	4859.0	4957.4	4988.9
10°	4717.3	4788.2	4921.0	5004.6	4972.1
12.5°	4644.5	4764.5	4942.6	4779.3	4703.6
15°	4559.9	4735.0	4781.3	4622.9	4625.8
17.5°	4460.6	4710.4	4567.8	4563.9	4535.3
20°	4353.3	4627.8	4438.9	4431.0	4400.5
22.5°	4238.2	4518.6	4324.8	4309.0	4391.7
25°	4113.3	4375.9	4176.2	4301.2	4371.0
27.5°	3956.8	4189.0	4052.3	4229.4	4316.9
30°	3798.5	3996.2	3925.4	4172.3	4327.7
32.5°	3649.9	3794.5	3821.1	4150.7	4176.2
35°	3509.2	3606.6	3660.7	3993.2	4129.0
37.5°	3354.8	3381.3	3525.0	3927.3	4058.2
40°	3197.4	3180.6	3410.8	3819.1	4000.1
42.5°	3028.1	3022.2	3289.8	3765.0	3855.5
45°	2867.8	2880.6	3117.7	3611.5	3746.3
47.5°	2703.5	2720.2	2954.4	3443.3	3610.5
50°	2512.6	2534.3	2808.8	3293.8	3509.2
52.5°	2306.0	2347.3	2667.1	3152.1	3369.5
55°	2112.2	2146.7	2487.0	3031.1	3272.1
57.5°	1935.1	1955.8	2301.1	2878.6	3060.6
60°	1761.0	1765.9	2126.0	2709.4	2883.5
62.5°	1561.3	1570.1	1946.0	2509.7	2742.8
65°	1337.0	1379.3	1752.1	2318.8	2529.4
67.5°	1127.4	1201.2	1554.4	2143.7	2253.9
70°	903.1	1028.1	1360.6	1938.1	2015.8
72.5°	697.5	844.1	1161.9	1707.9	1817.1
75°	505.7	670.0	976.9	1501.3	1595.7
77.5°	340.4	507.6	803.8	1273.0	1398.0
80°	203.6	370.9	649.3	1061.5	1202.2
82.5°	104.3	248.9	503.7	890.3	1016.3
85°	45.3	157.4	380.7	738.8	848.0
87.5°	12.8	89.5	280.4	597.2	689.6
90°	1.0	47.2	199.7	468.3	551.9
92.5°	1.0	22.6	140.7	354.2	418.1
95°	1.0	11.8	87.6	256.8	313.8
97.5°	1.0	6.9	53.1	182.0	230.2
100°	1.0	5.9	31.5	121.0	164.3
102.5°	1.0	6.9	21.6	76.7	107.2
105°	1.0	6.9	17.7	50.2	70.8
107.5°	2.0	6.9	15.7	37.4	49.2
110°	1.0	5.9	16.7	28.5	38.4

TEST NUMBER: P518120

CATALOG NUMBER: HVL8-4-LD4-3HI-50-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	2.0	4.9	15.7	23.6	28.5
115°	1.0	3.9	13.8	22.6	23.6
117.5°	2.0	3.0	10.8	22.6	23.6
120°	2.0	2.0	8.9	21.6	24.6
122.5°	2.0	2.0	6.9	19.7	23.6
125°	1.0	2.0	5.9	14.8	20.7
127.5°	2.0	2.0	4.9	11.8	15.7
130°	2.0	2.0	3.9	8.9	11.8
132.5°	2.0	2.0	3.0	6.9	8.9
135°	2.0	2.0	2.0	4.9	6.9
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)