

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518136

Luminaire Tested: HVL8-4-LD4-3LO-50-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518136
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-3LO-50-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 8777.1 lumens
Efficiency: N/A
Efficacy: 130.2 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 67.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518136

CATALOG NUMBER: HVL8-4-LD4-3LO-50-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518136

CATALOG NUMBER: HVL8-4-LD4-3LO-50-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			99
1	108	103	98	94	105	100	96	92	96	92	89	91	89	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	78	73	80	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	51	62	56	51	60	54	50			47
5	75	61	52	45	72	60	51	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	39	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	11760	11760	11760
5°	11734	11584	11703
10°	11579	11741	11775
15°	11369	11422	10929
20°	11112	10700	10452
25°	10841	10236	10518
30°	10430	9863	10634
35°	10136	9509	10445
40°	9820	9243	10510
45°	9480	8900	10320
50°	9068	8541	10242
55°	8463	8156	10236
60°	7999	7629	9799
65°	7072	6999	9487
70°	5769	6183	8508
75°	4118	5193	7766
80°	2311	4196	6972
85°	856	3168	6141

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 10320 cd/sqm

TEST NUMBER: P518136

CATALOG NUMBER: HVL8-4-LD4-3LO-50-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	280.0	3.2
10°-20°	797.4	9.1
20°-30°	1186.5	13.5
30°-40°	1426.2	16.2
40°-50°	1501.1	17.1
50°-60°	1392.9	15.9
60°-70°	1101.3	12.5
70°-80°	672.7	7.7
80°-90°	293.1	3.3
90°-100°	91.3	1.0
100°-110°	20.5	0.2
110°-120°	8.2	0.1
120°-130°	4.6	0.1
130°-140°	1.3	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2263.9	25.8
0°-40°	3690.1	42.0
0°-60°	6584.0	75.0
0°-90°	8651.1	98.6
90°-120°	120.0	1.4
90°-150°	125.9	1.4
90°-180°	126.0	1.4
0°-180°	8777.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2914	2914	2914	2914	2914	
5°	2906	2900	2910	2943	2952	275
15°	2751	2856	2884	2789	2791	775
25°	2481	2640	2519	2595	2637	1139
35°	2117	2176	2208	2409	2491	1323
45°	1730	1738	1881	2179	2260	1334
55°	1274	1295	1500	1829	1974	1145
65°	807	832	1057	1399	1526	799
75°	305	404	589	906	963	333
85°	27	95	230	446	512	42
90°	1	28	120	282	333	1
95°	1	7	53	155	189	0
105°	1	4	11	30	43	1
115°	1	2	8	14	14	1
125°	1	1	4	9	12	1
135°	1	1	1	3	4	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518136

CATALOG NUMBER: HVL8-4-LD4-3LO-50-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2913.5	2913.5	2913.5	2913.5	2913.5
2.5°	2917.0	2909.3	2893.3	2908.7	2912.9
5°	2906.4	2900.4	2910.5	2943.2	2951.5
7.5°	2882.0	2904.6	2931.3	2990.6	3009.6
10°	2845.8	2888.6	2968.7	3019.1	2999.5
12.5°	2801.9	2874.3	2981.7	2883.2	2837.5
15°	2750.9	2856.5	2884.4	2788.9	2790.6
17.5°	2690.9	2841.7	2755.6	2753.2	2736.0
20°	2626.2	2791.8	2677.9	2673.1	2654.7
22.5°	2556.8	2725.9	2609.0	2599.5	2649.4
25°	2481.4	2639.9	2519.4	2594.8	2636.9
27.5°	2387.1	2527.1	2444.6	2551.5	2604.3
30°	2291.5	2410.8	2368.1	2517.0	2610.8
32.5°	2201.9	2289.1	2305.2	2504.0	2519.4
35°	2117.0	2175.8	2208.4	2409.0	2490.9
37.5°	2023.8	2039.9	2126.5	2369.2	2448.2
40°	1928.9	1918.8	2057.7	2304.0	2413.2
42.5°	1826.8	1823.2	1984.7	2271.3	2325.9
45°	1730.0	1737.8	1880.8	2178.7	2260.0
47.5°	1630.9	1641.0	1782.3	2077.2	2178.1
50°	1515.8	1528.9	1694.4	1987.0	2117.0
52.5°	1391.2	1416.1	1609.0	1901.6	2032.7
55°	1274.2	1295.0	1500.4	1828.6	1974.0
57.5°	1167.4	1179.9	1388.2	1736.6	1846.4
60°	1062.4	1065.3	1282.6	1634.5	1739.5
62.5°	941.9	947.2	1173.9	1514.0	1654.7
65°	806.6	832.1	1057.0	1398.9	1525.9
67.5°	680.1	724.7	937.7	1293.2	1359.7
70°	544.8	620.2	820.8	1169.2	1216.1
72.5°	420.8	509.2	700.9	1030.3	1096.2
75°	305.1	404.2	589.3	905.7	962.7
77.5°	205.4	306.2	484.9	768.0	843.4
80°	122.9	223.7	391.7	640.4	725.3
82.5°	62.9	150.2	303.9	537.1	613.1
85°	27.3	95.0	229.7	445.7	511.6
87.5°	7.7	54.0	169.1	360.3	416.0
90°	0.6	28.5	120.5	282.5	333.0
92.5°	0.6	13.7	84.9	213.7	252.2
95°	0.6	7.1	52.8	154.9	189.3
97.5°	0.6	4.2	32.0	109.8	138.9
100°	0.6	3.6	19.0	73.0	99.1
102.5°	0.6	4.2	13.1	46.3	64.7
105°	0.6	4.2	10.7	30.3	42.7
107.5°	1.2	4.2	9.5	22.6	29.7
110°	0.6	3.6	10.1	17.2	23.1

TEST NUMBER: P518136

CATALOG NUMBER: HVL8-4-LD4-3LO-50-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.2	3.0	9.5	14.2	17.2
115°	0.6	2.4	8.3	13.7	14.2
117.5°	1.2	1.8	6.5	13.7	14.2
120°	1.2	1.2	5.3	13.1	14.8
122.5°	1.2	1.2	4.2	11.9	14.2
125°	0.6	1.2	3.6	8.9	12.5
127.5°	1.2	1.2	3.0	7.1	9.5
130°	1.2	1.2	2.4	5.3	7.1
132.5°	1.2	1.2	1.8	4.2	5.3
135°	1.2	1.2	1.2	3.0	4.2
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)