

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518144

Luminaire Tested: HVL8-4-LD4-3STD-35-UNV-C-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518144
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-3STD-35-UNV-C-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 11007.0 lumens
Efficiency: N/A
Efficacy: 115.3 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.32 / 1.37
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 95.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518144

CATALOG NUMBER: HVL8-4-LD4-3STD-35-UNV-C-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518144

CATALOG NUMBER: HVL8-4-LD4-3STD-35-UNV-C-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	103	98	94	105	100	96	92	96	92	89		91	89	86		87
2	98	89	82	76	95	87	80	75	83	78	73		80	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	51		62	56	51		60
5	75	61	52	45	72	60	51	45	58	50	44		56	49	44		54
6	69	55	46	39	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	14748	14748	14748
5°	14715	14527	14677
10°	14521	14724	14767
15°	14257	14324	13706
20°	13936	13418	13108
25°	13595	12837	13190
30°	13079	12368	13335
35°	12711	11925	13099
40°	12315	11591	13181
45°	11890	11162	12943
50°	11372	10711	12844
55°	10614	10228	12837
60°	10031	9567	12289
65°	8868	8778	11897
70°	7236	7754	10669
75°	5164	6513	9739
80°	2897	5262	8743
85°	1073	3972	7702

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 90°

Vertical Angle: 45°

Luminance: 12943 cd/sqm

TEST NUMBER: P518144

CATALOG NUMBER: HVL8-4-LD4-3STD-35-UNV-C-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	351.2	3.2
10°-20°	1000.0	9.1
20°-30°	1487.9	13.5
30°-40°	1788.5	16.2
40°-50°	1882.5	17.1
50°-60°	1746.8	15.9
60°-70°	1381.1	12.5
70°-80°	843.6	7.7
80°-90°	367.6	3.3
90°-100°	114.4	1.0
100°-110°	25.7	0.2
110°-120°	10.3	0.1
120°-130°	5.8	0.1
130°-140°	1.6	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2839.1	25.8
0°-40°	4627.6	42.0
0°-60°	8256.9	75.0
0°-90°	10849.2	98.6
90°-120°	150.5	1.4
90°-150°	157.8	1.4
90°-180°	158.0	1.4
0°-180°	11007.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3654	3654	3654	3654	3654	
5°	3645	3637	3650	3691	3701	345
15°	3450	3582	3617	3497	3500	972
25°	3112	3311	3160	3254	3307	1429
35°	2655	2729	2770	3021	3124	1659
45°	2170	2179	2359	2732	2834	1672
55°	1598	1624	1882	2293	2476	1436
65°	1012	1044	1326	1754	1914	1002
75°	383	507	739	1136	1207	418
85°	34	119	288	559	642	53
90°	1	36	151	354	418	2
95°	1	9	66	194	237	1
105°	1	5	13	38	54	1
115°	1	3	10	17	18	1
125°	1	2	4	11	16	1
135°	2	2	2	4	5	1
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518144

CATALOG NUMBER: HVL8-4-LD4-3STD-35-UNV-C-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3653.7	3653.7	3653.7	3653.7	3653.7
2.5°	3658.2	3648.5	3628.4	3647.8	3653.0
5°	3644.8	3637.4	3650.0	3690.9	3701.4
7.5°	3614.3	3642.6	3676.1	3750.5	3774.3
10°	3568.9	3622.5	3722.9	3786.2	3761.6
12.5°	3513.8	3604.6	3739.3	3615.8	3558.5
15°	3449.8	3582.3	3617.3	3497.4	3499.7
17.5°	3374.6	3563.7	3455.7	3452.8	3431.2
20°	3293.5	3501.1	3358.2	3352.3	3329.2
22.5°	3206.4	3418.5	3271.9	3260.0	3322.5
25°	3111.9	3310.6	3159.5	3254.0	3306.9
27.5°	2993.5	3169.2	3065.7	3199.7	3265.9
30°	2873.7	3023.3	2969.7	3156.5	3274.1
32.5°	2761.3	2870.7	2890.8	3140.2	3159.5
35°	2654.9	2728.6	2769.5	3021.1	3123.8
37.5°	2538.0	2558.1	2666.8	2971.2	3070.2
40°	2418.9	2406.3	2580.5	2889.3	3026.3
42.5°	2290.9	2286.5	2488.9	2848.4	2916.9
45°	2169.6	2179.3	2358.7	2732.3	2834.3
47.5°	2045.3	2058.0	2235.1	2605.0	2731.5
50°	1900.9	1917.3	2125.0	2491.9	2654.9
52.5°	1744.6	1775.9	2017.8	2384.7	2549.2
55°	1598.0	1624.0	1881.6	2293.2	2475.5
57.5°	1464.0	1479.7	1740.9	2177.8	2315.5
60°	1332.3	1336.0	1608.4	2049.8	2181.5
62.5°	1181.2	1187.9	1472.2	1898.7	2075.1
65°	1011.5	1043.5	1325.6	1754.3	1913.6
67.5°	853.0	908.8	1176.0	1621.8	1705.2
70°	683.3	777.8	1029.4	1466.3	1525.1
72.5°	527.7	638.6	879.0	1292.1	1374.7
75°	382.6	506.9	739.1	1135.8	1207.2
77.5°	257.5	384.1	608.1	963.1	1057.6
80°	154.1	280.6	491.2	803.1	909.5
82.5°	78.9	188.3	381.1	673.6	768.9
85°	34.2	119.1	288.0	559.0	641.6
87.5°	9.7	67.7	212.1	451.8	521.7
90°	0.7	35.7	151.1	354.3	417.5
92.5°	0.7	17.1	106.4	267.9	316.3
95°	0.7	8.9	66.2	194.3	237.4
97.5°	0.7	5.2	40.2	137.7	174.2
100°	0.7	4.5	23.8	91.5	124.3
102.5°	0.7	5.2	16.4	58.1	81.1
105°	0.7	5.2	13.4	38.0	53.6
107.5°	1.5	5.2	11.9	28.3	37.2
110°	0.7	4.5	12.7	21.6	29.0

TEST NUMBER: P518144

CATALOG NUMBER: HVL8-4-LD4-3STD-35-UNV-C-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.5	3.7	11.9	17.9	21.6
115°	0.7	3.0	10.4	17.1	17.9
117.5°	1.5	2.2	8.2	17.1	17.9
120°	1.5	1.5	6.7	16.4	18.6
122.5°	1.5	1.5	5.2	14.9	17.9
125°	0.7	1.5	4.5	11.2	15.6
127.5°	1.5	1.5	3.7	8.9	11.9
130°	1.5	1.5	3.0	6.7	8.9
132.5°	1.5	1.5	2.2	5.2	6.7
135°	1.5	1.5	1.5	3.7	5.2
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)