

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517726

Luminaire Tested: HVL8-1-LD4-1HI-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517726
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-1HI-30-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1020.0 lumens
Efficiency: N/A
Efficacy: 95.3 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 10.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517726

CATALOG NUMBER: HVL8-1-LD4-1HI-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517726

CATALOG NUMBER: HVL8-1-LD4-1HI-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5448	5448	5448
5°	5377	5285	5331
10°	5285	5152	5224
15°	5181	5012	5096
20°	5075	4862	4970
25°	4961	4708	4844
30°	4833	4549	4700
35°	4688	4377	4557
40°	4536	4199	4392
45°	4374	4009	4212
50°	4179	3794	4019
55°	3965	3560	3806
60°	3718	3271	3558
65°	3372	2952	3313
70°	2921	2588	3028
75°	2334	2193	2765
80°	1568	1807	2530
85°	669	1412	2305

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4374 cd/sqm

TEST NUMBER: P517726

CATALOG NUMBER: HVL8-1-LD4-1HI-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	31.9	3.1
10°-20°	91.6	9.0
20°-30°	139.0	13.6
30°-40°	168.0	16.5
40°-50°	175.3	17.2
50°-60°	160.3	15.7
60°-70°	124.9	12.2
70°-80°	78.2	7.7
80°-90°	35.5	3.5
90°-100°	11.9	1.2
100°-110°	3.0	0.3
110°-120°	0.5	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	262.4	25.7
0°-40°	430.5	42.2
0°-60°	766.0	75.1
0°-90°	1004.7	98.5
90°-120°	15.4	1.5
90°-150°	15.4	1.5
90°-180°	15.0	1.5
0°-180°	1020.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	337	337	337	337	337	
5°	337	336	334	336	336	32
15°	324	324	324	325	325	91
25°	300	300	301	303	304	138
35°	266	267	268	271	272	166
45°	224	226	227	230	231	172
55°	174	176	180	182	184	156
65°	120	122	126	131	133	119
75°	61	64	74	83	86	65
85°	10	19	33	44	48	13
90°	0	7	20	30	33	0
95°	0	2	10	18	21	0
105°	0	0	2	5	7	0
115°	0	0	0	1	1	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517726

CATALOG NUMBER: HVL8-1-LD4-1HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	337.4	337.4	337.4	337.4	337.4
2.5°	337.8	337.3	335.8	337.3	337.2
5°	336.6	336.0	334.5	336.1	336.1
7.5°	334.4	334.2	332.8	334.7	334.7
10°	331.8	331.7	330.6	332.6	332.7
12.5°	328.1	328.4	327.4	329.3	329.6
15°	323.8	324.4	323.5	325.3	325.3
17.5°	319.1	319.5	318.8	320.9	320.8
20°	313.3	313.7	313.3	315.4	315.6
22.5°	306.9	307.5	307.4	309.6	310.2
25°	300.1	300.3	300.6	303.2	303.6
27.5°	292.5	292.9	293.5	295.8	296.2
30°	284.2	284.9	285.5	287.9	288.5
32.5°	275.5	276.1	276.9	280.0	280.3
35°	265.6	266.8	267.9	270.6	271.7
37.5°	255.8	257.3	258.3	261.2	262.0
40°	245.3	246.9	248.5	251.5	252.1
42.5°	234.4	236.2	238.2	240.9	241.8
45°	223.5	225.5	227.3	229.5	230.6
47.5°	211.6	213.6	215.8	218.4	219.1
50°	199.4	201.7	204.1	206.5	207.7
52.5°	186.8	189.6	192.3	194.8	196.0
55°	174.4	176.5	179.7	182.4	183.5
57.5°	161.5	163.3	166.2	170.5	171.1
60°	148.4	150.0	153.0	156.5	157.9
62.5°	133.9	136.1	139.3	143.7	145.0
65°	119.8	121.9	126.1	131.1	133.2
67.5°	106.2	107.0	112.4	117.6	121.0
70°	90.2	92.9	99.2	105.6	108.2
72.5°	76.3	79.1	86.0	93.5	96.7
75°	60.7	64.4	73.8	82.6	85.7
77.5°	46.9	51.1	62.7	71.6	75.2
80°	32.8	39.2	51.9	61.9	65.8
82.5°	20.6	28.6	42.1	52.6	56.0
85°	10.5	19.4	33.3	44.1	48.0
87.5°	2.8	12.6	25.9	36.2	40.2
90°	0.1	7.2	19.6	29.5	33.1
92.5°	0.1	4.1	14.6	23.5	27.1
95°	0.1	1.9	10.2	18.5	21.3
97.5°	0.1	0.8	7.0	13.9	16.8
100°	0.1	0.4	4.5	10.1	12.6
102.5°	0.2	0.2	2.8	7.2	9.2
105°	0.2	0.2	1.7	4.9	6.6
107.5°	0.2	0.2	1.0	3.3	4.5
110°	0.2	0.2	0.6	2.1	3.0

TEST NUMBER: P517726

CATALOG NUMBER: HVL8-1-LD4-1HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.2	0.2	0.3	1.4	2.0
115°	0.2	0.2	0.3	0.9	1.3
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)