

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517730

Luminaire Tested: HVL8-1-LD4-1HI-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517730
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-1HI-35-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1071.0 lumens
Efficiency: N/A
Efficacy: 100.1 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct

Input Watts (W): 10.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517730
CATALOG NUMBER: HVL8-1-LD4-1HI-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517730

CATALOG NUMBER: HVL8-1-LD4-1HI-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5719	5719	5719
5°	5647	5549	5597
10°	5549	5410	5485
15°	5440	5263	5350
20°	5330	5104	5219
25°	5209	4943	5086
30°	5075	4777	4936
35°	4923	4596	4786
40°	4763	4409	4611
45°	4591	4210	4424
50°	4386	3984	4221
55°	4163	3738	3997
60°	3904	3436	3736
65°	3540	3100	3479
70°	3066	2716	3179
75°	2450	2302	2904
80°	1644	1894	2657
85°	701	1484	2420

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4591 cd/sqm

TEST NUMBER: P517730

CATALOG NUMBER: HVL8-1-LD4-1HI-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	33.5	3.1
10°-20°	96.2	9.0
20°-30°	145.9	13.6
30°-40°	176.4	16.5
40°-50°	184.1	17.2
50°-60°	168.3	15.7
60°-70°	131.2	12.2
70°-80°	82.1	7.7
80°-90°	37.3	3.5
90°-100°	12.5	1.2
100°-110°	3.2	0.3
110°-120°	0.5	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	275.6	25.7
0°-40°	452.0	42.2
0°-60°	804.3	75.1
0°-90°	1054.9	98.5
90°-120°	16.2	1.5
90°-150°	16.2	1.5
90°-180°	16.0	1.5
0°-180°	1071.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	354	354	354	354	354	
5°	354	353	351	353	353	34
15°	340	341	340	342	342	96
25°	315	315	316	318	319	145
35°	279	280	281	284	285	175
45°	235	237	239	241	242	181
55°	183	185	189	192	193	164
65°	126	128	132	138	140	125
75°	64	68	78	87	90	68
85°	11	20	35	46	50	14
90°	0	8	21	31	35	0
95°	0	2	11	19	22	0
105°	0	0	2	5	7	0
115°	0	0	0	1	1	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517730

CATALOG NUMBER: HVL8-1-LD4-1HI-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	354.2	354.2	354.2	354.2	354.2
2.5°	354.6	354.1	352.6	354.1	354.1
5°	353.5	352.8	351.2	352.9	352.9
7.5°	351.1	350.9	349.5	351.4	351.4
10°	348.4	348.3	347.1	349.2	349.3
12.5°	344.5	344.9	343.8	345.8	346.0
15°	340.0	340.6	339.7	341.6	341.5
17.5°	335.1	335.4	334.8	336.9	336.9
20°	329.0	329.4	328.9	331.2	331.4
22.5°	322.2	322.8	322.7	325.1	325.7
25°	315.1	315.3	315.6	318.3	318.8
27.5°	307.1	307.5	308.1	310.5	311.1
30°	298.4	299.1	299.8	302.3	303.0
32.5°	289.3	289.9	290.8	294.0	294.4
35°	278.9	280.2	281.3	284.2	285.3
37.5°	268.5	270.1	271.2	274.2	275.1
40°	257.6	259.2	260.9	264.1	264.7
42.5°	246.2	248.0	250.1	252.9	253.9
45°	234.6	236.7	238.7	241.0	242.2
47.5°	222.2	224.3	226.6	229.3	230.1
50°	209.3	211.8	214.3	216.8	218.1
52.5°	196.1	199.1	201.9	204.6	205.8
55°	183.1	185.3	188.7	191.5	192.7
57.5°	169.6	171.4	174.5	179.0	179.7
60°	155.8	157.5	160.7	164.3	165.8
62.5°	140.6	142.9	146.2	150.9	152.2
65°	125.8	128.0	132.4	137.7	139.9
67.5°	111.6	112.3	118.0	123.5	127.0
70°	94.7	97.5	104.1	110.9	113.6
72.5°	80.2	83.0	90.3	98.2	101.5
75°	63.7	67.6	77.5	86.8	90.0
77.5°	49.3	53.6	65.8	75.2	78.9
80°	34.4	41.2	54.4	65.0	69.1
82.5°	21.6	30.0	44.2	55.2	58.8
85°	11.0	20.4	35.0	46.3	50.4
87.5°	2.9	13.2	27.2	38.0	42.2
90°	0.1	7.6	20.6	31.0	34.7
92.5°	0.1	4.3	15.4	24.6	28.5
95°	0.1	2.0	10.7	19.4	22.4
97.5°	0.1	0.8	7.3	14.6	17.6
100°	0.1	0.4	4.7	10.6	13.2
102.5°	0.2	0.3	2.9	7.6	9.7
105°	0.2	0.3	1.8	5.2	6.9
107.5°	0.2	0.3	1.0	3.5	4.8
110°	0.3	0.3	0.6	2.2	3.2

TEST NUMBER: P517730

CATALOG NUMBER: HVL8-1-LD4-1HI-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.3	0.3	0.3	1.4	2.1
115°	0.3	0.3	0.3	0.9	1.3
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)