

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517734

Luminaire Tested: HVL8-1-LD4-1HI-40-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517734
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-1HI-40-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1081.0 lumens
Efficiency: N/A
Efficacy: 101.0 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 10.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517734

CATALOG NUMBER: HVL8-1-LD4-1HI-40-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517734

CATALOG NUMBER: HVL8-1-LD4-1HI-40-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5772	5772	5772
5°	5700	5601	5650
10°	5600	5461	5537
15°	5491	5312	5400
20°	5380	5152	5268
25°	5257	4990	5134
30°	5122	4821	4982
35°	4969	4640	4831
40°	4808	4451	4655
45°	4634	4249	4464
50°	4428	4021	4259
55°	4202	3774	4034
60°	3941	3468	3772
65°	3574	3130	3511
70°	3095	2742	3207
75°	2473	2323	2933
80°	1658	1914	2680
85°	708	1497	2439

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4634 cd/sqm

TEST NUMBER: P517734

CATALOG NUMBER: HVL8-1-LD4-1HI-40-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	33.8	3.1
10°-20°	97.1	9.0
20°-30°	147.3	13.6
30°-40°	178.1	16.5
40°-50°	185.8	17.2
50°-60°	169.9	15.7
60°-70°	132.4	12.3
70°-80°	82.8	7.7
80°-90°	37.6	3.5
90°-100°	12.6	1.2
100°-110°	3.2	0.3
110°-120°	0.5	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	278.1	25.7
0°-40°	456.2	42.2
0°-60°	811.9	75.1
0°-90°	1064.8	98.5
90°-120°	16.3	1.5
90°-150°	16.3	1.5
90°-180°	16.0	1.5
0°-180°	1081.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	358	358	358	358	358	
5°	357	356	354	356	356	34
15°	343	344	343	345	345	97
25°	318	318	319	321	322	147
35°	282	283	284	287	288	176
45°	237	239	241	243	244	182
55°	185	187	190	193	194	165
65°	127	129	134	139	141	126
75°	64	68	78	88	91	69
85°	11	21	35	47	51	14
90°	0	8	21	31	35	0
95°	0	2	11	20	23	0
105°	0	0	2	5	7	0
115°	0	0	0	1	1	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517734

CATALOG NUMBER: HVL8-1-LD4-1HI-40-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	357.5	357.5	357.5	357.5	357.5
2.5°	358.0	357.4	355.8	357.4	357.4
5°	356.8	356.1	354.5	356.2	356.2
7.5°	354.4	354.2	352.7	354.7	354.7
10°	351.6	351.5	350.4	352.5	352.6
12.5°	347.8	348.1	347.0	349.0	349.3
15°	343.2	343.8	342.9	344.8	344.7
17.5°	338.2	338.6	337.9	340.1	340.0
20°	332.1	332.5	332.0	334.3	334.5
22.5°	325.2	325.8	325.8	328.1	328.8
25°	318.0	318.3	318.6	321.3	321.8
27.5°	310.0	310.4	311.0	313.4	314.0
30°	301.2	301.9	302.6	305.1	305.8
32.5°	292.0	292.6	293.5	296.8	297.1
35°	281.5	282.8	284.0	286.8	288.0
37.5°	271.1	272.7	273.8	276.8	277.7
40°	260.0	261.6	263.4	266.6	267.2
42.5°	248.5	250.3	252.4	255.3	256.3
45°	236.8	238.9	240.9	243.2	244.4
47.5°	224.3	226.4	228.7	231.4	232.2
50°	211.3	213.7	216.3	218.8	220.1
52.5°	198.0	200.9	203.8	206.5	207.8
55°	184.8	187.0	190.5	193.3	194.5
57.5°	171.2	173.0	176.2	180.7	181.4
60°	157.3	159.0	162.2	165.9	167.4
62.5°	141.9	144.2	147.6	152.3	153.6
65°	127.0	129.2	133.7	139.0	141.2
67.5°	112.6	113.4	119.1	124.7	128.2
70°	95.6	98.4	105.1	111.9	114.6
72.5°	80.9	83.8	91.1	99.1	102.5
75°	64.3	68.3	78.2	87.6	90.9
77.5°	49.7	54.1	66.4	75.9	79.6
80°	34.7	41.6	55.0	65.6	69.7
82.5°	21.8	30.3	44.6	55.7	59.3
85°	11.1	20.6	35.3	46.7	50.8
87.5°	2.9	13.3	27.5	38.3	42.6
90°	0.1	7.7	20.8	31.3	35.1
92.5°	0.1	4.3	15.5	24.9	28.7
95°	0.1	2.0	10.8	19.6	22.6
97.5°	0.1	0.8	7.4	14.7	17.8
100°	0.1	0.4	4.7	10.7	13.3
102.5°	0.2	0.3	2.9	7.7	9.8
105°	0.2	0.3	1.8	5.2	7.0
107.5°	0.2	0.3	1.0	3.5	4.8
110°	0.3	0.3	0.6	2.2	3.2

TEST NUMBER: P517734

CATALOG NUMBER: HVL8-1-LD4-1HI-40-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.3	0.3	0.3	1.4	2.1
115°	0.3	0.3	0.3	0.9	1.3
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)