

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517762

Luminaire Tested: HVL8-1-LD4-1STD-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517762
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-1STD-35-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 832.0 lumens
Efficiency: N/A
Efficacy: 101.5 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 8.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517762

CATALOG NUMBER: HVL8-1-LD4-1STD-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517762

CATALOG NUMBER: HVL8-1-LD4-1STD-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		87
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		60
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		54
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	4443	4443	4443
5°	4387	4310	4347
10°	4310	4203	4260
15°	4226	4088	4156
20°	4141	3965	4055
25°	4047	3840	3952
30°	3942	3711	3833
35°	3825	3570	3719
40°	3700	3425	3582
45°	3568	3270	3436
50°	3407	3095	3278
55°	3235	2904	3105
60°	3032	2668	2902
65°	2752	2409	2703
70°	2383	2110	2468
75°	1904	1788	2256
80°	1276	1472	2061
85°	548	1154	1877

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 3568 cd/sqm

TEST NUMBER: P517762

CATALOG NUMBER: HVL8-1-LD4-1STD-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	26.0	3.1
10°-20°	74.7	9.0
20°-30°	113.3	13.6
30°-40°	137.0	16.5
40°-50°	143.0	17.2
50°-60°	130.7	15.7
60°-70°	101.9	12.2
70°-80°	63.8	7.7
80°-90°	29.0	3.5
90°-100°	9.7	1.2
100°-110°	2.4	0.3
110°-120°	0.4	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	214.1	25.7
0°-40°	351.1	42.2
0°-60°	624.8	75.1
0°-90°	819.5	98.5
90°-120°	12.5	1.5
90°-150°	12.5	1.5
90°-180°	13.0	1.6
0°-180°	832.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	275	275	275	275	275	
5°	275	274	273	274	274	26
15°	264	265	264	265	265	75
25°	245	245	245	247	248	113
35°	217	218	218	221	222	136
45°	182	184	185	187	188	140
55°	142	144	147	149	150	127
65°	98	99	103	107	109	97
75°	50	52	60	67	70	53
85°	9	16	27	36	39	11
90°	0	6	16	24	27	0
95°	0	2	8	15	17	0
105°	0	0	1	4	5	0
115°	0	0	0	1	1	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517762

CATALOG NUMBER: HVL8-1-LD4-1STD-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	275.2	275.2	275.2	275.2	275.2
2.5°	275.5	275.1	273.9	275.1	275.0
5°	274.6	274.1	272.8	274.1	274.1
7.5°	272.8	272.6	271.5	273.0	273.0
10°	270.6	270.6	269.7	271.3	271.3
12.5°	267.7	267.9	267.1	268.6	268.8
15°	264.1	264.6	263.9	265.4	265.3
17.5°	260.3	260.6	260.1	261.7	261.7
20°	255.6	255.9	255.5	257.3	257.5
22.5°	250.3	250.8	250.7	252.5	253.1
25°	244.8	244.9	245.2	247.3	247.7
27.5°	238.6	238.9	239.4	241.2	241.6
30°	231.8	232.4	232.9	234.8	235.3
32.5°	224.7	225.2	225.9	228.4	228.7
35°	216.7	217.6	218.5	220.8	221.7
37.5°	208.6	209.9	210.7	213.0	213.7
40°	200.1	201.4	202.7	205.2	205.6
42.5°	191.2	192.7	194.3	196.5	197.3
45°	182.3	183.9	185.4	187.2	188.1
47.5°	172.6	174.2	176.1	178.1	178.7
50°	162.6	164.5	166.5	168.4	169.4
52.5°	152.4	154.6	156.9	158.9	159.9
55°	142.3	143.9	146.6	148.7	149.7
57.5°	131.7	133.2	135.6	139.1	139.6
60°	121.0	122.3	124.8	127.7	128.8
62.5°	109.2	111.0	113.6	117.2	118.3
65°	97.8	99.4	102.9	107.0	108.7
67.5°	86.7	87.2	91.7	95.9	98.7
70°	73.6	75.8	80.9	86.1	88.2
72.5°	62.3	64.5	70.1	76.3	78.9
75°	49.5	52.5	60.2	67.4	69.9
77.5°	38.3	41.6	51.1	58.4	61.3
80°	26.7	32.0	42.3	50.5	53.6
82.5°	16.8	23.3	34.3	42.9	45.7
85°	8.6	15.8	27.2	35.9	39.1
87.5°	2.3	10.2	21.1	29.5	32.8
90°	0.1	5.9	16.0	24.1	27.0
92.5°	0.1	3.3	11.9	19.1	22.1
95°	0.1	1.6	8.3	15.0	17.4
97.5°	0.1	0.6	5.7	11.4	13.7
100°	0.1	0.3	3.6	8.2	10.2
102.5°	0.1	0.2	2.3	5.9	7.5
105°	0.1	0.2	1.4	4.0	5.4
107.5°	0.1	0.2	0.8	2.7	3.7
110°	0.2	0.2	0.5	1.7	2.5

TEST NUMBER: P517762

CATALOG NUMBER: HVL8-1-LD4-1STD-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.2	0.2	0.3	1.1	1.6
115°	0.2	0.2	0.3	0.7	1.0
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)