

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517822

Luminaire Tested: HVL8-1-LD4-3HI-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517822
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-3HI-30-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3055.0 lumens
Efficiency: N/A
Efficacy: 97.0 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 31.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517822

CATALOG NUMBER: HVL8-1-LD4-3HI-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517822

CATALOG NUMBER: HVL8-1-LD4-3HI-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	16314	16314	16314
5°	16107	15829	15965
10°	15826	15432	15646
15°	15519	15012	15262
20°	15203	14559	14889
25°	14856	14103	14509
30°	14478	13624	14079
35°	14043	13112	13652
40°	13587	12578	13155
45°	13099	12007	12618
50°	12512	11362	12041
55°	11878	10665	11402
60°	11138	9798	10658
65°	10103	8844	9923
70°	8745	7748	9064
75°	6988	6566	8287
80°	4689	5406	7575
85°	2002	4232	6895

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 13099 cd/sqm

TEST NUMBER: P517822

CATALOG NUMBER: HVL8-1-LD4-3HI-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	95.6	3.1
10°-20°	274.3	9.0
20°-30°	416.2	13.6
30°-40°	503.2	16.5
40°-50°	525.1	17.2
50°-60°	480.1	15.7
60°-70°	374.2	12.2
70°-80°	234.1	7.7
80°-90°	106.3	3.5
90°-100°	35.6	1.2
100°-110°	9.0	0.3
110°-120°	1.4	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	786.0	25.7
0°-40°	1289.2	42.2
0°-60°	2294.4	75.1
0°-90°	3009.0	98.5
90°-120°	46.0	1.5
90°-150°	46.0	1.5
90°-180°	46.0	1.5
0°-180°	3055.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1010	1010	1010	1010	1010	
5°	1008	1006	1002	1007	1007	96
15°	970	972	969	974	974	274
25°	899	899	900	908	909	414
35°	796	799	802	811	814	498
45°	669	675	681	687	691	516
55°	522	528	538	546	550	467
65°	359	365	378	393	399	355
75°	182	193	221	248	257	194
85°	31	58	100	132	144	40
90°	0	22	59	88	99	1
95°	0	6	30	55	64	0
105°	0	1	5	15	20	1
115°	1	1	1	3	4	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517822

CATALOG NUMBER: HVL8-1-LD4-3HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1010.4	1010.4	1010.4	1010.4	1010.4
2.5°	1011.6	1010.2	1005.6	1010.2	1009.9
5°	1008.3	1006.4	1001.8	1006.6	1006.6
7.5°	1001.6	1000.9	996.8	1002.3	1002.3
10°	993.7	993.5	990.2	996.1	996.4
12.5°	982.8	983.7	980.6	986.4	987.1
15°	969.9	971.6	969.0	974.4	974.2
17.5°	955.9	956.8	954.9	961.1	960.9
20°	938.5	939.7	938.2	944.7	945.4
22.5°	919.2	920.8	920.6	927.3	929.2
25°	898.7	899.4	900.4	908.0	909.4
27.5°	876.1	877.3	878.9	885.8	887.3
30°	851.3	853.2	855.1	862.3	864.2
32.5°	825.1	827.0	829.4	838.7	839.6
35°	795.6	799.1	802.5	810.6	813.9
37.5°	766.0	770.6	773.6	782.2	784.8
40°	734.8	739.3	744.3	753.4	755.1
42.5°	702.2	707.4	713.4	721.5	724.3
45°	669.3	675.3	680.8	687.4	690.8
47.5°	633.8	639.8	646.5	654.1	656.2
50°	597.1	604.1	611.2	618.3	622.2
52.5°	559.5	567.8	575.9	583.6	587.1
55°	522.4	528.5	538.3	546.2	549.7
57.5°	483.8	489.0	497.8	510.7	512.6
60°	444.5	449.2	458.3	468.8	473.0
62.5°	401.1	407.5	417.1	430.4	434.2
65°	359.0	365.1	377.8	392.8	399.0
67.5°	318.2	320.4	336.6	352.3	362.3
70°	270.1	278.2	297.0	316.3	323.9
72.5°	228.7	236.8	257.5	280.1	289.6
75°	181.7	192.9	221.0	247.5	256.8
77.5°	140.5	152.9	187.7	214.4	225.1
80°	98.1	117.4	155.3	185.3	197.0
82.5°	61.7	85.5	126.0	157.4	167.7
85°	31.4	58.1	99.8	132.0	143.6
87.5°	8.3	37.6	77.7	108.4	120.3
90°	0.2	21.7	58.8	88.4	99.1
92.5°	0.2	12.1	43.8	70.3	81.2
95°	0.2	5.7	30.5	55.3	63.8
97.5°	0.2	2.4	21.0	41.7	50.3
100°	0.2	1.2	13.3	30.3	37.6
102.5°	0.5	0.7	8.3	21.7	27.6
105°	0.5	0.7	5.0	14.8	19.8
107.5°	0.5	0.7	2.9	10.0	13.6
110°	0.7	0.7	1.7	6.2	9.1

TEST NUMBER: P517822

CATALOG NUMBER: HVL8-1-LD4-3HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.7	0.7	1.0	4.0	6.0
115°	0.7	0.7	1.0	2.6	3.8
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)