

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517825

Luminaire Tested: HVL8-1-LD4-3HI-35-UNV-O-EDD-90

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517825
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-3HI-35-UNV-O-EDD-90
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 90 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3207.1 lumens
Efficiency: N/A
Efficacy: 101.8 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 31.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517825

CATALOG NUMBER: HVL8-1-LD4-3HI-35-UNV-O-EDD-90

Luminous Intensity Polar Plot



TEST NUMBER: P517825

CATALOG NUMBER: HVL8-1-LD4-3HI-35-UNV-O-EDD-90

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		0
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		98
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		81
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		67
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		56
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		47
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		41
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		36
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		32
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		28
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		25
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	17126	17126	17126
5°	16907	16617	16760
10°	16615	16199	16423
15°	16292	15759	16021
20°	15959	15283	15629
25°	15594	14804	15232
30°	15199	14303	14780
35°	14740	13764	14331
40°	14264	13204	13808
45°	13751	12603	13245
50°	13137	11927	12639
55°	12466	11196	11970
60°	11692	10286	11190
65°	10604	9284	10415
70°	9179	8134	9517
75°	7338	6893	8697
80°	4923	5674	7952
85°	2104	4444	7241

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 13751 cd/sqm

TEST NUMBER: P517825

CATALOG NUMBER: HVL8-1-LD4-3HI-35-UNV-O-EDD-90

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	100.4	3.1
10°-20°	287.9	9.0
20°-30°	436.9	13.6
30°-40°	528.2	16.5
40°-50°	551.2	17.2
50°-60°	503.9	15.7
60°-70°	392.8	12.2
70°-80°	245.7	7.7
80°-90°	111.6	3.5
90°-100°	37.4	1.2
100°-110°	9.4	0.3
110°-120°	1.5	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	825.2	25.7
0°-40°	1353.4	42.2
0°-60°	2408.5	75.1
0°-90°	3158.7	98.5
90°-120°	48.4	1.5
90°-150°	48.4	1.5
90°-180°	48.0	1.5
0°-180°	3207.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1061	1061	1061	1061	1061	
5°	1058	1056	1052	1057	1057	101
15°	1018	1020	1017	1023	1023	287
25°	943	944	945	953	955	435
35°	835	839	842	851	854	523
45°	703	709	715	722	725	541
55°	548	555	565	573	577	490
65°	377	383	397	412	419	373
75°	191	202	232	260	270	203
85°	33	61	105	138	151	42
90°	0	23	62	93	104	1
95°	0	6	32	58	67	0
105°	0	1	5	16	21	1
115°	1	1	1	3	4	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517825

CATALOG NUMBER: HVL8-1-LD4-3HI-35-UNV-O-EDD-90

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1060.7	1060.7	1060.7	1060.7	1060.7
2.5°	1061.9	1060.4	1055.7	1060.4	1060.2
5°	1058.4	1056.4	1051.7	1056.7	1056.7
7.5°	1051.4	1050.7	1046.4	1052.2	1052.2
10°	1043.2	1042.9	1039.4	1045.7	1045.9
12.5°	1031.7	1032.7	1029.4	1035.4	1036.2
15°	1018.2	1019.9	1017.2	1022.9	1022.7
17.5°	1003.4	1004.4	1002.4	1008.9	1008.7
20°	985.2	986.4	984.9	991.7	992.4
22.5°	964.9	966.7	966.4	973.4	975.4
25°	943.4	944.2	945.2	953.2	954.7
27.5°	919.7	920.9	922.7	929.9	931.4
30°	893.7	895.7	897.7	905.2	907.2
32.5°	866.1	868.1	870.6	880.4	881.4
35°	835.1	838.9	842.4	850.9	854.4
37.5°	804.1	808.9	812.1	821.1	823.9
40°	771.4	776.1	781.4	790.9	792.6
42.5°	737.1	742.6	748.9	757.4	760.4
45°	702.6	708.9	714.6	721.6	725.1
47.5°	665.4	671.6	678.6	686.6	688.9
50°	626.9	634.1	641.6	649.1	653.1
52.5°	587.4	596.1	604.6	612.6	616.4
55°	548.3	554.8	565.1	573.3	577.1
57.5°	507.8	513.3	522.6	536.1	538.1
60°	466.6	471.6	481.1	492.1	496.6
62.5°	421.1	427.8	437.8	451.8	455.8
65°	376.8	383.3	396.6	412.3	418.8
67.5°	334.1	336.3	353.3	369.8	380.3
70°	283.5	292.1	311.8	332.1	340.1
72.5°	240.0	248.5	270.3	294.1	304.1
75°	190.8	202.5	232.0	259.8	269.5
77.5°	147.5	160.5	197.0	225.0	236.3
80°	103.0	123.3	163.0	194.5	206.8
82.5°	64.8	89.8	132.3	165.3	176.0
85°	33.0	61.0	104.8	138.5	150.8
87.5°	8.8	39.5	81.5	113.8	126.3
90°	0.3	22.8	61.8	92.8	104.0
92.5°	0.3	12.8	46.0	73.8	85.3
95°	0.3	6.0	32.0	58.0	67.0
97.5°	0.3	2.5	22.0	43.8	52.8
100°	0.3	1.3	14.0	31.8	39.5
102.5°	0.5	0.8	8.8	22.8	29.0
105°	0.5	0.8	5.3	15.5	20.8
107.5°	0.5	0.8	3.0	10.5	14.3
110°	0.8	0.8	1.8	6.5	9.5

TEST NUMBER: P517825

CATALOG NUMBER: HVL8-1-LD4-3HI-35-UNV-O-EDD-90

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.8	0.8	1.0	4.3	6.3
115°	0.8	0.8	1.0	2.8	4.0
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)