

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517842

Luminaire Tested: HVL8-1-LD4-3LO-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517842
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-3LO-35-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1934.0 lumens
Efficiency: N/A
Efficacy: 115.1 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 16.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517842

CATALOG NUMBER: HVL8-1-LD4-3LO-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517842

CATALOG NUMBER: HVL8-1-LD4-3LO-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	10329	10329	10329
5°	10197	10020	10106
10°	10020	9769	9905
15°	9824	9503	9661
20°	9624	9218	9426
25°	9404	8928	9185
30°	9165	8624	8913
35°	8889	8300	8642
40°	8602	7963	8328
45°	8292	7601	7988
50°	7921	7192	7623
55°	7519	6752	7218
60°	7051	6202	6749
65°	6394	5600	6282
70°	5537	4904	5739
75°	4426	4156	5247
80°	2968	3422	4795
85°	1269	2680	4365

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8292 cd/sqm

TEST NUMBER: P517842

CATALOG NUMBER: HVL8-1-LD4-3LO-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	60.5	3.1
10°-20°	173.6	9.0
20°-30°	263.5	13.6
30°-40°	318.6	16.5
40°-50°	332.4	17.2
50°-60°	303.9	15.7
60°-70°	236.9	12.2
70°-80°	148.2	7.7
80°-90°	67.3	3.5
90°-100°	22.6	1.2
100°-110°	5.7	0.3
110°-120°	0.9	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	497.6	25.7
0°-40°	816.2	42.2
0°-60°	1452.5	75.1
0°-90°	1904.9	98.5
90°-120°	29.1	1.5
90°-150°	29.1	1.5
90°-180°	29.0	1.5
0°-180°	1934.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	640	640	640	640	640	
5°	638	637	634	637	637	61
15°	614	615	613	617	617	173
25°	569	569	570	575	576	262
35°	504	506	508	513	515	315
45°	424	428	431	435	437	326
55°	331	335	341	346	348	295
65°	227	231	239	249	253	225
75°	115	122	140	157	163	123
85°	20	37	63	84	91	25
90°	0	14	37	56	63	1
95°	0	4	19	35	40	0
105°	0	0	3	9	12	0
115°	0	0	1	2	2	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517842

CATALOG NUMBER: HVL8-1-LD4-3LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	639.7	639.7	639.7	639.7	639.7
2.5°	640.4	639.5	636.6	639.5	639.3
5°	638.3	637.1	634.2	637.2	637.2
7.5°	634.1	633.6	631.1	634.5	634.5
10°	629.1	628.9	626.8	630.6	630.8
12.5°	622.2	622.8	620.8	624.4	624.9
15°	614.0	615.1	613.4	616.9	616.7
17.5°	605.1	605.7	604.5	608.4	608.3
20°	594.1	594.9	594.0	598.0	598.5
22.5°	581.9	583.0	582.8	587.0	588.2
25°	568.9	569.4	570.0	574.8	575.7
27.5°	554.6	555.4	556.4	560.8	561.7
30°	538.9	540.1	541.3	545.9	547.1
32.5°	522.3	523.5	525.1	530.9	531.5
35°	503.6	505.9	508.0	513.1	515.2
37.5°	484.9	487.8	489.8	495.2	496.9
40°	465.2	468.1	471.2	476.9	478.0
42.5°	444.5	447.8	451.6	456.7	458.6
45°	423.7	427.5	431.0	435.2	437.3
47.5°	401.3	405.0	409.2	414.1	415.4
50°	378.0	382.4	386.9	391.5	393.9
52.5°	354.2	359.5	364.6	369.4	371.7
55°	330.7	334.6	340.8	345.8	348.0
57.5°	306.3	309.6	315.2	323.3	324.5
60°	281.4	284.4	290.1	296.8	299.5
62.5°	253.9	258.0	264.0	272.5	274.9
65°	227.2	231.2	239.2	248.7	252.6
67.5°	201.5	202.8	213.1	223.0	229.4
70°	171.0	176.1	188.0	200.2	205.1
72.5°	144.8	149.9	163.0	177.3	183.4
75°	115.1	122.1	139.9	156.7	162.6
77.5°	89.0	96.8	118.8	135.7	142.5
80°	62.1	74.3	98.3	117.3	124.7
82.5°	39.1	54.1	79.8	99.7	106.2
85°	19.9	36.8	63.2	83.5	90.9
87.5°	5.3	23.8	49.2	68.6	76.1
90°	0.2	13.7	37.2	55.9	62.7
92.5°	0.2	7.7	27.7	44.5	51.4
95°	0.2	3.6	19.3	35.0	40.4
97.5°	0.2	1.5	13.3	26.4	31.8
100°	0.2	0.8	8.4	19.2	23.8
102.5°	0.3	0.5	5.3	13.7	17.5
105°	0.3	0.5	3.2	9.3	12.5
107.5°	0.3	0.5	1.8	6.3	8.6
110°	0.5	0.5	1.1	3.9	5.7

TEST NUMBER: P517842

CATALOG NUMBER: HVL8-1-LD4-3LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	0.5	0.6	2.6	3.8
115°	0.5	0.5	0.6	1.7	2.4
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)