

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517846

Luminaire Tested: HVL8-1-LD4-3LO-40-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517846
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-3LO-40-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1954.0 lumens
Efficiency: N/A
Efficacy: 116.3 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 16.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517846

CATALOG NUMBER: HVL8-1-LD4-3LO-40-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517846

CATALOG NUMBER: HVL8-1-LD4-3LO-40-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	10435	10435	10435
5°	10302	10125	10211
10°	10123	9870	10007
15°	9927	9602	9761
20°	9724	9312	9523
25°	9501	9020	9281
30°	9260	8714	9004
35°	8980	8387	8732
40°	8691	8045	8413
45°	8378	7679	8070
50°	8003	7267	7700
55°	7596	6821	7293
60°	7124	6266	6818
65°	6462	5656	6347
70°	5595	4956	5798
75°	4469	4201	5299
80°	3002	3456	4845
85°	1282	2706	4413

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8378 cd/sqm

TEST NUMBER: P517846

CATALOG NUMBER: HVL8-1-LD4-3LO-40-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	61.2	3.1
10°-20°	175.4	9.0
20°-30°	266.2	13.6
30°-40°	321.8	16.5
40°-50°	335.8	17.2
50°-60°	307.0	15.7
60°-70°	239.4	12.2
70°-80°	149.7	7.7
80°-90°	68.0	3.5
90°-100°	22.8	1.2
100°-110°	5.7	0.3
110°-120°	0.9	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	502.8	25.7
0°-40°	824.6	42.2
0°-60°	1467.5	75.1
0°-90°	1924.6	98.5
90°-120°	29.4	1.5
90°-150°	29.4	1.5
90°-180°	29.0	1.5
0°-180°	1954.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	646	646	646	646	646	
5°	645	644	641	644	644	61
15°	620	621	620	623	623	175
25°	575	575	576	581	582	265
35°	509	511	513	518	521	318
45°	428	432	435	440	442	330
55°	334	338	344	349	352	298
65°	230	234	242	251	255	227
75°	116	123	141	158	164	124
85°	20	37	64	84	92	25
90°	0	14	38	56	63	1
95°	0	4	20	35	41	0
105°	0	0	3	9	13	0
115°	0	0	1	2	2	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517846

CATALOG NUMBER: HVL8-1-LD4-3LO-40-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	646.3	646.3	646.3	646.3	646.3
2.5°	647.0	646.1	643.2	646.1	646.0
5°	644.9	643.7	640.8	643.8	643.8
7.5°	640.6	640.2	637.6	641.1	641.1
10°	635.6	635.4	633.3	637.1	637.3
12.5°	628.6	629.2	627.2	630.9	631.3
15°	620.4	621.4	619.8	623.3	623.1
17.5°	611.4	612.0	610.8	614.7	614.6
20°	600.3	601.0	600.1	604.2	604.7
22.5°	587.9	589.0	588.8	593.1	594.3
25°	574.8	575.3	575.9	580.8	581.7
27.5°	560.3	561.1	562.2	566.6	567.5
30°	544.5	545.7	546.9	551.5	552.7
32.5°	527.7	529.0	530.5	536.4	537.0
35°	508.8	511.1	513.3	518.4	520.6
37.5°	490.0	492.8	494.8	500.3	502.0
40°	470.0	472.9	476.1	481.9	482.9
42.5°	449.1	452.5	456.3	461.5	463.3
45°	428.1	431.9	435.4	439.7	441.8
47.5°	405.4	409.2	413.5	418.4	419.7
50°	381.9	386.4	390.9	395.5	397.9
52.5°	357.9	363.2	368.4	373.3	375.5
55°	334.1	338.1	344.3	349.3	351.6
57.5°	309.4	312.8	318.4	326.6	327.9
60°	284.3	287.3	293.1	299.8	302.6
62.5°	256.6	260.7	266.8	275.3	277.7
65°	229.6	233.6	241.6	251.2	255.2
67.5°	203.5	204.9	215.3	225.3	231.7
70°	172.8	177.9	190.0	202.3	207.2
72.5°	146.3	151.4	164.7	179.2	185.3
75°	116.2	123.4	141.4	158.3	164.2
77.5°	89.9	97.8	120.1	137.1	144.0
80°	62.8	75.1	99.3	118.5	126.0
82.5°	39.5	54.7	80.6	100.7	107.3
85°	20.1	37.2	63.8	84.4	91.9
87.5°	5.3	24.1	49.7	69.3	76.9
90°	0.2	13.9	37.6	56.5	63.4
92.5°	0.2	7.8	28.0	44.9	52.0
95°	0.2	3.7	19.5	35.3	40.8
97.5°	0.2	1.5	13.4	26.7	32.1
100°	0.2	0.8	8.5	19.3	24.1
102.5°	0.3	0.5	5.3	13.9	17.7
105°	0.3	0.5	3.2	9.4	12.6
107.5°	0.3	0.5	1.8	6.4	8.7
110°	0.5	0.5	1.1	4.0	5.8

TEST NUMBER: P517846

CATALOG NUMBER: HVL8-1-LD4-3LO-40-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	0.5	0.6	2.6	3.8
115°	0.5	0.5	0.6	1.7	2.4
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)