

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517854

Luminaire Tested: HVL8-1-LD4-3STD-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517854
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-3STD-30-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2374.0 lumens
Efficiency: N/A
Efficacy: 99.3 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 23.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517854

CATALOG NUMBER: HVL8-1-LD4-3STD-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517854

CATALOG NUMBER: HVL8-1-LD4-3STD-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	12678	12678	12678
5°	12516	12300	12406
10°	12299	11991	12159
15°	12060	11666	11859
20°	11814	11314	11569
25°	11545	10959	11275
30°	11250	10587	10940
35°	10911	10189	10609
40°	10558	9774	10223
45°	10179	9330	9805
50°	9723	8830	9357
55°	9229	8287	8861
60°	8655	7613	8283
65°	7849	6873	7709
70°	6796	6021	7043
75°	5430	5104	6438
80°	3647	4201	5887
85°	1556	3291	5359

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 10179 cd/sqm

TEST NUMBER: P517854

CATALOG NUMBER: HVL8-1-LD4-3STD-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	74.3	3.1
10°-20°	213.1	9.0
20°-30°	323.4	13.6
30°-40°	391.0	16.5
40°-50°	408.0	17.2
50°-60°	373.0	15.7
60°-70°	290.8	12.2
70°-80°	181.9	7.7
80°-90°	82.6	3.5
90°-100°	27.7	1.2
100°-110°	7.0	0.3
110°-120°	1.1	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	610.8	25.7
0°-40°	1001.9	42.2
0°-60°	1782.9	75.1
0°-90°	2338.3	98.5
90°-120°	35.8	1.5
90°-150°	35.8	1.5
90°-180°	36.0	1.5
0°-180°	2374.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	785	785	785	785	785	
5°	784	782	778	782	782	74
15°	754	755	753	757	757	213
25°	698	699	700	706	707	322
35°	618	621	624	630	632	387
45°	520	525	529	534	537	401
55°	406	411	418	424	427	363
65°	279	284	294	305	310	276
75°	141	150	172	192	200	151
85°	24	45	78	102	112	31
90°	0	17	46	69	77	1
95°	0	4	24	43	50	0
105°	0	1	4	12	15	0
115°	1	1	1	2	3	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517854

CATALOG NUMBER: HVL8-1-LD4-3STD-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	785.2	785.2	785.2	785.2	785.2
2.5°	786.1	785.0	781.5	785.0	784.8
5°	783.5	782.0	778.5	782.2	782.2
7.5°	778.3	777.8	774.6	778.9	778.9
10°	772.2	772.0	769.4	774.1	774.3
12.5°	763.7	764.4	762.0	766.5	767.0
15°	753.7	755.0	753.0	757.2	757.0
17.5°	742.8	743.5	742.0	746.9	746.7
20°	729.3	730.2	729.1	734.1	734.6
22.5°	714.3	715.6	715.4	720.6	722.1
25°	698.4	698.9	699.7	705.6	706.7
27.5°	680.8	681.7	683.0	688.4	689.5
30°	661.5	663.0	664.5	670.0	671.5
32.5°	641.2	642.7	644.5	651.7	652.5
35°	618.2	621.0	623.6	629.9	632.5
37.5°	595.3	598.8	601.2	607.9	609.9
40°	571.0	574.5	578.4	585.5	586.8
42.5°	545.7	549.7	554.4	560.7	562.9
45°	520.1	524.7	529.0	534.2	536.8
47.5°	492.5	497.2	502.3	508.3	509.9
50°	464.0	469.4	475.0	480.5	483.5
52.5°	434.8	441.3	447.6	453.5	456.3
55°	405.9	410.7	418.3	424.4	427.2
57.5°	375.9	380.0	386.8	396.8	398.3
60°	345.4	349.1	356.1	364.3	367.6
62.5°	311.7	316.7	324.1	334.5	337.4
65°	278.9	283.8	293.6	305.2	310.0
67.5°	247.3	249.0	261.5	273.8	281.5
70°	209.9	216.2	230.8	245.8	251.7
72.5°	177.7	184.0	200.1	217.7	225.1
75°	141.2	149.9	171.8	192.3	199.5
77.5°	109.2	118.8	145.9	166.6	174.9
80°	76.3	91.3	120.7	144.0	153.1
82.5°	47.9	66.4	97.9	122.3	130.3
85°	24.4	45.2	77.6	102.5	111.6
87.5°	6.5	29.2	60.3	84.2	93.5
90°	0.2	16.8	45.7	68.7	77.0
92.5°	0.2	9.4	34.1	54.6	63.1
95°	0.2	4.4	23.7	42.9	49.6
97.5°	0.2	1.9	16.3	32.4	39.1
100°	0.2	0.9	10.4	23.5	29.2
102.5°	0.4	0.6	6.5	16.8	21.5
105°	0.4	0.6	3.9	11.5	15.4
107.5°	0.4	0.6	2.2	7.8	10.6
110°	0.6	0.6	1.3	4.8	7.0

TEST NUMBER: P517854

CATALOG NUMBER: HVL8-1-LD4-3STD-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.6	0.6	0.7	3.1	4.6
115°	0.6	0.6	0.7	2.0	3.0
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)