

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517862

Luminaire Tested: HVL8-1-LD4-3STD-40-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517862
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-1-LD4-3STD-40-UNV-O-EDD
Description: 1 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2517.0 lumens
Efficiency: N/A
Efficacy: 105.3 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 1' x H: 0.17')
CIE Type: Direct


Input Watts (W): 23.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517862

CATALOG NUMBER: HVL8-1-LD4-3STD-40-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517862

CATALOG NUMBER: HVL8-1-LD4-3STD-40-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	13441	13441	13441
5°	13270	13041	13153
10°	13039	12714	12890
15°	12786	12367	12573
20°	12525	11995	12267
25°	12239	11619	11955
30°	11929	11225	11600
35°	11570	10802	11248
40°	11194	10364	10838
45°	10792	9892	10395
50°	10310	9362	9920
55°	9786	8786	9394
60°	9176	8073	8781
65°	8322	7285	8174
70°	7204	6383	7469
75°	5757	5410	6828
80°	3867	4455	6241
85°	1651	3486	5680

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 10792 cd/sqm

TEST NUMBER: P517862

CATALOG NUMBER: HVL8-1-LD4-3STD-40-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	78.8	3.1
10°-20°	226.0	9.0
20°-30°	342.9	13.6
30°-40°	414.6	16.5
40°-50°	432.6	17.2
50°-60°	395.5	15.7
60°-70°	308.3	12.2
70°-80°	192.9	7.7
80°-90°	87.6	3.5
90°-100°	29.4	1.2
100°-110°	7.4	0.3
110°-120°	1.2	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	647.6	25.7
0°-40°	1062.2	42.2
0°-60°	1890.3	75.1
0°-90°	2479.1	98.5
90°-120°	37.9	1.5
90°-150°	37.9	1.5
90°-180°	38.0	1.5
0°-180°	2517.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	832	832	832	832	832	
5°	831	829	825	829	829	79
15°	799	800	798	803	803	226
25°	740	741	742	748	749	341
35°	656	658	661	668	671	410
45°	551	556	561	566	569	425
55°	430	436	444	450	453	385
65°	296	301	311	324	329	293
75°	150	159	182	204	212	160
85°	26	48	82	109	118	33
90°	0	18	48	73	82	1
95°	0	5	25	46	53	0
105°	0	1	4	12	16	0
115°	1	1	1	2	3	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517862

CATALOG NUMBER: HVL8-1-LD4-3STD-40-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	832.5	832.5	832.5	832.5	832.5
2.5°	833.5	832.3	828.5	832.3	832.1
5°	830.7	829.1	825.4	829.3	829.3
7.5°	825.2	824.6	821.3	825.8	825.8
10°	818.7	818.5	815.8	820.7	820.9
12.5°	809.7	810.5	807.9	812.7	813.2
15°	799.1	800.5	798.3	802.8	802.6
17.5°	787.5	788.3	786.7	791.8	791.7
20°	773.2	774.2	773.0	778.3	778.9
22.5°	757.3	758.7	758.5	764.0	765.6
25°	740.4	741.0	741.8	748.1	749.3
27.5°	721.8	722.8	724.1	729.8	731.0
30°	701.4	702.9	704.5	710.4	712.0
32.5°	679.8	681.4	683.3	691.0	691.8
35°	655.5	658.4	661.1	667.8	670.6
37.5°	631.1	634.9	637.4	644.5	646.6
40°	605.4	609.1	613.3	620.7	622.1
42.5°	578.5	582.8	587.8	594.4	596.8
45°	551.4	556.4	560.9	566.4	569.1
47.5°	522.2	527.1	532.6	538.9	540.7
50°	492.0	497.7	503.6	509.5	512.6
52.5°	461.0	467.8	474.5	480.8	483.7
55°	430.4	435.5	443.5	450.0	452.9
57.5°	398.6	402.9	410.2	420.7	422.3
60°	366.2	370.1	377.6	386.2	389.7
62.5°	330.5	335.8	343.6	354.6	357.8
65°	295.7	300.8	311.2	323.6	328.7
67.5°	262.2	263.9	277.3	290.2	298.5
70°	222.5	229.2	244.7	260.6	266.9
72.5°	188.4	195.1	212.1	230.8	238.6
75°	149.7	159.0	182.1	203.9	211.6
77.5°	115.8	126.0	154.6	176.6	185.5
80°	80.9	96.7	128.0	152.7	162.3
82.5°	50.8	70.5	103.8	129.7	138.2
85°	25.9	47.9	82.2	108.7	118.3
87.5°	6.9	31.0	64.0	89.3	99.1
90°	0.2	17.9	48.5	72.8	81.6
92.5°	0.2	10.0	36.1	57.9	66.9
95°	0.2	4.7	25.1	45.5	52.6
97.5°	0.2	2.0	17.3	34.3	41.4
100°	0.2	1.0	11.0	24.9	31.0
102.5°	0.4	0.6	6.9	17.9	22.8
105°	0.4	0.6	4.1	12.2	16.3
107.5°	0.4	0.6	2.4	8.2	11.2
110°	0.6	0.6	1.4	5.1	7.5

TEST NUMBER: P517862

CATALOG NUMBER: HVL8-1-LD4-3STD-40-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.6	0.6	0.8	3.3	4.9
115°	0.6	0.6	0.8	2.2	3.1
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)