

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517918

Luminaire Tested: HVL8-2-LD4-2HI-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517918
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-2-LD4-2HI-30-UNV-O-EDD
Description: 2 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3358.0 lumens
Efficiency: N/A
Efficacy: 77.9 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 2' x H: 0.17')
CIE Type: Direct

Input Watts (W): 43.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517918
CATALOG NUMBER: HVL8-2-LD4-2HI-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517918

CATALOG NUMBER: HVL8-2-LD4-2HI-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		87
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		60
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		54
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	8966	8966	8966
5°	8916	8744	8774
10°	8824	8566	8599
15°	8716	8373	8387
20°	8602	8160	8182
25°	8470	7943	7974
30°	8322	7712	7738
35°	8143	7462	7503
40°	7956	7199	7230
45°	7753	6913	6935
50°	7499	6587	6617
55°	7222	6230	6267
60°	6892	5775	5859
65°	6395	5268	5452
70°	5702	4677	4982
75°	4753	4032	4553
80°	3406	3396	4162
85°	1641	2750	3791

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 7753 cd/sqm

TEST NUMBER: P517918

CATALOG NUMBER: HVL8-2-LD4-2HI-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	105.1	3.1
10°-20°	301.5	9.0
20°-30°	457.4	13.6
30°-40°	553.1	16.5
40°-50°	577.1	17.2
50°-60°	527.7	15.7
60°-70°	411.3	12.2
70°-80°	257.3	7.7
80°-90°	116.9	3.5
90°-100°	39.2	1.2
100°-110°	9.8	0.3
110°-120°	1.5	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	864.0	25.7
0°-40°	1417.1	42.2
0°-60°	2521.9	75.1
0°-90°	3307.4	98.5
90°-120°	50.6	1.5
90°-150°	50.6	1.5
90°-180°	51.0	1.5
0°-180°	3358.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1111	1111	1111	1111	1111	
5°	1108	1106	1101	1106	1106	105
15°	1066	1068	1065	1071	1071	301
25°	988	989	990	998	1000	455
35°	874	878	882	891	895	547
45°	736	742	748	756	759	567
55°	574	581	592	600	604	513
65°	395	401	415	432	438	390
75°	200	212	243	272	282	213
85°	35	64	110	145	158	44
90°	0	24	65	97	109	1
95°	0	6	34	61	70	0
105°	0	1	6	16	22	1
115°	1	1	1	3	4	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517918

CATALOG NUMBER: HVL8-2-LD4-2HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1110.6	1110.6	1110.6	1110.6	1110.6
2.5°	1111.9	1110.4	1105.4	1110.4	1110.1
5°	1108.3	1106.2	1101.2	1106.4	1106.4
7.5°	1100.9	1100.2	1095.7	1101.7	1101.7
10°	1092.3	1092.0	1088.4	1094.9	1095.2
12.5°	1080.3	1081.3	1077.9	1084.2	1085.0
15°	1066.1	1067.9	1065.1	1071.1	1070.8
17.5°	1050.7	1051.7	1049.6	1056.4	1056.2
20°	1031.6	1032.9	1031.3	1038.4	1039.1
22.5°	1010.3	1012.2	1011.9	1019.2	1021.3
25°	987.8	988.6	989.7	998.0	999.6
27.5°	963.0	964.3	966.1	973.7	975.3
30°	935.7	937.8	939.9	947.8	949.9
32.5°	906.9	909.0	911.6	921.9	922.9
35°	874.5	878.4	882.1	891.0	894.6
37.5°	842.0	847.0	850.4	859.8	862.7
40°	807.7	812.7	818.2	828.1	830.0
42.5°	771.8	777.6	784.1	793.0	796.2
45°	735.7	742.2	748.3	755.6	759.3
47.5°	696.7	703.2	710.6	718.9	721.3
50°	656.4	664.0	671.8	679.7	683.9
52.5°	615.0	624.2	633.1	641.4	645.4
55°	574.2	581.0	591.7	600.3	604.3
57.5°	531.7	537.5	547.2	561.3	563.4
60°	488.5	493.8	503.7	515.3	520.0
62.5°	440.9	448.0	458.4	473.1	477.3
65°	394.6	401.4	415.2	431.7	438.5
67.5°	349.8	352.1	369.9	387.2	398.2
70°	296.9	305.8	326.5	347.7	356.1
72.5°	251.3	260.2	283.0	307.9	318.4
75°	199.8	212.1	243.0	272.0	282.2
77.5°	154.5	168.1	206.3	235.6	247.4
80°	107.9	129.1	170.7	203.7	216.5
82.5°	67.8	94.0	138.5	173.1	184.3
85°	34.6	63.9	109.7	145.0	157.9
87.5°	9.2	41.4	85.4	119.1	132.2
90°	0.3	23.8	64.7	97.1	108.9
92.5°	0.3	13.4	48.2	77.2	89.3
95°	0.3	6.3	33.5	60.7	70.2
97.5°	0.3	2.6	23.0	45.8	55.2
100°	0.3	1.3	14.7	33.3	41.4
102.5°	0.5	0.8	9.2	23.8	30.4
105°	0.5	0.8	5.5	16.2	21.7
107.5°	0.5	0.8	3.1	11.0	14.9
110°	0.8	0.8	1.8	6.8	9.9

TEST NUMBER: P517918

CATALOG NUMBER: HVL8-2-LD4-2HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.8	0.8	1.0	4.5	6.5
115°	0.8	0.8	1.0	2.9	4.2
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)