

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517922

Luminaire Tested: HVL8-2-LD4-2HI-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517922
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-2-LD4-2HI-35-UNV-O-EDD
Description: 2 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3403.0 lumens
Efficiency: N/A
Efficacy: 79.0 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 2' x H: 0.17')
CIE Type: Direct


Input Watts (W): 43.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517922

CATALOG NUMBER: HVL8-2-LD4-2HI-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517922

CATALOG NUMBER: HVL8-2-LD4-2HI-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	9086	9086	9086
5°	9035	8861	8892
10°	8942	8681	8714
15°	8832	8485	8500
20°	8717	8269	8293
25°	8584	8049	8081
30°	8434	7815	7841
35°	8252	7561	7603
40°	8062	7294	7327
45°	7857	7006	7027
50°	7600	6675	6705
55°	7319	6314	6351
60°	6985	5853	5936
65°	6479	5339	5526
70°	5779	4740	5048
75°	4815	4085	4615
80°	3450	3442	4218
85°	1660	2788	3841

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 7857 cd/sqm

TEST NUMBER: P517922

CATALOG NUMBER: HVL8-2-LD4-2HI-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	106.5	3.1
10°-20°	305.5	9.0
20°-30°	463.6	13.6
30°-40°	560.5	16.5
40°-50°	584.9	17.2
50°-60°	534.7	15.7
60°-70°	416.9	12.2
70°-80°	260.8	7.7
80°-90°	118.4	3.5
90°-100°	39.7	1.2
100°-110°	10.0	0.3
110°-120°	1.6	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	875.6	25.7
0°-40°	1436.1	42.2
0°-60°	2555.7	75.1
0°-90°	3351.8	98.5
90°-120°	51.2	1.5
90°-150°	51.2	1.5
90°-180°	51.0	1.5
0°-180°	3403.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1126	1126	1126	1126	1126	
5°	1123	1121	1116	1121	1121	107
15°	1080	1082	1079	1085	1085	305
25°	1001	1002	1003	1011	1013	461
35°	886	890	894	903	907	555
45°	746	752	758	766	769	575
55°	582	589	600	608	612	520
65°	400	407	421	438	444	396
75°	202	215	246	276	286	216
85°	35	65	111	147	160	44
90°	0	24	66	98	110	1
95°	0	6	34	62	71	0
105°	0	1	6	16	22	1
115°	1	1	1	3	4	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517922

CATALOG NUMBER: HVL8-2-LD4-2HI-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1125.5	1125.5	1125.5	1125.5	1125.5
2.5°	1126.8	1125.2	1120.2	1125.2	1125.0
5°	1123.1	1121.0	1116.0	1121.3	1121.3
7.5°	1115.7	1114.9	1110.4	1116.5	1116.5
10°	1106.9	1106.7	1103.0	1109.6	1109.9
12.5°	1094.7	1095.8	1092.3	1098.7	1099.5
15°	1080.4	1082.3	1079.3	1085.4	1085.2
17.5°	1064.7	1065.8	1063.7	1070.6	1070.3
20°	1045.4	1046.7	1045.1	1052.3	1053.1
22.5°	1023.9	1025.7	1025.5	1032.9	1035.0
25°	1001.1	1001.9	1002.9	1011.4	1013.0
27.5°	975.9	977.2	979.0	986.7	988.3
30°	948.3	950.4	952.5	960.5	962.6
32.5°	919.1	921.2	923.9	934.2	935.3
35°	886.2	890.2	893.9	902.9	906.6
37.5°	853.3	858.3	861.8	871.3	874.2
40°	818.5	823.6	829.1	839.2	841.1
42.5°	782.2	788.0	794.6	803.7	806.9
45°	745.6	752.2	758.3	765.7	769.4
47.5°	706.0	712.7	720.1	728.6	731.0
50°	665.2	672.9	680.8	688.8	693.0
52.5°	623.2	632.5	641.6	650.0	654.0
55°	581.9	588.8	599.6	608.4	612.4
57.5°	538.9	544.7	554.5	568.9	571.0
60°	495.1	500.4	510.5	522.2	526.9
62.5°	446.8	454.0	464.6	479.4	483.7
65°	399.8	406.7	420.8	437.5	444.4
67.5°	354.5	356.9	374.9	392.4	403.6
70°	300.9	309.9	330.9	352.4	360.8
72.5°	254.7	263.7	286.8	312.0	322.6
75°	202.4	214.9	246.2	275.7	286.0
77.5°	156.5	170.3	209.1	238.8	250.7
80°	109.3	130.8	173.0	206.4	219.4
82.5°	68.7	95.3	140.4	175.4	186.8
85°	35.0	64.7	111.2	147.0	160.0
87.5°	9.3	41.9	86.5	120.7	134.0
90°	0.3	24.1	65.5	98.4	110.4
92.5°	0.3	13.5	48.8	78.3	90.5
95°	0.3	6.4	34.0	61.6	71.1
97.5°	0.3	2.7	23.3	46.4	56.0
100°	0.3	1.3	14.9	33.7	41.9
102.5°	0.5	0.8	9.3	24.1	30.8
105°	0.5	0.8	5.6	16.5	22.0
107.5°	0.5	0.8	3.2	11.1	15.1
110°	0.8	0.8	1.9	6.9	10.1

TEST NUMBER: P517922

CATALOG NUMBER: HVL8-2-LD4-2HI-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.8	0.8	1.1	4.5	6.6
115°	0.8	0.8	1.1	2.9	4.2
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)