

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517934

Luminaire Tested: HVL8-2-LD4-2LO-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517934
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-2-LD4-2LO-30-UNV-O-EDD
Description: 2 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2026.0 lumens
Efficiency: N/A
Efficacy: 87.7 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 2' x H: 0.17')
CIE Type: Direct


Input Watts (W): 23.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517934

CATALOG NUMBER: HVL8-2-LD4-2LO-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517934

CATALOG NUMBER: HVL8-2-LD4-2LO-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		0
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		98
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		81
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		67
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		56
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		47
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		41
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		36
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		32
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		28
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		25
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5410	5410	5410
5°	5380	5275	5294
10°	5324	5168	5188
15°	5258	5052	5061
20°	5190	4923	4937
25°	5110	4792	4811
30°	5021	4653	4668
35°	4913	4502	4527
40°	4800	4343	4361
45°	4678	4171	4184
50°	4524	3974	3992
55°	4357	3759	3781
60°	4159	3484	3534
65°	3859	3178	3290
70°	3440	2822	3005
75°	2867	2432	2748
80°	2055	2049	2511
85°	991	1660	2288

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4678 cd/sqm

TEST NUMBER: P517934

CATALOG NUMBER: HVL8-2-LD4-2LO-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	63.4	3.1
10°-20°	181.9	9.0
20°-30°	276.0	13.6
30°-40°	333.7	16.5
40°-50°	348.2	17.2
50°-60°	318.4	15.7
60°-70°	248.2	12.2
70°-80°	155.3	7.7
80°-90°	70.5	3.5
90°-100°	23.6	1.2
100°-110°	5.9	0.3
110°-120°	0.9	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	521.3	25.7
0°-40°	855.0	42.2
0°-60°	1521.6	75.1
0°-90°	1995.5	98.5
90°-120°	30.5	1.5
90°-150°	30.5	1.5
90°-180°	31.0	1.5
0°-180°	2026.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	670	670	670	670	670	
5°	669	667	664	668	668	63
15°	643	644	643	646	646	182
25°	596	596	597	602	603	275
35°	528	530	532	538	540	330
45°	444	448	452	456	458	342
55°	346	350	357	362	365	309
65°	238	242	250	260	265	236
75°	120	128	147	164	170	128
85°	21	38	66	88	95	26
90°	0	14	39	59	66	1
95°	0	4	20	37	42	0
105°	0	0	3	10	13	0
115°	0	0	1	2	2	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517934

CATALOG NUMBER: HVL8-2-LD4-2LO-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	670.1	670.1	670.1	670.1	670.1
2.5°	670.9	669.9	666.9	669.9	669.8
5°	668.7	667.4	664.4	667.6	667.6
7.5°	664.2	663.8	661.1	664.7	664.7
10°	659.0	658.9	656.7	660.6	660.8
12.5°	651.8	652.4	650.3	654.1	654.6
15°	643.2	644.3	642.6	646.2	646.1
17.5°	633.9	634.5	633.3	637.4	637.2
20°	622.4	623.2	622.2	626.5	627.0
22.5°	609.6	610.7	610.5	614.9	616.2
25°	596.0	596.5	597.1	602.2	603.1
27.5°	581.0	581.8	582.9	587.5	588.4
30°	564.6	565.8	567.1	571.8	573.1
32.5°	547.2	548.4	550.0	556.2	556.8
35°	527.6	530.0	532.2	537.5	539.8
37.5°	508.0	511.0	513.1	518.8	520.5
40°	487.3	490.3	493.6	499.6	500.7
42.5°	465.7	469.1	473.1	478.5	480.4
45°	443.9	447.8	451.5	455.9	458.1
47.5°	420.3	424.3	428.7	433.8	435.2
50°	396.0	400.6	405.3	410.1	412.6
52.5°	371.1	376.6	382.0	387.0	389.4
55°	346.4	350.5	357.0	362.2	364.6
57.5°	320.8	324.3	330.1	338.7	339.9
60°	294.8	297.9	303.9	310.9	313.7
62.5°	266.0	270.3	276.6	285.4	288.0
65°	238.1	242.2	250.5	260.5	264.6
67.5°	211.0	212.5	223.2	233.6	240.3
70°	179.1	184.5	197.0	209.8	214.8
72.5°	151.6	157.0	170.8	185.8	192.1
75°	120.5	127.9	146.6	164.1	170.3
77.5°	93.2	101.4	124.5	142.2	149.3
80°	65.1	77.9	103.0	122.9	130.6
82.5°	40.9	56.7	83.6	104.4	111.2
85°	20.9	38.5	66.2	87.5	95.3
87.5°	5.5	25.0	51.5	71.9	79.8
90°	0.2	14.4	39.0	58.6	65.7
92.5°	0.2	8.1	29.1	46.6	53.9
95°	0.2	3.8	20.2	36.6	42.3
97.5°	0.2	1.6	13.9	27.6	33.3
100°	0.2	0.8	8.8	20.1	25.0
102.5°	0.3	0.5	5.5	14.4	18.3
105°	0.3	0.5	3.3	9.8	13.1
107.5°	0.3	0.5	1.9	6.6	9.0
110°	0.5	0.5	1.1	4.1	6.0

TEST NUMBER: P517934

CATALOG NUMBER: HVL8-2-LD4-2LO-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	0.5	0.6	2.7	3.9
115°	0.5	0.5	0.6	1.7	2.5
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)