

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517938

Luminaire Tested: HVL8-2-LD4-2LO-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517938
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-2-LD4-2LO-35-UNV-O-EDD
Description: 2 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2053.0 lumens
Efficiency: N/A
Efficacy: 88.9 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 2' x H: 0.17')
CIE Type: Direct


Input Watts (W): 23.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517938

CATALOG NUMBER: HVL8-2-LD4-2LO-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517938

CATALOG NUMBER: HVL8-2-LD4-2LO-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		87
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		60
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		54
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5482	5482	5482
5°	5451	5345	5364
10°	5395	5237	5257
15°	5329	5119	5128
20°	5259	4989	5003
25°	5178	4856	4875
30°	5088	4715	4730
35°	4978	4562	4588
40°	4864	4401	4420
45°	4740	4227	4240
50°	4585	4027	4045
55°	4415	3810	3831
60°	4214	3531	3582
65°	3909	3221	3334
70°	3486	2859	3046
75°	2905	2464	2785
80°	2080	2077	2546
85°	1001	1682	2317

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4740 cd/sqm

TEST NUMBER: P517938

CATALOG NUMBER: HVL8-2-LD4-2LO-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	64.3	3.1
10°-20°	184.3	9.0
20°-30°	279.7	13.6
30°-40°	338.2	16.5
40°-50°	352.8	17.2
50°-60°	322.6	15.7
60°-70°	251.5	12.3
70°-80°	157.3	7.7
80°-90°	71.5	3.5
90°-100°	24.0	1.2
100°-110°	6.0	0.3
110°-120°	0.9	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	528.2	25.7
0°-40°	866.4	42.2
0°-60°	1541.8	75.1
0°-90°	2022.1	98.5
90°-120°	30.9	1.5
90°-150°	30.9	1.5
90°-180°	31.0	1.5
0°-180°	2053.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	679	679	679	679	679	
5°	678	676	673	676	676	64
15°	652	653	651	655	655	184
25°	604	604	605	610	611	278
35°	535	537	539	545	547	335
45°	450	454	458	462	464	347
55°	351	355	362	367	369	314
65°	241	245	254	264	268	239
75°	122	130	148	166	173	130
85°	21	39	67	89	96	27
90°	0	15	40	59	67	1
95°	0	4	20	37	43	0
105°	0	0	3	10	13	0
115°	0	0	1	2	3	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517938

CATALOG NUMBER: HVL8-2-LD4-2LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	679.0	679.0	679.0	679.0	679.0
2.5°	679.8	678.8	675.8	678.8	678.7
5°	677.6	676.3	673.2	676.4	676.4
7.5°	673.1	672.6	669.9	673.6	673.6
10°	667.8	667.6	665.4	669.4	669.6
12.5°	660.4	661.1	659.0	662.8	663.3
15°	651.8	652.9	651.2	654.8	654.7
17.5°	642.4	643.0	641.7	645.9	645.7
20°	630.7	631.5	630.5	634.8	635.3
22.5°	617.7	618.8	618.7	623.1	624.4
25°	603.9	604.4	605.1	610.2	611.1
27.5°	588.7	589.5	590.7	595.3	596.3
30°	572.1	573.4	574.6	579.4	580.7
32.5°	554.5	555.8	557.4	563.6	564.2
35°	534.6	537.0	539.3	544.7	547.0
37.5°	514.8	517.8	519.9	525.7	527.4
40°	493.8	496.9	500.2	506.3	507.4
42.5°	471.9	475.4	479.4	484.8	486.8
45°	449.8	453.8	457.5	462.0	464.2
47.5°	425.9	429.9	434.4	439.5	441.0
50°	401.3	405.9	410.7	415.5	418.1
52.5°	376.0	381.6	387.0	392.2	394.6
55°	351.0	355.2	361.8	367.0	369.4
57.5°	325.1	328.6	334.5	343.2	344.5
60°	298.7	301.9	308.0	315.0	317.9
62.5°	269.6	273.9	280.3	289.2	291.8
65°	241.2	245.4	253.9	264.0	268.1
67.5°	213.9	215.3	226.2	236.7	243.5
70°	181.5	187.0	199.6	212.6	217.7
72.5°	153.7	159.1	173.0	188.2	194.6
75°	122.1	129.7	148.5	166.3	172.6
77.5°	94.4	102.8	126.1	144.1	151.3
80°	65.9	78.9	104.4	124.5	132.4
82.5°	41.5	57.5	84.7	105.8	112.7
85°	21.1	39.1	67.1	88.7	96.5
87.5°	5.6	25.3	52.2	72.8	80.8
90°	0.2	14.6	39.5	59.4	66.6
92.5°	0.2	8.2	29.5	47.2	54.6
95°	0.2	3.8	20.5	37.1	42.9
97.5°	0.2	1.6	14.1	28.0	33.8
100°	0.2	0.8	9.0	20.3	25.3
102.5°	0.3	0.5	5.6	14.6	18.6
105°	0.3	0.5	3.4	9.9	13.3
107.5°	0.3	0.5	1.9	6.7	9.1
110°	0.5	0.5	1.1	4.2	6.1

TEST NUMBER: P517938

CATALOG NUMBER: HVL8-2-LD4-2LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	0.5	0.6	2.7	4.0
115°	0.5	0.5	0.6	1.8	2.6
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)