

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517942

Luminaire Tested: HVL8-2-LD4-2LO-40-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517942
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-2-LD4-2LO-40-UNV-O-EDD
Description: 2 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2082.0 lumens
Efficiency: N/A
Efficacy: 90.1 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 2' x H: 0.17')
CIE Type: Direct


Input Watts (W): 23.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517942

CATALOG NUMBER: HVL8-2-LD4-2LO-40-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517942

CATALOG NUMBER: HVL8-2-LD4-2LO-40-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		87
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		60
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		54
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5559	5559	5559
5°	5528	5421	5440
10°	5471	5311	5331
15°	5404	5191	5200
20°	5333	5059	5073
25°	5252	4924	4944
30°	5160	4782	4797
35°	5049	4626	4652
40°	4933	4463	4483
45°	4807	4286	4300
50°	4650	4084	4103
55°	4478	3863	3886
60°	4274	3580	3632
65°	3964	3267	3381
70°	3536	2899	3089
75°	2948	2499	2824
80°	2112	2105	2580
85°	1015	1705	2350

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4807 cd/sqm

TEST NUMBER: P517942

CATALOG NUMBER: HVL8-2-LD4-2LO-40-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	65.2	3.1
10°-20°	186.9	9.0
20°-30°	283.6	13.6
30°-40°	342.9	16.5
40°-50°	357.8	17.2
50°-60°	327.2	15.7
60°-70°	255.0	12.2
70°-80°	159.5	7.7
80°-90°	72.5	3.5
90°-100°	24.3	1.2
100°-110°	6.1	0.3
110°-120°	1.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	535.7	25.7
0°-40°	878.6	42.2
0°-60°	1563.6	75.1
0°-90°	2050.7	98.5
90°-120°	31.4	1.5
90°-150°	31.4	1.5
90°-180°	31.0	1.5
0°-180°	2082.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	689	689	689	689	689	
5°	687	686	683	686	686	65
15°	661	662	660	664	664	187
25°	612	613	614	619	620	282
35°	542	545	547	552	555	339
45°	456	460	464	468	471	351
55°	356	360	367	372	375	318
65°	245	249	258	268	272	242
75°	124	132	151	169	175	132
85°	21	40	68	90	98	27
90°	0	15	40	60	68	1
95°	0	4	21	38	44	0
105°	0	0	3	10	14	0
115°	0	0	1	2	3	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517942

CATALOG NUMBER: HVL8-2-LD4-2LO-40-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	688.6	688.6	688.6	688.6	688.6
2.5°	689.4	688.4	685.4	688.4	688.3
5°	687.1	685.8	682.8	686.0	686.0
7.5°	682.6	682.1	679.3	683.1	683.1
10°	677.2	677.1	674.8	678.9	679.0
12.5°	669.8	670.4	668.3	672.2	672.7
15°	661.0	662.1	660.4	664.1	663.9
17.5°	651.4	652.1	650.8	655.0	654.8
20°	639.6	640.4	639.4	643.8	644.3
22.5°	626.4	627.6	627.4	631.9	633.2
25°	612.5	613.0	613.6	618.8	619.8
27.5°	597.0	597.9	599.0	603.7	604.7
30°	580.2	581.5	582.8	587.6	588.9
32.5°	562.3	563.6	565.2	571.6	572.2
35°	542.2	544.6	546.9	552.4	554.7
37.5°	522.1	525.1	527.2	533.1	534.9
40°	500.8	503.9	507.3	513.4	514.6
42.5°	478.5	482.1	486.2	491.7	493.6
45°	456.1	460.2	463.9	468.5	470.8
47.5°	432.0	436.0	440.6	445.8	447.2
50°	407.0	411.7	416.5	421.4	424.0
52.5°	381.3	387.0	392.5	397.7	400.1
55°	356.0	360.2	366.9	372.2	374.7
57.5°	329.7	333.3	339.3	348.0	349.3
60°	302.9	306.2	312.3	319.5	322.4
62.5°	273.4	277.7	284.2	293.3	295.9
65°	244.6	248.9	257.5	267.7	271.9
67.5°	216.9	218.3	229.4	240.1	246.9
70°	184.1	189.6	202.4	215.6	220.8
72.5°	155.8	161.4	175.5	190.9	197.4
75°	123.9	131.5	150.6	168.7	175.0
77.5°	95.8	104.2	127.9	146.1	153.4
80°	66.9	80.0	105.8	126.3	134.2
82.5°	42.0	58.3	85.9	107.3	114.3
85°	21.4	39.6	68.0	89.9	97.9
87.5°	5.7	25.6	52.9	73.9	82.0
90°	0.2	14.8	40.1	60.2	67.5
92.5°	0.2	8.3	29.9	47.9	55.4
95°	0.2	3.9	20.8	37.7	43.5
97.5°	0.2	1.6	14.3	28.4	34.3
100°	0.2	0.8	9.1	20.6	25.6
102.5°	0.3	0.5	5.7	14.8	18.8
105°	0.3	0.5	3.4	10.1	13.5
107.5°	0.3	0.5	1.9	6.8	9.3
110°	0.5	0.5	1.1	4.2	6.2

TEST NUMBER: P517942

CATALOG NUMBER: HVL8-2-LD4-2LO-40-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.5	0.5	0.6	2.8	4.1
115°	0.5	0.5	0.6	1.8	2.6
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)