

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P517954

Luminaire Tested: HVL8-2-LD4-2STD-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P517954
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-2-LD4-2STD-35-UNV-O-EDD
Description: 2 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2644.0 lumens
Efficiency: N/A
Efficacy: 80.9 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 2' x H: 0.17')
CIE Type: Direct


Input Watts (W): 32.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P517954

CATALOG NUMBER: HVL8-2-LD4-2STD-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P517954

CATALOG NUMBER: HVL8-2-LD4-2STD-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	7060	7060	7060
5°	7020	6885	6909
10°	6948	6745	6770
15°	6862	6592	6604
20°	6772	6425	6443
25°	6669	6253	6279
30°	6553	6073	6092
35°	6411	5875	5908
40°	6264	5668	5693
45°	6105	5444	5460
50°	5904	5187	5210
55°	5686	4906	4935
60°	5428	4547	4612
65°	5035	4148	4294
70°	4490	3683	3923
75°	3742	3174	3585
80°	2680	2674	3278
85°	1290	2166	2984

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6105 cd/sqm

TEST NUMBER: P517954

CATALOG NUMBER: HVL8-2-LD4-2STD-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	82.8	3.1
10°-20°	237.4	9.0
20°-30°	360.2	13.6
30°-40°	435.5	16.5
40°-50°	454.4	17.2
50°-60°	415.5	15.7
60°-70°	323.9	12.2
70°-80°	202.6	7.7
80°-90°	92.0	3.5
90°-100°	30.8	1.2
100°-110°	7.7	0.3
110°-120°	1.2	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	680.3	25.7
0°-40°	1115.8	42.2
0°-60°	1985.7	75.1
0°-90°	2604.2	98.5
90°-120°	39.8	1.5
90°-150°	39.8	1.5
90°-180°	40.0	1.5
0°-180°	2644.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	874	874	874	874	874	
5°	873	871	867	871	871	83
15°	839	841	839	843	843	237
25°	778	778	779	786	787	358
35°	688	692	694	702	704	431
45°	579	584	589	595	598	446
55°	452	457	466	473	476	404
65°	311	316	327	340	345	307
75°	157	167	191	214	222	168
85°	27	50	86	114	124	34
90°	0	19	51	76	86	1
95°	0	5	26	48	55	0
105°	0	1	4	13	17	0
115°	1	1	1	2	3	0
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P517954

CATALOG NUMBER: HVL8-2-LD4-2STD-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	874.5	874.5	874.5	874.5	874.5
2.5°	875.5	874.3	870.4	874.3	874.1
5°	872.6	871.0	867.1	871.2	871.2
7.5°	866.8	866.2	862.7	867.5	867.5
10°	860.0	859.8	857.0	862.1	862.3
12.5°	850.6	851.4	848.7	853.7	854.3
15°	839.4	840.9	838.6	843.3	843.1
17.5°	827.3	828.1	826.4	831.8	831.6
20°	812.2	813.2	812.0	817.6	818.2
22.5°	795.5	797.0	796.8	802.5	804.2
25°	777.8	778.4	779.2	785.8	787.1
27.5°	758.2	759.2	760.7	766.7	767.9
30°	736.8	738.4	740.1	746.3	747.9
32.5°	714.1	715.7	717.8	725.8	726.7
35°	688.5	691.6	694.5	701.5	704.4
37.5°	663.0	666.9	669.6	677.0	679.3
40°	636.0	639.9	644.2	652.0	653.5
42.5°	607.7	612.3	617.4	624.4	626.9
45°	579.3	584.4	589.2	594.9	597.8
47.5°	548.6	553.7	559.5	566.1	567.9
50°	516.8	522.8	529.0	535.2	538.5
52.5°	484.2	491.5	498.5	505.1	508.2
55°	452.1	457.4	465.9	472.7	475.8
57.5°	418.7	423.2	430.8	442.0	443.6
60°	384.7	388.8	396.6	405.7	409.4
62.5°	347.2	352.7	361.0	372.5	375.8
65°	310.7	316.0	326.9	339.9	345.3
67.5°	275.4	277.3	291.3	304.9	313.5
70°	233.8	240.8	257.1	273.8	280.4
72.5°	197.9	204.9	222.8	242.4	250.7
75°	157.3	167.0	191.3	214.2	222.2
77.5°	121.6	132.3	162.4	185.5	194.8
80°	84.9	101.6	134.4	160.4	170.5
82.5°	53.4	74.0	109.1	136.3	145.1
85°	27.2	50.3	86.4	114.2	124.3
87.5°	7.2	32.6	67.2	93.8	104.1
90°	0.2	18.8	50.9	76.5	85.8
92.5°	0.2	10.5	37.9	60.8	70.3
95°	0.2	4.9	26.4	47.8	55.2
97.5°	0.2	2.1	18.1	36.1	43.5
100°	0.2	1.0	11.5	26.2	32.6
102.5°	0.4	0.6	7.2	18.8	23.9
105°	0.4	0.6	4.3	12.8	17.1
107.5°	0.4	0.6	2.5	8.7	11.8
110°	0.6	0.6	1.4	5.4	7.8

TEST NUMBER: P517954

CATALOG NUMBER: HVL8-2-LD4-2STD-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	0.6	0.6	0.8	3.5	5.2
115°	0.6	0.6	0.8	2.3	3.3
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)