

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518082

Luminaire Tested: HVL8-4-LD4-2LO-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518082
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2LO-35-UNV-O-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4105.0 lumens
Efficiency: N/A
Efficacy: 89.0 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 46.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518082

CATALOG NUMBER: HVL8-4-LD4-2LO-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518082

CATALOG NUMBER: HVL8-4-LD4-2LO-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5480	5480	5480
5°	5470	5358	5363
10°	5433	5262	5256
15°	5386	5156	5127
20°	5336	5037	5001
25°	5276	4915	4874
30°	5206	4785	4729
35°	5118	4643	4586
40°	5027	4493	4419
45°	4929	4329	4239
50°	4800	4140	4045
55°	4662	3932	3831
60°	4497	3663	3580
65°	4229	3361	3333
70°	3843	3006	3045
75°	3296	2617	2783
80°	2480	2236	2545
85°	1324	1850	2317

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4929 cd/sqm

TEST NUMBER: P518082

CATALOG NUMBER: HVL8-4-LD4-2LO-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	128.5	3.1
10°-20°	368.5	9.0
20°-30°	559.2	13.6
30°-40°	676.2	16.5
40°-50°	705.5	17.2
50°-60°	645.0	15.7
60°-70°	502.8	12.2
70°-80°	314.6	7.7
80°-90°	142.9	3.5
90°-100°	47.9	1.2
100°-110°	12.0	0.3
110°-120°	1.9	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1056.2	25.7
0°-40°	1732.4	42.2
0°-60°	3082.9	75.1
0°-90°	4043.2	98.5
90°-120°	61.8	1.5
90°-150°	61.8	1.5
90°-180°	62.0	1.5
0°-180°	4105.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1358	1358	1358	1358	1358	
5°	1355	1352	1346	1353	1353	129
15°	1303	1306	1302	1309	1309	368
25°	1208	1208	1210	1220	1222	556
35°	1069	1074	1078	1089	1094	669
45°	899	907	915	924	928	693
55°	702	710	723	734	739	627
65°	482	491	508	528	536	477
75°	244	259	297	332	345	260
85°	42	78	134	177	193	53
90°	0	29	79	119	133	2
95°	0	8	41	74	86	0
105°	1	1	7	20	27	1
115°	1	1	1	4	5	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518082

CATALOG NUMBER: HVL8-4-LD4-2LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1357.7	1357.7	1357.7	1357.7	1357.7
2.5°	1359.3	1357.4	1351.3	1357.4	1357.0
5°	1354.8	1352.2	1346.2	1352.6	1352.6
7.5°	1345.8	1344.9	1339.4	1346.8	1346.8
10°	1335.3	1335.0	1330.5	1338.5	1338.8
12.5°	1320.6	1321.8	1317.7	1325.4	1326.3
15°	1303.3	1305.5	1302.0	1309.4	1309.0
17.5°	1284.4	1285.7	1283.1	1291.4	1291.1
20°	1261.0	1262.6	1260.7	1269.4	1270.3
22.5°	1235.1	1237.3	1237.0	1246.0	1248.5
25°	1207.6	1208.5	1209.8	1220.1	1222.0
27.5°	1177.2	1178.8	1181.0	1190.3	1192.2
30°	1143.9	1146.4	1149.0	1158.6	1161.2
32.5°	1108.7	1111.2	1114.4	1126.9	1128.2
35°	1069.0	1073.8	1078.3	1089.2	1093.6
37.5°	1029.3	1035.4	1039.5	1051.1	1054.6
40°	987.4	993.5	1000.2	1012.3	1014.6
42.5°	943.5	950.6	958.6	969.5	973.3
45°	899.4	907.4	914.7	923.7	928.2
47.5°	851.7	859.7	868.6	878.9	881.8
50°	802.4	811.7	821.3	830.9	836.0
52.5°	751.8	763.0	773.9	784.1	788.9
55°	701.9	710.2	723.3	733.9	738.7
57.5°	650.0	657.1	668.9	686.2	688.8
60°	597.2	603.6	615.8	629.9	635.6
62.5°	539.0	547.6	560.4	578.3	583.5
65°	482.3	490.6	507.6	527.8	536.1
67.5°	427.6	430.5	452.2	473.4	486.8
70°	362.9	373.8	399.1	425.0	435.3
72.5°	307.3	318.1	346.0	376.4	389.2
75°	244.2	259.2	297.0	332.5	345.0
77.5°	188.8	205.5	252.2	288.1	302.5
80°	131.9	157.8	208.7	249.0	264.7
82.5°	82.9	114.9	169.3	211.6	225.3
85°	42.2	78.1	134.1	177.3	193.0
87.5°	11.2	50.6	104.3	145.6	161.6
90°	0.3	29.1	79.1	118.7	133.1
92.5°	0.3	16.3	58.9	94.4	109.1
95°	0.3	7.7	41.0	74.3	85.8
97.5°	0.3	3.2	28.2	56.0	67.5
100°	0.3	1.6	17.9	40.6	50.6
102.5°	0.6	1.0	11.2	29.1	37.1
105°	0.6	1.0	6.7	19.8	26.6
107.5°	0.6	1.0	3.8	13.4	18.2
110°	1.0	1.0	2.2	8.3	12.2

TEST NUMBER: P518082

CATALOG NUMBER: HVL8-4-LD4-2LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.0	1.0	1.3	5.4	8.0
115°	1.0	1.0	1.3	3.5	5.1
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)