

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518094

Luminaire Tested: HVL8-4-LD4-2STD-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518094
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2STD-30-UNV-O-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5219.0 lumens
Efficiency: N/A
Efficacy: 79.8 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 65.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518094

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518094

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	6967	6967	6967
5°	6954	6812	6818
10°	6907	6690	6682
15°	6848	6555	6518
20°	6784	6404	6359
25°	6707	6249	6197
30°	6619	6084	6013
35°	6507	5903	5831
40°	6391	5712	5618
45°	6266	5504	5389
50°	6103	5263	5142
55°	5927	4999	4870
60°	5717	4657	4552
65°	5376	4274	4238
70°	4886	3822	3871
75°	4191	3327	3539
80°	3151	2842	3235
85°	1685	2352	2946

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6266 cd/sqm

TEST NUMBER: P518094

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	163.3	3.1
10°-20°	468.5	9.0
20°-30°	710.9	13.6
30°-40°	859.6	16.5
40°-50°	897.0	17.2
50°-60°	820.1	15.7
60°-70°	639.3	12.2
70°-80°	399.9	7.7
80°-90°	181.6	3.5
90°-100°	60.9	1.2
100°-110°	15.3	0.3
110°-120°	2.4	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1342.8	25.7
0°-40°	2202.5	42.2
0°-60°	3919.5	75.1
0°-90°	5140.4	98.5
90°-120°	78.6	1.5
90°-150°	78.6	1.5
90°-180°	79.0	1.5
0°-180°	5219.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1726	1726	1726	1726	1726	
5°	1722	1719	1712	1720	1720	164
15°	1657	1660	1655	1665	1664	468
25°	1535	1536	1538	1551	1554	707
35°	1359	1365	1371	1385	1390	851
45°	1143	1154	1163	1174	1180	881
55°	892	903	920	933	939	797
65°	613	624	645	671	682	607
75°	310	330	378	423	439	331
85°	54	99	170	225	245	68
90°	0	37	100	151	169	2
95°	0	10	52	94	109	0
105°	1	1	8	25	34	1
115°	1	1	2	4	6	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518094

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1726.1	1726.1	1726.1	1726.1	1726.1
2.5°	1728.2	1725.7	1718.0	1725.7	1725.3
5°	1722.5	1719.2	1711.5	1719.6	1719.6
7.5°	1711.1	1709.9	1702.9	1712.3	1712.3
10°	1697.6	1697.2	1691.5	1701.7	1702.1
12.5°	1678.9	1680.6	1675.3	1685.0	1686.3
15°	1657.0	1659.8	1655.3	1664.7	1664.3
17.5°	1632.9	1634.6	1631.3	1641.9	1641.5
20°	1603.2	1605.3	1602.8	1613.8	1615.0
22.5°	1570.3	1573.1	1572.7	1584.1	1587.4
25°	1535.3	1536.5	1538.1	1551.2	1553.6
27.5°	1496.6	1498.7	1501.5	1513.3	1515.8
30°	1454.3	1457.6	1460.8	1473.0	1476.3
32.5°	1409.6	1412.8	1416.9	1432.7	1434.4
35°	1359.1	1365.2	1370.9	1384.7	1390.4
37.5°	1308.6	1316.4	1321.7	1336.3	1340.8
40°	1255.3	1263.1	1271.6	1287.1	1289.9
42.5°	1199.6	1208.5	1218.7	1232.5	1237.4
45°	1143.4	1153.6	1163.0	1174.4	1180.1
47.5°	1082.8	1093.0	1104.4	1117.4	1121.0
50°	1020.1	1031.9	1044.1	1056.3	1062.9
52.5°	955.8	970.1	983.9	996.9	1003.0
55°	892.4	902.9	919.6	933.1	939.2
57.5°	826.4	835.4	850.5	872.4	875.7
60°	759.3	767.4	782.9	800.8	808.1
62.5°	685.2	696.2	712.5	735.3	741.8
65°	613.2	623.8	645.4	671.0	681.6
67.5°	543.6	547.3	575.0	601.8	618.9
70°	461.4	475.3	507.4	540.4	553.4
72.5°	390.6	404.5	439.9	478.5	494.8
75°	310.5	329.6	377.6	422.8	438.7
77.5°	240.1	261.2	320.6	366.2	384.5
80°	167.6	200.6	265.3	316.6	336.5
82.5°	105.4	146.1	215.3	269.0	286.5
85°	53.7	99.3	170.5	225.4	245.4
87.5°	14.2	64.3	132.7	185.1	205.5
90°	0.4	37.0	100.5	151.0	169.3
92.5°	0.4	20.8	74.9	120.0	138.8
95°	0.4	9.8	52.1	94.4	109.1
97.5°	0.4	4.1	35.8	71.2	85.9
100°	0.4	2.0	22.8	51.7	64.3
102.5°	0.8	1.2	14.2	37.0	47.2
105°	0.8	1.2	8.5	25.2	33.8
107.5°	0.8	1.2	4.9	17.1	23.2
110°	1.2	1.2	2.8	10.6	15.5

TEST NUMBER: P518094

CATALOG NUMBER: HVL8-4-LD4-2STD-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.2	1.2	1.6	6.9	10.2
115°	1.2	1.2	1.6	4.5	6.5
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)