

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518102

Luminaire Tested: HVL8-4-LD4-2STD-40-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518102
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-4-LD4-2STD-40-UNV-O-EDD
Description: 4 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5363.0 lumens
Efficiency: N/A
Efficacy: 82.0 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 4' x H: 0.17')
CIE Type: Direct


Input Watts (W): 65.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518102

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518102

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	7160	7160	7160
5°	7146	7000	7007
10°	7098	6874	6866
15°	7037	6736	6698
20°	6971	6581	6534
25°	6892	6422	6368
30°	6802	6252	6179
35°	6687	6065	5992
40°	6568	5869	5773
45°	6439	5655	5537
50°	6271	5408	5284
55°	6091	5137	5005
60°	5875	4785	4678
65°	5524	4392	4355
70°	5021	3928	3978
75°	4305	3419	3637
80°	3239	2920	3324
85°	1732	2416	3026

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6439 cd/sqm

TEST NUMBER: P518102

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	167.9	3.1
10°-20°	481.5	9.0
20°-30°	730.6	13.6
30°-40°	883.4	16.5
40°-50°	921.7	17.2
50°-60°	842.7	15.7
60°-70°	656.9	12.2
70°-80°	410.9	7.7
80°-90°	186.7	3.5
90°-100°	62.6	1.2
100°-110°	15.7	0.3
110°-120°	2.5	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1379.9	25.7
0°-40°	2263.2	42.2
0°-60°	4027.7	75.1
0°-90°	5282.2	98.5
90°-120°	80.8	1.5
90°-150°	80.8	1.5
90°-180°	81.0	1.5
0°-180°	5363.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1774	1774	1774	1774	1774	
5°	1770	1767	1759	1767	1767	168
15°	1703	1706	1701	1711	1710	481
25°	1578	1579	1581	1594	1596	727
35°	1397	1403	1409	1423	1429	874
45°	1175	1185	1195	1207	1213	905
55°	917	928	945	959	965	819
65°	630	641	663	690	700	623
75°	319	339	388	434	451	340
85°	55	102	175	232	252	70
90°	0	38	103	155	174	2
95°	0	10	54	97	112	0
105°	1	1	9	26	35	1
115°	1	1	2	5	7	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518102

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1773.8	1773.8	1773.8	1773.8	1773.8
2.5°	1775.8	1773.3	1765.4	1773.3	1772.9
5°	1770.0	1766.6	1758.7	1767.1	1767.1
7.5°	1758.3	1757.0	1749.9	1759.5	1759.5
10°	1744.5	1744.1	1738.2	1748.7	1749.1
12.5°	1725.3	1726.9	1721.5	1731.5	1732.8
15°	1702.7	1705.6	1701.0	1710.6	1710.2
17.5°	1678.0	1679.7	1676.3	1687.2	1686.8
20°	1647.5	1649.6	1647.1	1658.3	1659.6
22.5°	1613.6	1616.5	1616.1	1627.8	1631.2
25°	1577.6	1578.9	1580.6	1594.0	1596.5
27.5°	1537.9	1540.0	1542.9	1555.1	1557.6
30°	1494.4	1497.8	1501.1	1513.7	1517.0
32.5°	1448.4	1451.8	1456.0	1472.3	1473.9
35°	1396.6	1402.9	1408.7	1422.9	1428.8
37.5°	1344.7	1352.7	1358.1	1373.2	1377.8
40°	1290.0	1297.9	1306.7	1322.6	1325.5
42.5°	1232.7	1241.9	1252.3	1266.6	1271.6
45°	1175.0	1185.4	1195.0	1206.8	1212.6
47.5°	1112.7	1123.1	1134.8	1148.2	1152.0
50°	1048.3	1060.4	1073.0	1085.5	1092.2
52.5°	982.2	996.8	1011.1	1024.4	1030.7
55°	917.0	927.9	945.0	958.8	965.1
57.5°	849.2	858.4	873.9	896.5	899.8
60°	780.3	788.6	804.5	822.9	830.4
62.5°	704.2	715.4	732.2	755.6	762.3
65°	630.1	641.0	663.2	689.5	700.4
67.5°	558.6	562.4	590.8	618.4	636.0
70°	474.2	488.4	521.4	555.3	568.7
72.5°	401.4	415.6	452.0	491.7	508.5
75°	319.0	338.7	388.0	434.4	450.8
77.5°	246.7	268.4	329.5	376.3	395.1
80°	172.3	206.1	272.6	325.3	345.8
82.5°	108.3	150.1	221.2	276.4	294.4
85°	55.2	102.0	175.2	231.7	252.1
87.5°	14.6	66.1	136.3	190.3	211.2
90°	0.4	38.1	103.3	155.1	173.9
92.5°	0.4	21.3	76.9	123.4	142.6
95°	0.4	10.0	53.5	97.0	112.1
97.5°	0.4	4.2	36.8	73.2	88.2
100°	0.4	2.1	23.4	53.1	66.1
102.5°	0.8	1.3	14.6	38.1	48.5
105°	0.8	1.3	8.8	25.9	34.7
107.5°	0.8	1.3	5.0	17.6	23.8
110°	1.3	1.3	2.9	10.9	15.9

TEST NUMBER: P518102

CATALOG NUMBER: HVL8-4-LD4-2STD-40-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.3	1.3	1.7	7.1	10.5
115°	1.3	1.3	1.7	4.6	6.7
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)