

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518206

Luminaire Tested: HVL8-8-LD4-2HI-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518206
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2HI-30-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 13431.0 lumens
Efficiency: N/A
Efficacy: 78.0 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct

Input Watts (W): 172.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518206
CATALOG NUMBER: HVL8-8-LD4-2HI-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518206

CATALOG NUMBER: HVL8-8-LD4-2HI-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	8965	8965	8965
5°	8964	8776	8774
10°	8921	8630	8598
15°	8860	8466	8387
20°	8795	8282	8182
25°	8714	8092	7974
30°	8618	7889	7737
35°	8493	7664	7502
40°	8365	7428	7229
45°	8227	7169	6934
50°	8043	6869	6617
55°	7847	6539	6266
60°	7613	6107	5858
65°	7214	5622	5452
70°	6628	5049	4982
75°	5781	4419	4554
80°	4484	3804	4162
85°	2585	3186	3790

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8227 cd/sqm

TEST NUMBER: P518206

CATALOG NUMBER: HVL8-8-LD4-2HI-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	420.4	3.1
10°-20°	1205.8	9.0
20°-30°	1829.6	13.6
30°-40°	2212.3	16.5
40°-50°	2308.4	17.2
50°-60°	2110.5	15.7
60°-70°	1645.3	12.2
70°-80°	1029.2	7.7
80°-90°	467.5	3.5
90°-100°	156.7	1.2
100°-110°	39.3	0.3
110°-120°	6.2	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3455.8	25.7
0°-40°	5668.0	42.2
0°-60°	10086.9	75.1
0°-90°	13228.8	98.5
90°-120°	202.2	1.5
90°-150°	202.2	1.5
90°-180°	202.0	1.5
0°-180°	13431.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4442	4442	4442	4442	4442	
5°	4433	4424	4404	4425	4425	421
15°	4264	4272	4260	4284	4283	1204
25°	3951	3954	3958	3992	3998	1821
35°	3498	3513	3528	3564	3578	2189
45°	2943	2969	2993	3022	3037	2267
55°	2296	2324	2367	2401	2417	2052
65°	1578	1605	1661	1727	1754	1561
75°	799	848	972	1088	1129	852
85°	138	256	439	580	632	175
90°	1	95	259	388	436	5
95°	1	25	134	243	281	1
105°	2	3	22	65	87	2
115°	3	3	4	12	17	2
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518206

CATALOG NUMBER: HVL8-8-LD4-2HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4442.2	4442.2	4442.2	4442.2	4442.2
2.5°	4447.4	4441.1	4421.2	4441.1	4440.1
5°	4432.7	4424.4	4404.5	4425.4	4425.4
7.5°	4403.4	4400.3	4382.5	4406.6	4406.6
10°	4368.9	4367.8	4353.2	4379.3	4380.4
12.5°	4320.7	4324.9	4311.3	4336.4	4339.5
15°	4264.1	4271.5	4260.0	4284.0	4283.0
17.5°	4202.4	4206.5	4198.2	4225.4	4224.3
20°	4125.9	4131.1	4124.9	4153.1	4156.3
22.5°	4041.1	4048.4	4047.4	4076.7	4085.1
25°	3951.0	3954.2	3958.4	3991.9	3998.2
27.5°	3851.6	3856.8	3864.1	3894.5	3900.8
30°	3742.6	3751.0	3759.4	3790.8	3799.2
32.5°	3627.5	3635.8	3646.3	3687.1	3691.3
35°	3497.6	3513.3	3528.0	3563.6	3578.2
37.5°	3367.8	3387.6	3401.3	3439.0	3450.5
40°	3230.6	3250.5	3272.5	3312.2	3319.6
42.5°	3087.1	3110.1	3136.3	3171.9	3184.5
45°	2942.6	2968.8	2992.9	3022.2	3036.8
47.5°	2786.6	2812.7	2842.1	2875.6	2885.0
50°	2625.3	2655.7	2687.1	2718.5	2735.3
52.5°	2459.8	2496.5	2532.1	2565.6	2581.3
55°	2296.5	2323.7	2366.6	2401.2	2416.9
57.5°	2126.8	2149.9	2188.6	2245.2	2253.5
60°	1954.0	1975.0	2014.8	2060.9	2079.7
62.5°	1763.5	1791.7	1833.6	1892.3	1909.0
65°	1578.1	1605.3	1660.8	1726.8	1754.0
67.5°	1399.0	1408.5	1479.7	1548.8	1592.8
70°	1187.5	1223.1	1305.8	1390.7	1424.2
72.5°	1005.3	1040.9	1132.0	1231.5	1273.4
75°	799.0	848.2	971.8	1088.0	1128.9
77.5°	617.8	672.3	825.2	942.5	989.6
80°	431.4	516.3	682.8	814.7	866.0
82.5°	271.2	375.9	554.0	692.2	737.2
85°	138.2	255.5	438.8	580.1	631.5
87.5°	36.7	165.5	341.4	476.5	528.8
90°	1.0	95.3	258.7	388.5	435.6
92.5°	1.0	53.4	192.7	308.9	357.1
95°	1.0	25.1	134.0	242.9	280.6
97.5°	1.0	10.5	92.2	183.3	221.0
100°	1.0	5.2	58.6	133.0	165.5
102.5°	2.1	3.1	36.7	95.3	121.5
105°	2.1	3.1	22.0	64.9	86.9
107.5°	2.1	3.1	12.6	44.0	59.7
110°	3.1	3.1	7.3	27.2	39.8

TEST NUMBER: P518206

CATALOG NUMBER: HVL8-8-LD4-2HI-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	3.1	3.1	4.2	17.8	26.2
115°	3.1	3.1	4.2	11.5	16.8
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)