

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518214

Luminaire Tested: HVL8-8-LD4-2HI-40-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518214
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2HI-40-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 13804.0 lumens
Efficiency: N/A
Efficacy: 80.1 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct

Input Watts (W): 172.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518214
CATALOG NUMBER: HVL8-8-LD4-2HI-40-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518214

CATALOG NUMBER: HVL8-8-LD4-2HI-40-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	9214	9214	9214
5°	9213	9020	9017
10°	9168	8869	8837
15°	9106	8702	8620
20°	9039	8512	8409
25°	8956	8317	8195
30°	8858	8108	7952
35°	8729	7877	7711
40°	8597	7634	7430
45°	8456	7368	7127
50°	8267	7060	6800
55°	8065	6720	6440
60°	7824	6276	6020
65°	7414	5778	5604
70°	6812	5189	5120
75°	5942	4542	4680
80°	4609	3909	4278
85°	2658	3275	3895

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8456 cd/sqm

TEST NUMBER: P518214

CATALOG NUMBER: HVL8-8-LD4-2HI-40-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	432.0	3.1
10°-20°	1239.3	9.0
20°-30°	1880.4	13.6
30°-40°	2273.7	16.5
40°-50°	2372.4	17.2
50°-60°	2169.1	15.7
60°-70°	1690.9	12.2
70°-80°	1057.8	7.7
80°-90°	480.4	3.5
90°-100°	161.0	1.2
100°-110°	40.4	0.3
110°-120°	6.4	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3551.7	25.7
0°-40°	5825.4	42.2
0°-60°	10367.0	75.1
0°-90°	13596.2	98.5
90°-120°	207.8	1.5
90°-150°	207.8	1.5
90°-180°	208.0	1.5
0°-180°	13804.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4566	4566	4566	4566	4566	
5°	4556	4547	4527	4548	4548	433
15°	4383	4390	4378	4403	4402	1237
25°	4061	4064	4068	4103	4109	1871
35°	3595	3611	3626	3662	3678	2250
45°	3024	3051	3076	3106	3121	2330
55°	2360	2388	2432	2468	2484	2109
65°	1622	1650	1707	1775	1803	1605
75°	821	872	999	1118	1160	875
85°	142	263	451	596	649	180
90°	1	98	266	399	448	6
95°	1	26	138	250	288	1
105°	2	3	23	67	89	2
115°	3	3	4	12	17	2
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518214

CATALOG NUMBER: HVL8-8-LD4-2HI-40-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4565.5	4565.5	4565.5	4565.5	4565.5
2.5°	4570.9	4564.5	4544.0	4564.5	4563.4
5°	4555.8	4547.2	4526.8	4548.3	4548.3
7.5°	4525.7	4522.5	4504.2	4528.9	4528.9
10°	4490.2	4489.1	4474.0	4501.0	4502.0
12.5°	4440.7	4445.0	4431.0	4456.8	4460.1
15°	4382.6	4390.1	4378.3	4403.0	4401.9
17.5°	4319.1	4323.4	4314.8	4342.7	4341.7
20°	4240.5	4245.9	4239.4	4268.5	4271.7
22.5°	4153.3	4160.9	4159.8	4189.9	4198.5
25°	4060.8	4064.0	4068.3	4102.7	4109.2
27.5°	3958.5	3963.9	3971.4	4002.6	4009.1
30°	3846.6	3855.2	3863.8	3896.1	3904.7
32.5°	3728.2	3736.8	3747.6	3789.5	3793.8
35°	3594.7	3610.9	3625.9	3662.5	3677.6
37.5°	3461.3	3481.7	3495.7	3534.5	3546.3
40°	3320.3	3340.7	3363.3	3404.2	3411.8
42.5°	3172.8	3196.5	3223.4	3260.0	3272.9
45°	3024.3	3051.2	3076.0	3106.1	3121.2
47.5°	2863.9	2890.9	2921.0	2955.4	2965.1
50°	2698.2	2729.4	2761.7	2794.0	2811.2
52.5°	2528.2	2565.8	2602.4	2636.9	2653.0
55°	2360.3	2388.2	2432.4	2467.9	2484.0
57.5°	2185.9	2209.6	2249.4	2307.5	2316.1
60°	2008.3	2029.8	2070.7	2118.1	2137.5
62.5°	1812.4	1841.5	1884.5	1944.8	1962.0
65°	1621.9	1649.9	1707.0	1774.8	1802.7
67.5°	1437.9	1447.6	1520.8	1591.8	1637.0
70°	1220.5	1257.1	1342.1	1429.3	1463.7
72.5°	1033.2	1069.8	1163.4	1265.7	1308.7
75°	821.2	871.8	998.8	1118.2	1160.2
77.5°	635.0	691.0	848.1	968.6	1017.1
80°	443.4	530.6	701.7	837.3	890.1
82.5°	278.8	386.4	569.3	711.4	757.7
85°	142.1	262.6	451.0	596.3	649.0
87.5°	37.7	170.1	350.9	489.7	543.5
90°	1.1	97.9	265.8	399.3	447.7
92.5°	1.1	54.9	198.0	317.5	367.0
95°	1.1	25.8	137.8	249.7	288.4
97.5°	1.1	10.8	94.7	188.3	227.1
100°	1.1	5.4	60.3	136.7	170.1
102.5°	2.2	3.2	37.7	97.9	124.8
105°	2.2	3.2	22.6	66.7	89.3
107.5°	2.2	3.2	12.9	45.2	61.3
110°	3.2	3.2	7.5	28.0	40.9

TEST NUMBER: P518214

CATALOG NUMBER: HVL8-8-LD4-2HI-40-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	3.2	3.2	4.3	18.3	26.9
115°	3.2	3.2	4.3	11.8	17.2
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)