

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518218

Luminaire Tested: HVL8-8-LD4-2HI-50-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518218
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2HI-50-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 14536.0 lumens
Efficiency: N/A
Efficacy: 84.4 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct

Input Watts (W): 172.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518218
CATALOG NUMBER: HVL8-8-LD4-2HI-50-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518218

CATALOG NUMBER: HVL8-8-LD4-2HI-50-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	9703	9703	9703
5°	9702	9498	9496
10°	9655	9340	9305
15°	9589	9163	9077
20°	9518	8963	8855
25°	9431	8758	8630
30°	9328	8538	8374
35°	9192	8295	8120
40°	9053	8039	7824
45°	8904	7759	7504
50°	8705	7434	7161
55°	8493	7077	6782
60°	8239	6609	6340
65°	7807	6085	5901
70°	7173	5464	5391
75°	6256	4782	4928
80°	4853	4116	4505
85°	2798	3448	4102

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8904 cd/sqm

TEST NUMBER: P518218

CATALOG NUMBER: HVL8-8-LD4-2HI-50-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	455.0	3.1
10°-20°	1305.0	9.0
20°-30°	1980.1	13.6
30°-40°	2394.3	16.5
40°-50°	2498.3	17.2
50°-60°	2284.2	15.7
60°-70°	1780.6	12.2
70°-80°	1113.8	7.7
80°-90°	505.9	3.5
90°-100°	169.5	1.2
100°-110°	42.6	0.3
110°-120°	6.7	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3740.1	25.7
0°-40°	6134.4	42.2
0°-60°	10916.8	75.1
0°-90°	14317.2	98.5
90°-120°	218.8	1.5
90°-150°	218.8	1.5
90°-180°	219.0	1.5
0°-180°	14536.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	4808	4808	4808	4808	4808	
5°	4797	4788	4767	4790	4790	456
15°	4615	4623	4610	4636	4635	1303
25°	4276	4280	4284	4320	4327	1970
35°	3785	3802	3818	3857	3873	2369
45°	3185	3213	3239	3271	3287	2454
55°	2485	2515	2561	2599	2616	2220
65°	1708	1737	1798	1869	1898	1690
75°	865	918	1052	1178	1222	922
85°	150	276	475	628	683	189
90°	1	103	280	420	472	6
95°	1	27	145	263	304	1
105°	2	3	24	70	94	2
115°	3	3	4	12	18	2
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518218

CATALOG NUMBER: HVL8-8-LD4-2HI-50-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	4807.6	4807.6	4807.6	4807.6	4807.6
2.5°	4813.3	4806.5	4785.0	4806.5	4805.4
5°	4797.4	4788.4	4766.8	4789.5	4789.5
7.5°	4765.7	4762.3	4743.0	4769.1	4769.1
10°	4728.3	4727.2	4711.3	4739.6	4740.8
12.5°	4676.2	4680.7	4666.0	4693.2	4696.6
15°	4615.0	4622.9	4610.4	4636.5	4635.4
17.5°	4548.1	4552.6	4543.6	4573.0	4571.9
20°	4465.4	4471.0	4464.2	4494.8	4498.2
22.5°	4373.6	4381.5	4380.4	4412.1	4421.2
25°	4276.1	4279.5	4284.0	4320.3	4327.1
27.5°	4168.4	4174.1	4182.0	4214.9	4221.7
30°	4050.6	4059.6	4068.7	4102.7	4111.8
32.5°	3925.9	3935.0	3946.3	3990.5	3995.0
35°	3785.4	3802.4	3818.2	3856.8	3872.6
37.5°	3644.8	3666.4	3681.1	3721.9	3734.4
40°	3496.4	3517.9	3541.7	3584.8	3592.7
42.5°	3341.1	3366.0	3394.4	3432.9	3446.5
45°	3184.7	3213.0	3239.1	3270.8	3286.7
47.5°	3015.8	3044.2	3075.9	3112.2	3122.4
50°	2841.3	2874.2	2908.2	2942.2	2960.3
52.5°	2662.2	2701.9	2740.4	2776.7	2793.7
55°	2485.4	2514.9	2561.3	2598.7	2615.8
57.5°	2301.8	2326.7	2368.7	2429.9	2438.9
60°	2114.8	2137.5	2180.5	2230.4	2250.8
62.5°	1908.5	1939.1	1984.5	2047.9	2066.1
65°	1707.9	1737.4	1797.5	1868.9	1898.3
67.5°	1514.1	1524.3	1601.4	1676.2	1723.8
70°	1285.2	1323.7	1413.3	1505.1	1541.3
72.5°	1088.0	1126.5	1225.1	1332.8	1378.1
75°	864.7	918.0	1051.7	1177.5	1221.7
77.5°	668.7	727.6	893.1	1020.0	1071.0
80°	466.9	558.7	738.9	881.7	937.3
82.5°	293.5	406.9	599.5	749.1	797.9
85°	149.6	276.5	474.9	627.9	683.4
87.5°	39.7	179.1	369.5	515.7	572.3
90°	1.1	103.1	279.9	420.5	471.5
92.5°	1.1	57.8	208.5	334.3	386.5
95°	1.1	27.2	145.1	262.9	303.7
97.5°	1.1	11.3	99.7	198.3	239.1
100°	1.1	5.7	63.5	143.9	179.1
102.5°	2.3	3.4	39.7	103.1	131.5
105°	2.3	3.4	23.8	70.3	94.1
107.5°	2.3	3.4	13.6	47.6	64.6
110°	3.4	3.4	7.9	29.5	43.1

TEST NUMBER: P518218

CATALOG NUMBER: HVL8-8-LD4-2HI-50-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	3.4	3.4	4.5	19.3	28.3
115°	3.4	3.4	4.5	12.5	18.1
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)